

Application No. 60117

Permit No. 45076

STATE OF OREGON WATER RESOURCES DEPARTMENT Application for Permit to Appropriate Surface Water

I, City of Roseburg (Name of Applicant)
of 900 S.E. Douglas (Mailing Address), Roseburg, (City)
State of Oregon, 97470 (Zip Code) Phone No. 672-7701 do hereby
make application for a permit to appropriate the following described waters of the State of Oregon:

- The source of the proposed appropriation is South Umpqua River
Umpqua River, a tributary of Umpqua River
- The point of diversion is to be located ft. (N. or S.) and ft. (E. or W.)
from the corner of (Public Land Survey Corner)
#1: 680'N. and 1,760'W from SE Cor. Sec. 14 within SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 14
(If there is more than one point of diversion, each must be described)
#2: 910'N. and 850'W from SE Cor. Sec. 14 within SE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 14
#3: 950'N. and 190'W from SE Cor. Sec. 14 within SE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 14
being within the 1/4 of the 1/4 of
Sec. 27S Tp. 6W R. Douglas, W. M., in the county of Douglas
(N. or S.) (E. or W.)
- Location of area to be irrigated, or place of use if other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
27S	6W	14	SE $\frac{1}{4}$ NE $\frac{1}{4}$	0.1
			SW $\frac{1}{4}$ NE $\frac{1}{4}$	14.0
			NW $\frac{1}{4}$ SE $\frac{1}{4}$	15.0
			SW $\frac{1}{4}$ SE $\frac{1}{4}$	0.6
			SE $\frac{1}{4}$ SE $\frac{1}{4}$	8.0
27S	6W	23	NE $\frac{1}{4}$ NE $\frac{1}{4}$	4.5
27S	6W	24	NW $\frac{1}{4}$ NW $\frac{1}{4}$	0.4
27S	6W	13	SE $\frac{1}{4}$ SE $\frac{1}{4}$	2.3
				44.9 Total

4. The amount of water which the applicant intends to apply to beneficial use is 0.56

cubic feet per second.....
(If water is to be used from more than one source, give quantity from each)

5. The use to which the water is to be applied is irrigation.....

6.

DESCRIPTION OF WORKS

Include dimensions and type of construction of diversion dam and headgate, length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

27S R6W Division 2 - Consists of a U.S. electrical motor 25 hp pump that delivers 250 GPM, is pumped into a 6" cement asbestos pipe mainline 1,000 yards in length branching off this mainline is four 3" pvc lines. Each about 500' to 700' in length. Branching from the 3" lines are 1¼ to 1½ inch lateral lines with Rain bird heads that deliver from 0 to 37 GPM. All system is in the ground.

27S R6W Division 3 - Consists of Duty Master 25 hp pump that delivers 275 GPM into a 6" iron pip mainline that is 700 feet in length then is reduced to 4" for about 600 feet. From this mainline is one 4" pvc line 500 feet long and three 3" lines 400 feet in length. The 3" line have 1¼ to 1½ lateral lines that have rain bird no. 27 and no. 51 heads that deliver from 0 to 37 GPM. All system is in the ground.

If for domestic use state number of families to be supplied

7. Construction work will begin on or before 1980

8. Construction work will be completed on or before 1981


9. The water will be completely applied to the proposed use on or before 1982

Application No. 60117

Permit No. 45076

Remarks:.....

.....
.....
.....
.....
.....
.....
.....


Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before, 19.....

WITNESS my hand this day of....., 19.....

..... Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

..... 9th day of May, 19..... 80, at 8:00 o'clock

..... A.M.

Application No. 60117

Permit No. 45076

Application No.

60117

Permit No.

45076

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.56 cubic feet per second measured at the point of diversion from the stream, or its equivalent in case of rotation with other water users, from South Umpqua River

The use to which this water is to be applied is irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2½ acre feet per acre for each acre irrigated during the irrigation season of each year,

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The priority date of this permit is May 9, 1980


Actual construction work shall begin on or before September 19, 1981 and shall

thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1982

Extended to Oct. 1, 1983

Complete application of the water to the proposed use shall be made on or before October 1, 1983

WITNESS my hand this 19th day of September , 1980


Water Resources Director

244 A