



COQUILLE

RIVER

**PLAT**

FOR APPLICATION TO APPROPRIATE WATER FOR DOMESTIC PURPOSES  
 Showing Reservoir Creek, location of Diverting Reservoir on Same and location of Pipe line from reservoir to A.T. Bestull's Residence

**DESCRIPTION OF WORKS**

The head works consist of Concrete dam from which a 2" Galvanized iron pipe 40 feet long runs into the top of a reinforced Concrete Reservoir 6 feet wide at one end and 9.8 feet wide at the other 12 feet long 6.2 feet deep with arched roof and containing approximately 450 gallons. Reservoir is provided with man hole in roof, 2 inch flush pipe and 2 inch overflow or waste pipe. Leading from the Reservoir, 2 inch Galvanized Iron Pipe is laid for a distance of 500 feet; from this point 1 1/2 inch pipe is laid for 700 feet to River; from here 1 1/2 inch pipe is laid across the River well bedded in the bottom; from this point 1" pipe is laid to the end of line at the Residence of A.T. Bestull, where it is reduced to 3/4" to be used in the residence and out to 1 1/2" for Domestic Purposes. The intake is situated 150 feet above the outlet.

**CERTIFICATE OF SURVEYOR**

I, A. M. Gould, County Surveyor of Coos County, hereby certify that this map was made from notes taken by me in 1914 and that I have made a careful check and in the accompanying application together with the location of streams in the immediate vicinity. Dated at the office of the County Surveyor at Coquille, Oregon, this 5th day of September, 1914.  
 A. M. Gould  
 County Surveyor, Coos Co. Oreg.

RECEIVED  
 JAN 11 1915  
 SALEM, OREGON

Application No. 4059  
 Permit No. 2319

RECEIVED  
 SALEM, OREGON