

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED 6-7510 3N/28E-23

State Well No.

JAN 19 1977

State Permit No.

WATER RESOURCES DEPT.

(1) OWNER:

Name L.L. FARINS
 Address P.O. Box
RCHO, ORE.

UMAT
1214

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable
 Driven Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

16" Diam. from +1 ft. to -60 ft. Gage 250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
 Type Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 EST-2000 GPM AIR BFT " "
 " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 " " " " "
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used HEAT CEMENT
 Well sealed from land surface to 6.0 ft.
 Diameter of well bore to bottom of seal 2.0 in.
 Diameter of well bore below seal 16 in.
 Number of sacks of cement used in well seal 30 sacks
 Number of sacks of bentonite used in well seal sacks
 Brand name of bentonite
 Number of pounds of bentonite per 100 gallons
 of water lbs./100 gals.
 Was a drive shoe used? Yes No Plugs Size: location
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

SALEM, OREGON
 County WATILLA Driller's well number LEL #3
NW 1/4 NW 1/4 Section 23 T. 3N. R. 28 E.W.M.
 Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 40 ft.
 Static level 51 ft. below land surface. Date 12-18-76
 Artesian pressure NONE lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8" below
 Depth drilled 936 ft. Depth of completed well 936 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY SOIL	0	12	
SOFT BROWN BASALT	12	40	water
HARD GREY BASALT	40	127	
BROKEN RED SOAPSTONE	127	140	water
GREY BASALT	140	172	
BROKEN RED SOAPSTONE	172	190	water
VERY HARD GREY BASALT	190	272	
GREY SOAPSTONE	272	277	
MED. HARD GREY BASALT	277	415	
VERY HARD GREY	415	478	
SOFT GREY BASALT	478	489	
HARD GREY	489	638	
SOFT GREY	638	645	
MED. HARD GREY	645	670	
BROKEN RED	670	702	water
HARD GREY	702	814	
BROKEN GREY	814	842	water
HARD GREY	842	912	
BROKEN GREY	912	936	water

Work started 12-3 19 76 Completed 12-18 19 76
 Date well drilling machine moved off of well 12-18 19 76

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] W. Wallace Date 1-17, 19 77
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

[Signed] Wallace Well Dring. Co. Date 1-17, 19 77
 (Person, firm or corporation) (Type or print)

Address TEMPLETON, ORE.

[Signed] Wallace (Water Well Contractor)

Contractor's License No. 583 Date 1-17, 19 77

RECEIVED

JUN 08 2012

WATER RESOURCES DEPT
 SALEM, OREGON

(USE ADDITIONAL SHEETS IF NECESSARY)

1011429

SP#45856-119

RECEIVED

UMAT 5816

3N/28E/236
46860

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

MAY 17 1993

WATER RESOURCES DEPT.
SALEM, OREGON

(START CARD) #

(1) OWNER:

Name L & L Farms
Address P.O. Box 63
City Echo State OR Zip 97826

(2) TYPE OF WORK:

New Well Deepen Recondition Abandon

(3) DRILL METHOD:

Rotary Air Rotary Mud Cable
 Other

(4) PROPOSED USE:

Domestic Community Industrial Irrigation
 Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:

Special Construction approval Yes No Depth of Completed Well 1055 ft.
Explosives used Yes No Type _____ Amount _____

HOLE Diameter	From To		Material	SEAL From To		Amount sacks or pounds
14"	0	600	N/A			
8"	600	1055				

How was seal placed: Method A B C D E
 Other

Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Casing: <u>N/A</u>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) _____

(7) PERFORATIONS/SCREENS:

Perforations Method _____
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailer Air Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
<u>1500+</u>		<u>1055</u>	<u>1 hr.</u>

Temperature of Water 62° Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

(9) LOCATION OF WELL by legal description:

County Umatilla Latitude _____ Longitude _____
Township 3N N or S. Range 28E E or W. WM.
Section 23 NW 1/4 NW 1/4
Tax Lot 7100 Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) Echo, OR 97826

(10) STATIC WATER LEVEL:

349 ft. below land surface. Date 1-26-93
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:

Depth at which water was first found 978

From	To	Estimated Flow Rate	SWL
<u>978</u>	<u>986</u>	<u>300</u>	

(12) WELL LOG:

Ground elevation _____

Material	From	To	SWL
<u>Reconditioning & Deepening Procedure:</u>			
<u>Existing hole was:</u>			
	<u>14"</u>	<u>0 to 500</u>	
	<u>8"</u>	<u>500 to 936</u>	
<u>Well was reamed to</u>			
	<u>14"</u>	<u>500 to 600.</u>	
<u>Well was deepened</u>			
		<u>from 936 to 1055.</u>	
<u>Gray basalt</u>	<u>936</u>	<u>978</u>	
<u>Black basalt with green soapstone</u>	<u>978</u>	<u>986 WB</u>	
<u>Gray basalt</u>	<u>986</u>	<u>1055</u>	

RECEIVED

JUN 08 2012

WATER RESOURCES DEPT
SALEM OREGON

Date started 12-22-93 Completed 1-26-93

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

WWC Number _____
Signed _____ Date _____

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

WWC Number 1218
Signed Petrucci Wallace Date 2-20-93

1011429

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)
WATER RESOURCES DEPT.
SALEM, OREGON

RECEIVED

MAY 25 1976 State Well No. 67441

3N/28E-26

UMAT
1216

EL#2

(1) OWNER:

Name L & B FARMS INC.
Address P.O. Box 611
ECHO, ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 81 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No. If yes, by whom?
Yield: 1000 gal./min. with _____ ft. drawdown after _____ hrs.
AIR LIFT " " " "
" " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow NONE g.p.m.
Temperature of water 67 Depth artesian flow encountered NONE ft.

(9) CONSTRUCTION:

Well seal—Material used HEAT CEMENT
Well sealed from land surface to 81 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 14 in. TO 450 FT.
Number of sacks of cement used in well seal 50 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water 5 GAL. WATER PER 500 CEMENT lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number 7-76
NE 1/4 NW 1/4 Section 26 T. 3N R. 28 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 327 ft.
Static level 330 ft. below land surface. Date 5-7-76
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 14" TO 450 FT.

Depth drilled 911 ft. Depth of completed well 911 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SAND, SILT	0	4	
CLAY	4	12	
GRAVEL	12	38	
BROWN BASALT	38	67	
HARD GREY BASALT	67	145	
BROKEN RED BASALT	145	165	
HARD GREY BASALT	165	274	
BROKEN GREY BASALT	274	295	
HARD GREY BASALT	295	327	
BROKEN W/ SOAP STONE	327	341	WATER
HARD GREY BASALT	341	425	
BROKEN GREY SOAPSTONE	425	435	WATER
HARD GREY BASALT	435	601	
BROKEN GREY BASALT	601	608	
HARD GREY BASALT	608	615	
BROKEN GREY BASALT	615	650	
MED. HARD GREY	650	870	
BROKEN GREY BASALT	870	901	WATER
HARD GREY BASALT	901	911	

Work started 4-26 1976 Completed 5-7 1976
Date well drilling machine moved off of well 5-7 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Corett A. Wallace Date 5-23 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Wallace Well Drilling Co.
(Person, firm or corporation) (Type or print)

Address Box 172 Pendleton, OR.

[Signed] Corett A. Wallace
(Water Well Contractor)

Contractor's License No. 523 Date 5-23 1976

WATER RESOURCES DEPT. (PLEASE PRINT IF NECESSARY)

SALEM OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT UMAT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. _____

State Permit No. G-5812

(1) OWNER:

Name Glen Maddox
Address P. O. BOX P, Moses Lake, Wa. 98837

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "

Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used _____ RECEIVED
Well sealed from land surface to _____ ft.
Diameter of well bore to bottom of seal _____ WATER RESOURCES DEPT
Diameter of well bore below seal _____ SALEM OREGON
Number of sacks of cement used in well seal _____ sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Umatilla Driller's well number #1
1/4 1/4 Section 34 T. 3N R. 28E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ ft.
Static level _____ ft. below land surface. Date _____
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing _____

Depth drilled _____ ft. Depth of completed well _____ ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Basalt soft black	330	339	
Basalt hard black	339	362	
Basalt soft black	362	404	
Basalt hard black	404	486	
Basalt soft blk & clay seams	486	498	
Basalt soft black	498	535	
Basalt med black	535	559	
Basalt brown & black water	559	561	
Basalt soft black	561	569	
Basalt med black	569	584	
Basalt soft black 621' water	584	660	
Basalt hard black 646' water	660	666	
Basalt soft black 700' water	666	707	
Basalt hard black	707	732	
Basalt soft black broken	732	740	
Basalt red soft 740' water	740	750	
Basalt hard black	750	804	
Basalt soft black 810' water	804	830	
825' water.			

Work started _____ 19 _____ Completed _____ 19
Date well drilling machine moved off of well _____ 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19_____
(Drilling Machine Operator)

Drilling Machine Operator's License No. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name _____
(Person, firm or corporation) (Type or print)

Address _____

[Signed] _____
(Water Well Contractor)

Contractor's License No. _____ Date _____, 19____

October 28, 1976

RECEIVED
NOV 1 1976
WATER RESOURCES DEPT.
SALEM, OREGON

Water Resources Department
1178 Chemeketa Street N. E.
Salem, Oregon 97310

Re: File #G-5820 - Permit #G-5812

Gentlemen:

As you can see from the enclosed well log, this well yields 3,260 gallons per minute. This is sufficient water to irrigate the ground that this permit applies to, so it will not be necessary to drill another well. I hope this meets with your approval.

Sincerely yours,

Glen Maddox

GLEN MADDOX
P. O. Drawer P
Moses Lake, Wa. 98837

RECEIVED

JUN 08 2012

WATER RESOURCES DEPT
SALEM OREGON

1011429

UMAT
50476

RECEIVED

WELL I.D.# 208754

STATE OF OREGON
WATER SUPPLY WELL REPORT
(as required by ORS 537.765)

MAR 14 1997

(START CARD) # 096888

Instructions for completing this report are on the last page of the WATER RESOURCES DEPT.

(1) OWNER: Well Number _____
Name SIMPLot
Address PO BOX 850
City Hamilton State OR Zip 97138

(2) TYPE OF WORK
 New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well _____ ft.
Explosives used Yes No Type _____ Amount _____
HOLE SEAL
Diameter From To Material From To Sacks or pounds

How was seal placed: Method A B C D E
 Other _____
Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:
Diameter From To Gauge Steel Plastic Welded Threaded
Casing: _____
Liner: _____

Final location of shoe(s) _____
(7) PERFORATIONS/SCREENS:
 Perforations Method _____
 Screens Type _____ Material _____
From To Slot size Number Diameter Tele/pipe size Casing Liner

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailer Air Flowing Artesian
Yield gal/min Drawdown Depth stem at Time

Temperature of water _____ Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

(9) LOCATION OF WELL by legal description:
County Umatilla Latitude _____ Longitude _____
Township 3N N or S Range 28E E or W. WM.
Section 34 NE 1/4 3E 1/4
Tax Lot _____ Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) _____

(10) STATIC WATER LEVEL:
482 ft. below land surface. Date 2-27-97
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
Depth at which water was first found _____

From	To	Estimated Flow Rate	SWL
/			

(12) WELL LOG:
Ground Elevation _____

Material	From	To	SWL
clear out obstruction in well and run 12" STEELIZED TO BOTTOM			

RECEIVED
JUN 08 2012
WATER RESOURCES DEPT
SALEM OREGON
Date started 2-20-97 Completed 3-5-97
(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.
WWC Number 1683
Signed TONY BOWMAN Date 3-5-97

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.
WWC Number 544
Signed Jerry Burek Date 3-5-97

2011429