

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print) Do not write above this line

UMAT 5209

State Well No. 6N/36-3DE

State Permit No. 6-4080

RECEIVED 1968

G-4322

(1) OWNER: STATE ENGINEER

Name Harold Stillis OREGON
Address B.I. Box 132 M-F. O.R.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 110 ft. Gage 277
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Cutting Torch
Size of perforations 1/8" x 1/4" in. by 6-5-9 in.
294 perforations from 50 ft. to 110 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type AUG 15 2013 Model No. _____
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date Feb 2, 1968
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Flow: gal./min. with " ft. drawdown after " hrs.
Baller test 70 gal./min. with no ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 4.2 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 10-20 gravel
Gravel placed from 50 ft. to 4.2 ft.

(11) LOCATION OF WELL:

County UMATILLS Driller's well number _____
" Section 30 T. 6 R. 36 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 195 ft. Depth of completed well 190 ft.
Formation: Describe color, texture, grain size and structure of waterfiling; and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BROWN SOIL	0	9	
LIGHT BROWN SANDY	9	35	
— + gravel	35	48	
Red Shale - Water	48	67	WT
Brown clay	67	78	W.
Brown clay gra.	78	86	W.
DEPT BANKIN Clay + gra.	86	105	W.
Brown clay + gra.	105	115	W.
Red clay + gravel			
some gravel sand	115	128	W.
Brown clay			
gravel	128	133	
Light Brown clay			
and gravel	133	138	W.
Several layers of gravel small ones	138	175	W.
Brown clay gravel	175	187	
Blue clay +			
lots of gravel	187	195	

Work started Feb 12, 1968 Completed Mar 2, 1968
Date well drilling machine moved off of well Mar 4, 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Richard W. Davis Date Mar 5, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 147

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Richard W. Davis (Type or print)
Address B.I. Box 162 M-F. O.R.
[Signed] Richard W. Davis (Water Well Contractor)
Contractor's License No. 159 Date Mar 5, 1968

White Camp

UMAT 5209

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print) Do not write above this line

State Well No. 6N/36-3DE
State Permit No.

G-4822

(1) OWNER: STATE ENGINEER OREGON
Name Harold Stillie
Address P.O. Box 132 M.F. Co.

(11) LOCATION OF WELL:
County Umatilla Driller's well number
1/4 Section 30 T. 6 R. 36 W.M.
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):
New Well [x] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary [] Driven [] Domestic [] Industrial [] Municipal []
Cable [x] Jetted [] Irrigation [x] Test Well [] Other []
Dug [] Bored []

(5) CASING INSTALLED:
8" Diam. from 0 ft. to 110 ft. Gage 277

(6) PERFORATIONS:
Type of perforator used Casing Taper
Size of perforations 1/4" by 6-59 in.
294 perforations from 50 ft. to 110 ft.

(7) SCREENS:
Well screens installed? [] Yes [x] No
Type Model No.
Diam. Slot size 2013 Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level SALEM, OR 40 ft. below land surface Date Feb 2/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Was a pump test made? [] Yes [x] No
If yes, by whom?
Flow: gal./min. with ft. drawdown after hrs.

Ballor test 70 gal./min. with 70 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? [] Yes [x] No

(10) CONSTRUCTION:
Well seal-Material used Cement
Depth of seal 42 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [x] No
Was a drive shoe used? [x] Yes [] No
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [x] Yes [] No Size of gravel: 20 gravel
Gravel placed from 50 ft. to 42 ft.

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 195 ft. Depth of completed well 190 ft.
Formation: Describe color, texture, grain size and structure of waterlog; and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: BROWN SOIL, LIGHT BROWN SANDY, Red Brown water, Brown clay, etc.

Work started Feb 12 1968 Completed Mar 2 1968
Date well drilling machine moved off of well Mar 4 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Rudd W. Davis Date Mar 5 1968

Drilling Machine Operator's License No. 147

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Rudd W. Davis
Address P.O. Box 162 M.F. Co.
[Signed] Rudd W. Davis
Contractor's License No. 159 Date Mar 5 1968