



NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

APR 18 2011 WATER WELL REPORT UMAT

STATE OF OREGON

State Well No. \_\_\_\_\_

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

SALEM, OR (Please type or print) (Do not write above this line)

State Permit No. G-5812

(1) OWNER:

Name Glen Maddox Address P. O. Box P, Moses Lake, Wa. 98837

(2) TYPE OF WORK (check):

New Well [ ] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

Threaded [ ] Welded [ ]

Diam. from ft. to ft. Gage ...

PERFORATIONS:

Perforated? [ ] Yes [ ] No.

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [ ] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [ ] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION:

Well seal—Material used Well sealed from land surface to ft. Diameter of well bore to bottom of seal in.

(10) LOCATION OF WELL:

County Umatilla Driller's well number #1 1/4 1/4 Section 34 T. 3N R. 28E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found ft.

Static level ft. below land surface. Date

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing

Depth drilled ft. Depth of completed well ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated.

Table with columns: MATERIAL, From, To, SWL. Rows include Basalt soft black, Basalt hard black, Basalt soft black, Basalt hard black, Basalt soft blk & clay seams, Basalt soft black, Basalt med black, Basalt brown & black water, Basalt soft black, Basalt med black, Basalt soft black 621 water, Basalt hard black 646 water, Basalt soft black 700 water, Basalt hard black, Basalt soft black broken, Basalt red soft 740 water, Basalt hard black, Basalt soft black 812 water, 825 water.

Work started 19 Completed 19 Date well drilling machine moved off of well 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date, 19... (Drilling Machine Operator)

Drilling Machine Operator's License No.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name (Person, firm or corporation) (Type or print)

Address

[Signed] (Water Well Contractor)

Contractor's License No. Date, 19...

October 28, 1976

**RECEIVED**  
NOV 1 1976  
WATER RESOURCES DEPT.  
SALEM, OREGON

Water Resources Department  
1178 Chemeketa Street N. E.  
Salem, Oregon 97310

Re: File #G-5820 - Permit #G-5812

Gentlemen:

As you can see from the enclosed well log, this well yields 3,260 gallons per minute. This is sufficient water to irrigate the ground that this permit applies to, so it will not be necessary to drill another well. I hope this meets with your approval.

Sincerely yours,

*Glen Maddox*

GLEN MADDOX  
P. O. Drawer P  
Moses Lake, Wa. 98837

**RECEIVED BY OWRD**  
APR 18 2014  
SALEM, OR

**RECEIVED BY OWRD**

APR 18 2014

SALEM, OR

1011795

UMAT  
50476

RECEIVED WELL I.D.# 208754

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(as required by ORS 537.765)

MAR 14 1997

(START CARD) # 096888

Instructions for completing this report are on the last page of the WATER RESOURCES DEPT.

(1) OWNER: Well Number SALEM, OREGON

Name SIMPLOT  
Address PO BOX 850  
City Hamlet State OR Zip 97038

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well \_\_\_\_\_ ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE SEAL table with columns: Diameter, From, To, Material, From, To, Sacks or pounds

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER: table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded

Final location of shoe(s) \_\_\_\_\_

(7) PERFORATIONS/SCREENS: table with columns: From, To, Slot size, Number, Diameter, Material, Tele/pipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour

Table for well tests with columns: Pump, Bailer, Air, Flowing Artesian, Yield gal/min, Drawdown, Depth stem at, Time

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Umatilla Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 3N N or S Range 28E E or W. WM.  
Section 34 NE 1/4 SE 1/4  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) \_\_\_\_\_

(10) STATIC WATER LEVEL:  
482 ft. below land surface. Date 2-27-97  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES: table with columns: From, To, Estimated Flow Rate, SWL

(12) WELL LOG: Ground Elevation \_\_\_\_\_

Table for well log with columns: Material, From, To, SWL

Date started 2-20-97 Completed 3-5-97

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

WWC Number 1683  
Signed TONY BOWMAN Date 3-5-97

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

WWC Number 544  
Signed Jerry Burel Date 2-5-97

1011795

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

UMAT  
1216

WATER WELL REPORT

RECEIVED

67441

3N/28E-26

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON  
(Please type or print)

MAY 25 1976 State Well No.

WATER RESOURCES DEPT.  
SALEM, OREGON State Permit No.

LEL#2

(1) OWNER:

Name L.H. FARMS INC.  
Address P.O. Box 611  
ECHO, ORE.

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
16" Diam. from 0 ft. to 81 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No

Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is  
lowered below static level

Was a pump test made?  Yes  No. If yes, by whom?  
Yield: 1000 gal./min. with ft. drawdown after hrs.  
AIR LIFT " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow NONE g.p.m.  
Temperature of water 67 Depth artesian flow encountered NONE ft.

(9) CONSTRUCTION:

Well seal—Material used HEAT CEMENT  
Well sealed from land surface to 81 ft.  
Diameter of well bore to bottom of seal 20 in.  
Diameter of well bore below seal 14 in. TO 450 FT.  
Number of sacks of cement used in well seal 50 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons 5 GAL. WATER PER BAG CEMENT lbs./100 gals.  
of water  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number 7-76  
NE 1/4 NW 1/4 Section 26 T. 3N R. 28 E. W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 327 ft.  
Static level 330 ft. below land surface. Date 5-7-76  
Artesian pressure NONE lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 14" TO 450 FT.

Depth drilled 911 ft. Depth of completed well 911 ft.

Formation: Describe color, texture, grain size and structure of materials;  
and show thickness and nature of each stratum and aquifer penetrated,  
with at least one entry for each change of formation. Report each change in  
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SAND, SILT	0	4	
CLAY	4	12	
GRAVEL	12	38	
BROWN BASALT	38	67	
HARD GREY BASALT	67	145	
BROKEN RED BASALT	145	165	
HARD GREY BASALT	165	274	
BROKEN GREY BASALT	274	295	
HARD GREY BASALT	295	327	
BROKEN W/ SOAPSTONE	327	341	WATER
HARD GREY BASALT	341	425	
BROKEN GREY SOAPSTONE	425	435	WATER
HARD GREY BASALT	435	601	
BROKEN GREY BASALT	601	608	
HARD GREY BASALT	608	615	
BROKEN GREY BASALT	615	650	
MED. HARD GREY	650	870	
BROKEN GREY BASALT	870	901	WATER
HARD GREY BASALT	901	911	

Work started 4-26 1976 Completed 5-7 1976  
Date well drilling machine moved off of well 5-7 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.  
Materials used and information reported above are true to my  
best knowledge and belief

[Signed] Lorett A. Wallace Date 5-23, 1976  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is  
true to the best of my knowledge and belief

Name WALLACE WELL DRILLING CO.  
(Person, firm or corporation) (Type or print)

Address Box 122 Pendleton, OR.

[Signed] Lorett A. Wallace  
(Water Well Contractor)

Contractor's License No. 583 Date 5-23, 1976





RECEIVED

UMAT 5816

3N/28E/236 46860

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

MAY 17 1993

WATER RESOURCES DEPT. SALEM, OREGON

(START CARD) #

(1) OWNER:

Name L & L Farms Address P.O. Box 63 City Echo State OR Zip 97826

(2) TYPE OF WORK:

New Well Deepen Recondition Abandon

(3) DRILL METHOD:

Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:

Domestic Community Industrial Irrigation Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:

Special Construction approval Yes No Depth of Completed Well 1055 ft. Explosives used Yes No Type Amount

Table with columns: HOLE Diameter, From, To, Material, SEAL From, To, Amount sacks or pounds. Includes handwritten entries for 14" and 8" diameters.

How was seal placed: Method A B C D E Other

Backfill placed from ft. to ft. Material

Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes handwritten entry for N/A casing.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS:

Perforations Method Screens Type Material

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailer Air Flowing Artesian

Table with columns: Yield gal/min, Drawdown, Drill stem at, Time. Includes handwritten entry for 1500+ yield and 1055 drill stem at.

Temperature of Water 62° Depth Artesian Flow Found Was a water analysis done? Did any strata contain water not suitable for intended use? Salty Muddy Odor Colored Other

(9) LOCATION OF WELL by legal description:

County Umatilla Latitude Longitude Township 3N N or S. Range 28E E or W. WM. Section 23 NW 1/4 NW 1/4 Tax Lot 7100 Lot Block Subdivision Street Address of Well (or nearest address) Echo, OR 97826

(10) STATIC WATER LEVEL:

349 ft. below land surface. Date 1-26-93 Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES:

Table with columns: From, To, Estimated Flow Rate, SWL. Includes handwritten entry for 978 depth and 300 flow rate.

(12) WELL LOG:

Ground elevation

Table with columns: Material, From, To, SWL. Includes handwritten entries for Reconditioning & Deepening Procedure, Existing hole was, Gray basalt, Black basalt with green soapstone, Gray basalt.

Date started 12-22-93 Completed 1-26-93

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Date WWC Number

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed Patrick Wallace Date 2-20-93 WWC Number 1218

T011795

