

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

JUN 12 1973

State Well No.

STATE ENGINEER

SALEM, OREGON

State Permit

RECEIVED

(1) OWNER:

Name Donald J. Dieringer
Address 8085 S W Ridgeway Dr.
Portland, Oregon 97225

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 205 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used

Mills Knife

Size of perforations 3/8 in. by 34 in.
912 perforations from 160 ft. to 198 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller

Yield: 1200 gal./min. with 80 ft. drawdown after 10 hrs.

Ball test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement & Bentonite

Well sealed from land surface to 30 ft.

Diameter of well bore to bottom of seal 16 in.

Diameter of well bore below seal 12 in.

Number of sacks of cement used in well seal 3 sacks

Number of sacks of bentonite used in well seal 6 sacks

Brand name of bentonite Portland Western

Number of pounds of bentonite per 100 gallons
of water 600 lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plug Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number JUN 24 2014
1/4 1/4 Section 35 T. 4S R. 1W W.M.
Bearing and distance from section or subdivision corner
WATER RESOURCES DEPT
SALEM, OREGON

(11) WATER LEVEL: Completed well.

Depth at which water was first found 91 ft.

Static level 35 ft. below land surface. Date 6-6-73

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 205 ft. Depth of completed well 205 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Brown sandy clay	3	58	
Brown sand	58	65	
Blue sandy clay	65	91	
Med. gravel	91	97	
Black sand	97	104	
Blue sandy clay	104	123	
Black sand	123	145	
Blue clay	145	160	
Sand and small gravel	160	175	
Sand and med. gravel	175	201	
Blue clay	201	205	

Work started 4-29 1973 Completed 5-16 1973

Date well drilling machine moved off of well 5-16 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Sharon D. Shuster Date 6-6, 1973.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 782

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name William D. Christenson Jr.
(Person, firm or corporation) (Type or print)

Address P.O. Box 213 Hubbard, Oregon

[Signed] William D. Christenson Jr.
(Water Well Contractor)

Contractor's License No. 511 Date 6-6 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-43456-119