

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT 80 1973

STATE OF OREGON STATE ENGINEER

(Please type or print)
(Do not write above this line)

State Permit No.

G-6071

(1) OWNER:

Name DALE C, JAMES D, + WILLIAM J HUDSONAddress 1200 28th St Boulder Colo 80303

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

12" Diam. from 0 ft. to 225 1/2 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 6 ft. below land surface Date 24 JUNE 72

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller

Rate: 1325 gal./min. with 20 1/2 ft. drawdown after 4 hrs.

Ball test gal./min. with ft. drawdown after hrs.

Artisan flow g.p.m. Date

Temperature of water 60° Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used CONCRETE

Depth of seal 18' ft.

Diameter of well bore to bottom of seal 14 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☒ Yes ☐ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County HARNEY Driller's well number 269

CENTRE NE 1/4 Section 7 T. 24S R. 33E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 260 ft. Depth of completed well 255 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL + BROWN SAND	0	10'	
BROWN SAND	10'	25'	
BLUE CLAY	25'	30'	9FT
GREY CLAY	30'	40'	9FT
SHALE, GREEN	40'	55'	9FT
CLAY + BROWN	55'	65'	9FT
CLAY - BLUE	65'	100'	9FT
SANDSTONE, BLACK	100'	105'	9FT
CLAY, BLUE	105'	180'	9FT
CLAY, BLACK	180'	225'	9FT
CLAY, GREEN	215'	235'	9FT
COARSE GRAVEL + COARSE SAND	235'	260'	6FT

RECEIVED BY OWRD

AUG 18 2014

SALEM, OR

Work started 17 JUNE 1972 Completed 24 JUNE 1972

Date well drilling machine moved off of well 26 JUNE 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John W. Rossberg Date 24 JUNE, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 269

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Rossberg + Son Irrigation Co
(Person, firm or corporation) (Type or print)

Address Box 767, CRANE, ORE 97732

[Signed] John W. Rossberg
(Water Well Contractor)

Contractor's License No. 272 Date 24 JUNE, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)