

RECEIVED  
JUL 20 1966

Elmer Fry Water Master  
Walla, Ore.  
29 64384  
700

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON  
(Please type or print)

002864

State Well No. 2N/12-18  
State Permit No.

(1) OWNER:  
Name Gore Wilson Orchards  
Address Mosier Ore

(2) LOCATION OF WELL:  
County Wasco Driller's well number  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:  
8" Diam. from 0 ft. to 80 ft. Gage 250  
6" Diam. from 0 ft. to 300 ft. Gage 250

(7) PERFORATIONS:  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.

(8) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Slot size Set from ft. to ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal Cement  
Depth of seal 20 ft. Was a packer used? No  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth 15  
Was a drive shoe used?  Yes  No 8"  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:  
Static level 3 FT Above ft. land surface Date  
Artesian pressure 35 lbs. per square inch Date

(11) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
Ballor test gal./min. with ft. drawdown after hrs.  
Artesian flow 115 g.p.m. Date  
Temperature of water 51 Was a chemical analysis made?  Yes  No

(12) WELL LOG:  
Diameter of well below casing 6  
Depth drilled 315 ft. Depth of completed well 315 ft.  
Formation: Describes by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Topsoil Red Clay</u>	<u>0</u>	<u>7</u>
<u>Clay + sand</u>	<u>7</u>	<u>15</u>
<u>Blue clay</u>	<u>15</u>	<u>75</u>
<u>Sand - light</u>	<u>75</u>	<u>78</u>
<u>Black Basalt-Solid</u>	<u>78</u>	<u>235</u>
<u>Blue Tuffaceous Clay</u>	<u>235</u>	<u>261</u>
<u>Black Basalt</u>	<u>261</u>	<u>301</u>
<u>Gravel + Boulders containing water</u>	<u>301</u>	<u>315</u>

RECEIVED BY OWRD

DEC 22 2014

SALEM, OR

Work started 19 Completed 6-21-66 19  
Date well drilling machine moved off of well 19

(13) PUMP:  
Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Brandt Drilling Co.  
(Person, firm or corporation) (Type or print)  
Address 675 Crestview Rd.  
Drilling Machine Operator's License No. 189  
[Signed] John Pettus  
(Water Well Contractor)  
Contractor's License No. 401 Date 7-24- 1966

NASC 50497

RECEIVED

STATE OF OREGON

WELL ID # L19606

WATER SUPPLY WELL REPORT

MAY 27 1998

(as required by ORS 537.765)

(START CARD) # 101316

Instructions for completing this report are on the last page of this form

WATER RESOURCES DEPT.

SALEM, OREGON

REGISTRATION OF WELL by legal description:

(1) OWNER:

Well Number:

Name Charles R. Gove
Address 1300 Carroll Rd.
City Mosler, State OR Zip 97040

County Wasco Latitude Longitude
Township 2N N or S. Range 12E E or W. of WM.
Section 7 NW 1/4 SW 1/4
Tax Lot 1700 Lot Block Subdivision
Street Address of Well (or nearest address)
1300 Carroll Rd. Mosler, Or.

(2) TYPE OF WORK:

New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:

Rotary Air Rotary Mud Cable Auger
Other

(10) STATIC WATER LEVEL:

45 ft. below land surface. Date 5/24/98
Artesian pressure lb. per square inch. Date

(4) PROPOSED USE:

Domestic Community Industrial Irrigation
Thermal Injection Livestock Other

(11) WATER BEARING ZONES:

Depth at which water was first found

Table with columns: From, To, Estimated Flow Rate, SWL

(5) BORE HOLE CONSTRUCTION:

Special Construction approval Yes No Depth of Completed Well 316 ft.
Explosives used Yes No Type Amount

Table for HOLE and SEAL construction details including diameter, material, and amount.

How was seal placed: Method A B C D E

Other Did Not Disturb

Backfill placed from ft. to ft. Material
Gravel placed from ft. to ft. Size of gravel

(12) WELL LOG:

Ground elevation

Clean out existing well to 316ft. Install Liner, 4.5" PVC Land surface to 316 ft.

RECEIVED

JUN 25 1998

WATER RESOURCES DEPT.
SALEM, OREGON

RECEIVED BY OWRD

DEC 22 2014

SALEM, OR

(6) CASING/LINER:

Table for casing and liner specifications including diameter, gauge, and material.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS:

Table for perforation and screen details including slot size, number, diameter, and material.

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailer Air Flowing Artesian

Yield gal/min Drawdown Drill stem at Time
100 316 1 hr.

Temperature of Water 56 Depth Artesian Flow found
Was a water analysis done? Yes By whom
Did any strata contain water not suitable for intended use? Too little
Salty Muddy Odor Colored Other
Depth of strata:

Date started 5/21/98 Completed 5/24/98

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed WWC Number Date

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed Austin Well Drilling WWC Number 790 Date 5/26/98

RECEIVED

DEC 22 2014

MAY - 5 1997

STATE OF OREGON  
WATER SUPPLY WELL REPORT (as required by ORS 537.765)  
Instructions for completing this report are on the last page of this form

WATER RESOURCES DEPT.  
SALEM, OREGON

WELL ID # **LO7088**  
(START CARD) # **52357**

(1) OWNER: Well Number: \_\_\_\_\_  
Name **Charles R. Gove**  
Address **1300 Carroll Rd.**  
City **Mosier** State **OR** Zip **97040**

(2) TYPE OF WORK:  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well **344** ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE			SEAL			Amount
Diameter	From	To	Material	From	To	sacks or pounds
14"	0	81	Cement	0	81	70 Bags
10"	81	275				
8"	275	344				

How was seal placed: Method  A  B  C  D  E  
 Other  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 10"	0	81	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8"	275	306	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) **306 ft.**

(7) PERFORATIONS/SCREENS:

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Baker  Air  Flowing Artesian  
Yield gal/min **400** Drawdown **340** Drill stem at **1 hr.** Time

Temperature of Water **61** Depth Artesian Flow found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County **Wasco** Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township **2N** N or S. Range **12E** E or W. of WM.  
Section **7** NW **1/4** SW **1/4**  
Tax Lot **1700** Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address)  
**1300 Carroll Rd., Mosier, Or. 97040**

(10) STATIC WATER LEVEL:  
**46** ft. below land surface. Date **3/21/97**  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found **65**

From	To	Estimated Flow Rate	SWL
65	71	50	43
134	137	15	
298	340	400	48

(12) WELL LOG:

Material	From	To	SWL
10" casing sealed to 81 ft. 70 Bags cement in seal.			
306 ft. 8" casing Drill and Drive from 275 to 306			
Soil Sandy Brown	0	15	
Sand & Clay Brown	15	25	
Clay Gray	25	60	
Rock Soft Black	60	65	
Gravel Black Medium W/B	65	71	
Gravel Large Black	71	74	
Sandstone Coarse Hard Brown	74	81	
Basalt Hard Gray	81	109	
Basalt Med. Fract. Gray	109	134	
See next line	134	137	
Basalt Broken W/Green Clay Seam, Gray W/B 15 dpm			
Basalt Hard Fract. Gray	137	160	
Basalt Hard Gray	160	214	
Basalt Med Fract. Gray	214	244	
Clay Stone Green	244	284	
Clay Gray	284	298	
Gravel Med. Multi Color W/B	298	340	
Basalt Med. Hard Black	340	344	46

Date started **2/20/97** Completed **3/21/97**  
(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to my best knowledge and belief.  
Signed \_\_\_\_\_ WWC Number \_\_\_\_\_ Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
Signed *Austin Well Drilling* WWC Number **790** Date **5-1-97**