

Application for Groundwater Registration Modification

Part 1 of 4 – Minimum Requirements Checklist



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem, Oregon 97301-1266
(503) 986-0900
www.oregon.gov/OWRD

This Groundwater Registration Modification application will be returned if Parts 1 through 4 and all required attachments are not completed and included.

For questions, please call (503) 986-0900, and ask for Transfer Section.

Check all included with this application (N/A = Not Applicable)

- ☒ Part 1 – Completed Minimum Requirements Checklist.
- ☒ Part 2 – Completed Application Map Checklist.
- ☒ Part 3 – Completed Applicant Information and Signature.
- ☒ Part 4 – Completed Groundwater Registration Modification Application – Groundwater Registration Information. (Only one Groundwater registration per application, unless the Groundwater registrations to be modified are layered).
- ☒ Completed Groundwater Registration Modification Application Map (Does not have to be prepared by a Certified Water Right Examiner).
- ☒ **Application Fee** - payable by check to the Oregon Water Resources Department, the online fee calculator is located:
https://apps.wrd.state.or.us/apps/wr/wr_transfer_calculator/groundwater_modification.aspx

Received

NOV 21 2025

OWRD

Attachments:

- ☐ ☒ N/A Request for Assignment Form and statutory fee. This form needs to be completed if the applicant owns the land to which the registration is appurtenant and is **not** the registration certificate holder of record. The Request for Assignment Form is available at <https://www.oregon.gov/OWRD/Forms/Pages/default.aspx>.
Assignment is not needed for any person or entity who can demonstrate authorization to request recognition of a modification (e.g. legal representative, power of attorney, agent, etc.) **or** the applicant is named on the certificate of registration, or has been assigned to the certificate of registration.
- ☒ ☐ N/A Oregon Water Resources Department's Land Use Information Form with approval and signature from each local land use authority in which water is to be diverted, conveyed, and/or used. Not required if water is to be diverted, conveyed, and/or used only on federal lands or if **all** of the following apply: a) a change in place of use only, b) no structural changes, c) the use of water is for irrigation only, and d) the use is located within an irrigation district or an exclusive farm use zone.
- ☒ ☐ N/A Water Well Report/Well Log for changes in point(s) of appropriation (well(s)) or additional point(s) of appropriation.

(For Staff Use Only)

WE ARE RETURNING YOUR APPLICATION FOR THE FOLLOWING REASON(S):

- ☐ Application fee not enclosed/insufficient
- ☐ Map not included or incomplete
- ☐ Land Use Form not enclosed or incomplete
- ☐ Additional signature(s) required
- ☐ Part _____ is incomplete

Other/Explanation _____
Staff: _____ 503- _____ Date: ____/____/____

Part 2 of 4 – Groundwater Registration Modification Map Checklist

Your Groundwater Registration Modification application will be returned if any of the map requirements listed below are not met.

Please be sure that the map you submit includes all the items listed below and meets the requirements of OAR 690-380-3100, however, the map does not have to be prepared by a Certified Water Right Examiner. Check all boxes that apply.

- ☒ Permanent quality printed with dark ink on good quality paper.
- ☒ The size of the map can be 8½ x 11 inches, 8½ x 14 inches, 11 x 17 inches, or up to 30 x 30 inches. For 30 x 30 inch maps, one extra copy is required.
- ☒ A north arrow, a legend, and scale.
- ☒ The scale of the map must be: 1 inch = 400 feet, 1 inch = 1,320 feet, the scale of the county assessor map if the scale is not smaller than 1 inch = 1,320 feet, or a scale that has been pre-approved by the Department.
- ☒ Township, Range, Section, ¼ ¼, DLC, Government Lot, and other recognized public land survey lines.
- ☒ Tax lot boundaries (property lines) are required. Tax lot numbers are recommended.
- ☒ Major physical features including rivers and creeks showing direction of flow, lakes and reservoirs, roads and railroads.
- ☒ Major water delivery system features from the point(s) of appropriation such as main pipelines, canals, and ditches.
- ☒ Existing place of use that includes hachuring, priority date, and use including number of acres in each quarter-quarter section, government lot, or in each quarter-quarter section as projected within government lots, donation land claims, or other recognized public land survey subdivisions. If less than the entirety of the registration is being changed, a separate hachuring is needed for the portion of the registration left unchanged.
- ☐ ☒ N/A If you are proposing a modification in place of use, show the proposed place of use with hachuring including priority date and use including number of acres in each quarter-quarter section, government lot, or in each quarter-quarter section as projected within government lots, donation land claims, or other recognized public land survey subdivisions.
- ☒ Existing point(s) of appropriation with distance and bearing or coordinates from a recognized survey corner.
- ☒ ☐ N/A If you are proposing a modification in point(s) of appropriation, show the proposed location and label it clearly with distance and bearing or coordinates. If GPS coordinates are used, latitude-longitude coordinates may be expressed as either degrees-minutes-seconds with at least one digit after the decimal (example – 42°32'15.5") or degrees-decimal with five or more digits after the decimal (example – 42.53764°).

Received

NOV 21 2025

Part 3 of 4 – Applicant Information and Signature

Applicant Information

APPLICANT/BUSINESS NAME City of Sublimity			PHONE NO. 503-769-5475	ADDITIONAL CONTACT NO.
ADDRESS PO Box 146			FAX NO.	
CITY Sublimity	STATE OR	ZIP 97385	E-MAIL	
BY PROVIDING AN E-MAIL ADDRESS, CONSENT IS GIVEN TO RECEIVE ALL CORRESPONDENCE FROM THE DEPARTMENT ELECTRONICALLY. COPIES OF THE FINAL ORDER DOCUMENTS WILL ALSO BE MAILED.				

Agent Information – The agent is authorized to represent the applicant in all matters relating to this application

APPLICANT/BUSINESS NAME 4B Engineering & Consulting, LLC			PHONE NO. 503-580-8152	ADDITIONAL CONTACT NO.
ADDRESS 4454 71st Ave SE			FAX NO.	
CITY Salem	STATE OR	ZIP 97317	E-MAIL brooke.4b@outlook.com	
BY PROVIDING AN E-MAIL ADDRESS, CONSENT IS GIVEN TO RECEIVE ALL CORRESPONDENCE FROM THE DEPARTMENT ELECTRONICALLY. COPIES OF THE FINAL ORDER DOCUMENTS WILL ALSO BE MAILED.				

Received
NOV 21 2025
OWRD

Explain in your own words what you propose to accomplish with this modification; and why:
The property for the new APOA (Well #5) is inside of the City of Sublimity city limits and UGB. The existing POA Well #1 on the GR claim will also remain.

If you need additional space, continue on a separate piece of paper and attach to the application as "Attachment 1".


☐ Check this box if this project is fully or partially funded by the American Recovery and Reinvestment Act. (Federal stimulus dollars)

(Check one box)

- ☐ By signing this application, I (we) understand that, upon receipt of the draft preliminary determination and prior to Department approval of the Groundwater modification, I (we) will be required to provide landownership information and evidence that I am authorized to pursue the modification as identified in OAR 690-382-0400(16)(a); **OR**
- ☒ I (we) affirm the applicant is a municipality as defined in ORS 540.510(3)(b) and that the right is in the name of the municipality or a predecessor; **OR**
- ☐ I (we) affirm that the applicant is an entity with the authority to condemn property and is acquiring the property to which the Groundwater registration proposed for modification is appurtenant by condemnation and have attached supporting documentation.

I understand that prior to Department approval of the groundwater registration modification, I may be required to submit payment to the Department for publication of a notice in a newspaper with general circulation in the area where the groundwater registration is located, once per week for two consecutive weeks. If more than one qualifying newspaper is available, I suggest publishing the notice in the following paper: _____.

I (we) affirm that the information contained in this application is true and accurate.



Alan Frost
Applicant Signature

Alan Frost Director
Print Name (and Title if applicable)

10/29/25
Date

Applicant Signature

Print Name (and Title if applicable)

Date

Is the applicant the sole owner of the land on which the Groundwater registration modification or portion thereof, is located? ☐ Yes ☐ No If NO, include signatures of all deeded landowners (and mailing and/or e-mail addresses if different than the applicant's) or attach affidavits of consent (and mailing and/or e-mail addresses) from all landowners or individuals/entities to which the Groundwater registration has been conveyed.


Check the appropriate box, if applicable:

- ☐ Check here if the Groundwater registration proposed for modification is or will be located within or served by an irrigation or other water district.

IRRIGATION DISTRICT NAME	ADDRESS	
CITY	STATE	ZIP

- ☐ Check here if water for the Groundwater registration is supplied under a water service agreement or other contract with a federal agency or other entity.

ENTITY NAME	ADDRESS	
CITY	STATE	ZIP



To meet State Land Use Consistency Requirements, you must list all local governments (each county, city, municipal corporation, or tribal government) within whose jurisdiction water will be diverted, conveyed or used.

ENTITY NAME Marion County	ADDRESS 555 Court Street	
CITY Salem	STATE OR	ZIP 97301

ENTITY NAME	ADDRESS	
CITY	STATE	ZIP

Received
NOV 21 2025
OWRD

INSTRUCTIONS for editing the Application Form

To add additional lines to tables within the forms or to copy and paste additional Part 4 pages, please **save the application form to your computer**. Unlock the document by using one of the following instructions for your Microsoft Word software version:

Microsoft Word 2003

Unlock the document by one of the following:

- Using the **Tools** menu => click **Unprotect Document**;
OR
- Using the **Forms** toolbar => click on the **Protect/Unprotect** icon.

To relock the document to enable the checkboxes to work, you will need to:

- Using the **Tools** menu => click **Protect Document**;
OR
- Using the **Forms** toolbar => click on the **Protect/Unprotect** icon.

Microsoft Word 2007

- Unlock the document by clicking the **Review** tab, then click **Protect Document**, then click **Stop Protect**
- To relock the document, click **Editing Restrictions**, then click **Allow Only This Type of Editing**, select **Filling In Forms** from the drop-down menu, then check **Yes, Start Enforcing Protection**.

Microsoft Word 2010

- Unlock the document by clicking the **Review** tab; toggle the **Restrict Editing** icon at the upper right, then click **Stop Protect** at the bottom right. Then uncheck the "**Allow only this type of editing** in the document: **Filling in forms**" in the "Editing restrictions" section on the right-hand list of options.
- To relock the document, check the **Editing Restrictions/Allow Only This Type of Editing/Filling In Forms** box from the drop-down menu, then check **Yes, Start Enforcing Protection**. You do not need to assign a password for the editing restrictions.

Other Alternatives:

- Photocopy pages or tables in Part 4, ~~mark through~~ any non-applicable information, insert/attach photocopied pages to document in the appropriate location, and manually amend page numbers as necessary (e.g. Page ~~5~~ 6 of ~~9~~ 10).
- You may refer to additional attachments that you may include, such as separately produced tables or spreadsheets to convey large numbers of rows of place of use listings, owner/property parcels, etc. You may contact the Department at 503-986-0900 and ask for Transfer Staff if you have questions.

Once the application has been unlocked, you may:

- add additional rows to tables using the Table tools, and
- select and copy the pages of Part 4 and paste as many additional sets of Part 4 pages as needed at the end of the application.

After editing, re-lock the document to enable checkboxes to work.

Received

NOV 21 2025

OWRD

Part 4 of 4 – Groundwater Registration Information

Please use a separate Part 4 for each registration being modified. See instructions on page 5, to copy and paste additional Part 4s, or to add additional rows to tables within the form.

Groundwater Registration # GR-323 (Certificate # GR-305)

Table 1. Location of Authorized and Proposed Point(s) of Appropriation (POA)

(Note: If the POA name is not specified in the registration, assign it a name or number here.)

POA Name or Number	Is this POA Authorized by the registration or is it Proposed?	OWRD Well Log ID# (or Well ID Tag # L-___)	Twp		Rng		Sec	¼ ¼		Tax Lot, DLC or Gov't Lot	Measured Distances (from a recognized survey corner)
Sublimity Well #1	<input checked="" type="checkbox"/> Authorized <input type="checkbox"/> Proposed		8	S	1	W	34	NW	SE		1,423' north and 1,445' west from the SE corner of Section 34.
Sublimity Well #5	<input type="checkbox"/> Authorized <input checked="" type="checkbox"/> Proposed	MARI 9170	8	S	1	W	35	NW	NW		850' south and 356' east from the NW corner of Section 35.
	<input type="checkbox"/> Authorized <input type="checkbox"/> Proposed										
	<input type="checkbox"/> Authorized <input type="checkbox"/> Proposed										

Check all type(s) of modifications(s) proposed below (modification "CODES" are provided in parentheses):

- ☐ Place of Use (POU)
☐ Character of Use (USE)

☐ Point of Appropriation (well) (POA)
☒ Additional Point of Appropriation (APOA)

Will all of the proposed changes affect the entire Groundwater registration?

- ☒ Yes
☐ No

Complete only the proposed ("to" lands) section of Table 2 on the next page. Use the "CODES" listed above to describe the proposed changes.

Complete all of Table 2 to describe the portion of the registration to be changed.

Received
NOV 21 2025
OWRD

Received
NOV 21 2025
OWRD

Please use and attach additional pages of Table 2 as needed.
See page 5 for instructions.

Do you have questions about how to fill-out the tables?
Contact the Department at 503-986-0900 and ask for Transfer Staff.

Table 2. Description of Modifications to Registration GR-323 (Certificate # GR-305)

List only the part of the registration that will be modified. For the acreage in each ¼ ¼, list the modification proposed. If more than one modification, specify the acreage associated with each modification. If more than one POA, specify the acreage associated with each POA.

AUTHORIZED (the "from" or "off" lands) The listing that appears in the registration BEFORE PROPOSED CHANGES List only that part or portion of the groundwater registration that will be changed.												Proposed Changes (see "CODES" from previous page)	PROPOSED (the "to" or "on" lands) The listing as it would appear AFTER PROPOSED CHANGES are made.															
Twp	Rng	Sec	¼ ¼	Tax Lot	Gvt Lot or DLC	Acres	Type of USE listed on Certificate	POA(s) (name or number from Table 1)	Priority Date	Twp	Rng		Sec	¼ ¼	Tax Lot	Gvt Lot or DLC	Acres	New Type of USE	POA(s) to be used (from Table 1)	Priority Date								
EXAMPLE																												
2	S	9	E	15	NE	NW	100		15.0	Irrigation	POD #1 POD #2	1901	POU/POD	2	S	9	E	1	NW	NW	500	1	10.0		POD #5	1901		
"	"	"	"	"	"	"	"	"	"	EXAMPLE	"	"	"	2	S	9	E	2	SW	NW	500		5.0		POD #6	1901		
													APOA	8	S	1	W	35	NW	NW				MUNI	Sublimity Well #5	1948		
TOTAL ACRES																							TOTAL ACRES					

Additional remarks: _____.

Groundwater Registration # GR-323 (Certificate # GR-305)

For a modification in place of use or character of use:

Are there other water right certificates, water use permits, or Groundwater registrations associated with the "from" or "to" lands? ☒ Yes ☐ No

If YES, list the other certificate, water use permit, or other Groundwater registration numbers:

CITY OF SUBLIMITY HAS OTHER PERMITS-SEE ATTACHED LEDGER



Pursuant to OAR 690-382-0200, any "layered" water use, such as an irrigation right that is supplemental to a primary irrigation right proposed for transfer, must be concurrently transferred with the registration or be cancelled. Any change to a water right must be filed separately in a transfer application. Any change to a water use permit must be filed separately with a permit amendment. Any modification to a Groundwater registration on the "to" lands must be filed separately with a Groundwater registration modification.

For modifications in point(s) of appropriation (well(s) or additional point(s) of appropriation:

- ☒ Well log(s) are attached for each well that are clearly labeled and associated with the corresponding well(s) in Table 1 above and on the accompanying application map. **Received**
(Tip: You may search for well logs on the Department's web page at:
http://apps.wrd.state.or.us/apps/gw/well_log/) **NOV 21 2025**

AND/OR

- ☒ Describe the construction of the authorized and proposed well(s) in Table 3 for any wells that do not have a well log. For *proposed wells not yet constructed or built*, provide "a best estimate" for each requested information element in the table. The Department recommends you consult a licensed well driller, geologist, or certified water right examiner to assist with assembling the information necessary to complete Table 3. **OWRD**

Table 3. Construction of Point(s) of Appropriation

Any well(s) in this listing must be clearly tied to corresponding well(s) described in Table 1 and shown on the accompanying application map. Failure to provide adequate information is likely to delay the processing of your modification application until it is received. The information is necessary for the department to assess whether the proposed well(s) will access the same source aquifer as the authorized point(s) of appropriation (POA). The Department is prohibited by law from approving POA changes that do not access the same source aquifer.

Proposed or Authorized POA Name or Number	Is well already built? (Yes or No)	If an existing well, OWRD Well ID Tag No. L- ____	Total well depth	Casing Diameter	Casing Intervals (feet)	Seal depth(s) (intervals)	Perforated or screened intervals (in feet)	Static water level of completed well (in feet)	Source aquifer (sand, gravel, basalt, etc.)	Well - specific rate (cfs or gpm). If less than full rate of water right
Well #1 (Auth POA)	Yes	MARI 9149	370'	8"	0'-210'	n/a	n/a	68'	Clay, Rock	90 gpm
Well #5 (APOA)	Yes	MARI 9170	470'	12"	0'-59'	0'-59'	none	119'	Basalt	450 gpm

Proposed or Authorized POA Name or Number	Is well already built? (Yes or No)	If an existing well, OWRD Well ID Tag No. L-____	Total well depth	Casing Diameter	Casing Intervals (feet)	Seal depth(s) (intervals)	Perforated or screened intervals (in feet)	Static water level of completed well (in feet)	Source aquifer (sand, gravel, basalt, etc.)	Well - specific rate (cfs or gpm). <u>If</u> less than full rate of water right

Received
NOV 21 2025
OWRD

Water Rights Inventory for (Name of Entity) City of Sublimity
(List of All Permits, Permit Amendments, Certificates, Transfers, New Applications)

Ground Water

Application No.	Permit No.	Priority Date	Certificate No.	P.A. ¹ or Transfer No.	Source of water identified in water right	Facility Name used by entity	Use	Rate identified in water right (cfs or AF)	Actual Diversion	Authorized Completion Date ²	Notes or Limitations to water use ³
									Maximum Instantaneous Rate Diverted to Date (cfs)		
GR-323	GR-305	3/31/1948	N/A	N/A	MARI 9149	Well #1	Muni	0.20 CFS	0.20 CFS	March 30, 1948	N/A
G-1944	G-1787	3/7/1961	33984	N/A	MARI 9142	Well #2	Muni	0.18 CFS	0.18 CFS	October 1, 1962	N/A
GR-269	GR-249	9/1/1943	N/A	T-12437	MARI 9142	Well #2	Muni	0.27 CFS	0.27 CFS	September 10, 1943	March 1-October 31
G-3085	G-2882	4/22/1965	84853	T-7064	MARI 9147 MARI 9172	Wells #3 and 4	Muni	1.43 CFS	1.43 CFS	October 1, 1966	N/A
G-4426	G-4170	6/3/1968	N/A	T-12720	MARI 9149 MARI 9142 MARI 9147 MARI 9172	Wells #1-4	Muni	0.93 CFS	0.93 CFS	Fall, 1972	March 1-October 31

¹ P.A. = Permit Amendment

² Date by which full application of water is to be made within the terms and conditions of the permit (date will be specified in the permit or on the last extension Final Order).

³ If a particular water right certificate, permit, or transfer is not being utilized to meet current demands, or its use is somehow limited due to quality, seasonal, etc. limitations, or if a the actual diversion rate is less than a certificated rate, please explain why.

Received
NOV 21 2025
OWRD

14769 -

Land Use Information Form



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem, Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Applicant(s): City of Sublimity

Mailing Address: PO Box 146

City: Sublimity

State: OR

Zip Code: 97385

Daytime Phone: 503-769-5475

A. Land and Location

Please include the following information for all tax lots where water will be diverted (taken from its source), conveyed (transported), and/or used or developed. Applicants for municipal use, or irrigation uses within irrigation districts may substitute existing and proposed service-area boundaries for the tax-lot information requested below.

Township	Range	Section	¼ ¼	Tax Lot #	Plan Designation (e.g., Rural Residential/RR-5)	Water to be:			Proposed Land Use:
<u>8S</u>	<u>1W</u>	<u>34</u>	<u>ALL</u>	<u>ALL</u>	_____	<input checked="" type="checkbox"/> Diverted	<input checked="" type="checkbox"/> Conveyed	<input checked="" type="checkbox"/> Used	_____
<u>9S</u>	<u>1W</u>	<u>3</u>	<u>NW 1/4</u>	<u>ALL</u>	_____	<input checked="" type="checkbox"/> Diverted	<input checked="" type="checkbox"/> Conveyed	<input checked="" type="checkbox"/> Used	_____
<u>8S</u>	<u>1W</u>	<u>35</u>	<u>NW/SW</u>	<u>ALL</u>	_____	<input checked="" type="checkbox"/> Diverted	<input checked="" type="checkbox"/> Conveyed	<input checked="" type="checkbox"/> Used	_____
<u>8S</u>	<u>1W</u>	<u>35</u>	<u>SW/SW</u>	<u>ALL</u>	_____	<input checked="" type="checkbox"/> Diverted	<input checked="" type="checkbox"/> Conveyed	<input checked="" type="checkbox"/> Used	_____

List all counties and cities where water is proposed to be diverted, conveyed, and/or used or developed:

Marion County, OR

B. Description of Proposed Use

Type of application to be filed with the Water Resources Department:

- ☐ Permit to Use or Store Water ☐ Water Right Transfer ☒ Permit Amendment or Ground Water Registration Modification
☐ Limited Water Use License ☐ Allocation of Conserved Water ☐ Exchange of Water

Source of water: ☐ Reservoir/Pond ☒ Ground Water ☐ Surface Water (name) _____

Estimated quantity of water needed: 90 ☐ cubic feet per second ☒ gallons per minute ☐ acre-feet

Intended use of water: ☐ Irrigation ☐ Commercial ☐ Industrial ☐ Domestic for _____ household(s)
☒ Municipal ☐ Quasi-Municipal ☐ Instream ☐ Other _____

Briefly describe:

Claim GR-323: The existing POA is within the city limits and UGB of the City of Sublimity.
The new POA (Well #5) was purchased by the City of Sublimity in 2017 and is inside of the Sublimity city limits and UGB.

Received

NOV 21 2025

OWRD

Note to applicant: If the Land Use Information Form cannot be completed while you wait, please have a local government representative sign the receipt at the bottom of the next page and include it with the application filed with the Water Resources Department.

See bottom of Page 3. →

For Local Government Use Only

The following section must be completed by a planning official from each county and city listed unless the project will be located entirely within the city limits. In that case, only the city planning agency must complete this form. This deals only with the local land-use plan. Do not include approval for activities such as building or grading permits.

Please check the appropriate box below and provide the requested information


- ☒ Land uses to be served by the proposed water uses (including proposed construction) are allowed outright or are not regulated by your comprehensive plan. Cite applicable ordinance section(s): MCC 16.13.010.H
- ☐ Land uses to be served by the proposed water uses (including proposed construction) involve discretionary land-use approvals as listed in the table below. (Please attach documentation of applicable land-use approvals which have already been obtained. Record of Action/land-use decision and accompanying findings are sufficient.) **If approvals have been obtained but all appeal periods have not ended, check "Being pursued."**

Type of Land-Use Approval Needed (e.g., plan amendments, rezones, conditional-use permits, etc.)	Cite Most Significant, Applicable Plan Policies & Ordinance Section References	Land-Use Approval:	
		<input type="checkbox"/> Obtained <input type="checkbox"/> Denied	<input type="checkbox"/> Being Pursued <input type="checkbox"/> Not Being Pursued
	Received	<input type="checkbox"/> Obtained <input type="checkbox"/> Denied	<input type="checkbox"/> Being Pursued <input type="checkbox"/> Not Being Pursued
	NOV 21 2025	<input type="checkbox"/> Obtained <input type="checkbox"/> Denied	<input type="checkbox"/> Being Pursued <input type="checkbox"/> Not Being Pursued
	OWRD	<input type="checkbox"/> Obtained <input type="checkbox"/> Denied	<input type="checkbox"/> Being Pursued <input type="checkbox"/> Not Being Pursued
		<input type="checkbox"/> Obtained <input type="checkbox"/> Denied	<input type="checkbox"/> Being Pursued <input type="checkbox"/> Not Being Pursued

Local governments are invited to express special land-use concerns or make recommendations to the Water Resources Department regarding this proposed use of water below, or on a separate sheet.

There is only one lot within the UGB of Sublimity that is under Marion County jurisdiction. A utility facility for urban uses is permitted within the bounds of this parcel. The location of the utility facility (pump/well) is only permitted within the UGB and if it is located outside would not be outright permitted.

Name: Alexander Seifer Title: Assistant Planner

Signature:  Phone: 503-588-5038 Date: 9/23/2025

Government Entity: Marion County

Note to local government representative: Please complete this form or sign the receipt below and return it to the applicant. If you sign the receipt, you will have 30 days from the Water Resources Department's notice date to return the completed Land Use Information Form or WRD may presume the land use associated with the proposed use of water is compatible with local comprehensive plans.

Receipt for Request for Land Use Information

Applicant name: _____

City or County: _____ Staff contact: _____

Signature: _____ Phone: _____ Date: _____

Contact Information (Click to Collapse...)

▼ Contact information

REGISTRANT:
▷ CITY OF SUBLIMITY
SUBLIMITY, OR 97385

Water Right Information (Click to Collapse...)

Status: Non-Cancelled
County: Marion
Basin: Willamette
File Folder Location: Salem
[Watermaster District:](#) 16

Scanned Documents (Click to Collapse...)

Records per page: 3

<u>Document Type</u>	<u>Document Title</u>	<u>Date</u>	<u>Remarks</u>
Claim	Claim GR323 Map Image		
Claim	Claim GR323 Image		
Order	Order Image - Volume: 62 Page: 268	12/1/2004	CITY OF SUBLIMITY WMCP

Point(s) of Diversion (Click to Collapse...)

▷ [POD 1 - A WELL > BEAVER CREEK](#) ([View Groundwater Site MARI0009149](#))

Place(s) of Use (Click to Collapse...)

[Add TRS grouping](#)

▷ **Use - MUNICIPAL USES**
(Primary); Priority Date: 3/31/1948

Water Right Genealogy (Click to Collapse...)

---No genealogy records available for this water right, try the family link below instead.

[View Water Rights in same Family](#) [Report Errors with Water Right Data](#)

Processing History (Click to Collapse...)

▼ Claim: GR 323 [document](#) , [paper map](#)

▷ Claim Date: n/a

▼ Order(s)

<u>Order Origin</u>	<u>Volume-Page</u>	<u>Signature</u>	<u>Description</u>
▷ Special	62-268	12/1/2004	CITY OF SUBLIMITY WMCP

▷ [View right with Web Mapping](#)

▷ [View Places of Use from Water Rights in the Same Area](#)


▷ [View Reported Water Use](#)

Received

NOV 21 2025

OWRD

14769 -

REGISTRATION NO. GR-323

Registration Statement

CERTIFICATE NO. GR-305

CLAIMANT OF RIGHT TO APPROPRIATE GROUND WATER

(Under Chapter 708, Oregon Laws 1955.)

TO THE STATE ENGINEER OF OREGON:

I, Town of Sublimity
of Marion County of _____

State of Oregon, do hereby make application for a certificate of registration as evidence of a right to appropriate ground water.

1. Source from which water is withdrawn is Pump well
(Flowing well, pump well, infiltration trench, or tunnel)

2. Location is: within City Limits
(Approximate distance and direction from nearest city or town)

and is more particularly described as follows:

21.45 chains north and 22.7 chains west from S.E. corner of section 34
(Give distance and bearing to corner of section or other legal subdivision)
being within NW 1/4 Sec 34 of Sec. 34, Twp. 8 S, Rge. 1 W
(Smallest legal subdivision) (N. or S.) (E. or W.)

or (b) within limits of recorded platted property, town or city: _____

in Lot _____, Block 21 of Main Town
(Name of plat or addition)
Sublimity County of Marion
(If within city or town, give name)

3. Construction Work was begun on Mar. 1948; was completed on Mar 30, 1948
(Date) (Date)

and the ground water claimed was first used for the purposes set out below on 1948
(Date)

since which time the water has been used continuously
(Continuously or intermittently)

from April, 1948 to Jan 1957
(Date) (Date)

4. Quantity of water claimed and used is 90 gallons per minute; 95 acre feet per year.

5. Purpose or Purposes for which water is used municipal
(Domestic, irrigation, municipal, manufacturing, industrial, etc.)

6. Description of Well: Depth 370 feet. Type drilled
(Dug or drilled)
diameter 12 inches. Elevation of ground at well site 550 feet, mean sea level.
(As near as known)
Depth to water table 68 feet.

7. Capacity of Well: 90 g.p.m. with 7 feet drawdown.
_____ g.p.m. with _____ feet drawdown.

Date of test engine test pump

If Flowing Well: Measured discharge _____ g.p.m. on _____
(Date)

Shut-in pressure at ground surface _____ lbs. per sq. in. on _____
(Date)

Water is controlled by _____
(Cap, valve, etc.)

Received

NOV 21 2025

14769 - OWRD

8. Casing: (Give diameter, commercial specifications and depth below ground surface of each casing size.)

8 inch diameter from 0 to 210 feet
 solid rock beyond inch diameter from 210 to 370 feet
 inch diameter from to feet
 inch diameter from to feet

Describe and show depth of shoe, plug, adapter, liner or other details:

9. Perforated Casings or Screens:

unknown from to
 (Number per foot and size of perforations; or describe screen)
 from to
 from to
 from to

10. Log of Well: (Describe each stratum or formation clearly, indicate if water bearing, and give thickness and depth as indicated.)

MATERIAL	Thickness (Feet)	Depth to Bottom (Feet)
attached		
soil, top and clay, red	21	21
clay, yellow	29	50
clay, blue	10	60
clay, yellow	30	90
clay, with scattered rock (basalt)	20	110
clay, yellow	8	118
clay, blue	7	125
clay, grey	15	140
clay, red - scattered gravel (contact)	18	158
clay, brown	12	170
conglomerate	18	198
rock, grey	14	212
rock, black	20	232
" " lava	32	264
rock, gray	6	270
clay, blue & brown	9	279
rock, black porous	15	294
rock, black	53	347
rock, black hard	9	356
rock, black	14	370

Received

NOV 21 2025

OWRD

GR-305 A

14769 -

11. Infiltration Trench: Covered or open _____
 Dimensions: Length _____ ft. Minimum depth _____ ft. Maximum depth _____ ft.
 Bottom width _____ ft. Discharge _____ g.p.m. Date of test _____

Dimensions: _____
(Length, course, and cross sectional size)

Position of water bearing stratum with reference to portal of tunnel _____

13. Pumping Equipment:

(a) Pump Fairbank Morris Turbine Capacity 90 g.p.m.
(Make, type and size)

(b) Motor 7 1/2 H.P. Fairbanks Morris
(Type and horsepower)

[illegible]

15. If the ground water supply is supplemental to an existing water supply, identification of any application for a permit, permit, certificate or adjudicated right to appropriate water made or held by the registrant.

14769 - GR-305B

34

Lot 8
Bentley St. Avenue
Bentley St. Avenue
on 22-7-88

35

Scale: 2" = 1 Mile

County of Marion SS.

L. R. Bradley Rec'd
(Signature of Registrant)

My commission expires 8/20/58 Robert H. Bass
(Notary Public)

Received

NOV 21 2025

OWRD

CERTIFICATE OF REGISTRATION

This is to certify that the foregoing Registration Statement was received in the office of the State Engineer on the 2nd day of January, 19 57, at 8 o'clock A. M. and has been duly recorded in said office in Book No. 2 of Registration Statements on page GR-305 C

Construction shall be completed by X-X-X-X-X-X-X-X-X-X, 19X-X, and the water company X-X-X-X-X-X-X-X-X-X by X-X-X-X-X-X-X-X-X-X, 19X-X.

Witness my hand this : 4th day of March 1957

1957
Lewis G. Stanley
(State Engineer)

By
(Deputy)

14769 - GR-305C

**BEFORE THE WATER RESOURCES DEPARTMENT
OF THE
STATE OF OREGON**

In the Matter of the Proposed Water)	FINAL ORDER APPROVING WATER
Management and Conservation Plan for)	MANAGEMENT AND
City of Sublimity, Marion County, Oregon)	CONSERVATION PLAN
)	

Authority

OAR Chapter 690, Division 086, establishes the process and criteria for approving water management and conservation plans required under the conditions of permits, permit extensions and other orders of the Department.

Findings of Fact

1. The City of Sublimity submitted a Water Management and Conservation Plan to the Department on September 27, 2002.
2. Public notice was published as required under OAR Chapter 690, Division 086. No comments were received.
3. The Department reviewed the draft plan. Based on the plan, the Department outlined a proposed work plan that, if completed, would allow the City of Sublimity to satisfy the requirements of OAR 690-086-0140. The Department notified the City of Sublimity of the areas needing additional work in the Department's letter of September 24, 2004.
4. The City of Sublimity agreed by letter dated October 21, 2004 to complete the activities described in the work plan by October 1, 2009. Pursuant to OAR 690-086-0100(3), the Department reviewed the revised plan for consistency with OAR Chapter 690, Division 086 as adopted by the Water Resources Commission in 1994.
5. The final plan is generally consistent with the relevant requirements and includes a work plan as described in the Department's letter of September 24, 2004 for completion of additional work necessary to satisfy the requirements within five years.

Conclusion of Law

The water management and conservation plan, with the inclusion of the work plan submitted by the City of Sublimity, is consistent with the criteria in OAR Chapter 690, Division 086 [1994].

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-080 and OAR 690-01-005 you may either petition for judicial review or petition the Director for reconsideration of this order.

Received


NOV 21 2025

OWRD

Now, therefore, it is ORDERED:

1. The City of Sublimity Water Management and Conservation Plan is approved and shall remain in effect until October 1, 2010, unless this approval is rescinded pursuant to OAR 690-086-0920.
2. The City of Sublimity shall submit an updated plan meeting the requirements of OAR Chapter 690, Division 86 (effective November 1, 2002) within five years and no later than October 1, 2009 that incorporates the results of the activities included in its work plan.

Dated at Salem, Oregon this 1st day of December, 2004.


Phillip C. Ward, Director

Received
NOV 21 2025
OWRD

Mailing date: DEC 02 2004

Site Identification (Click to Collapse...)

GW LogID: MARI 9149 [Well Log Database](#)
GW Well Tag Number:
Tag Verified on Well: No
Site Type: WELL
Primary Use: MUNICIPAL
Unused Status:
Site Source Organization:
Site Source OWRD:
Established By: KARL WOZNAK
Established Date: 10/13/2008
Bonded Company: TESTING
Stage: COMPLETE

Location (Click to Collapse...)

Latitude/Longitude
Latitude: 44.82816389 Horiz. Error: 24.00 ft
Longitude: -122.78970146 Datum: WGS1984
Lat/Long Source: WR APPL MAP

Location
TRSQQ: WM 8.00S1.00W34NWSE
Tax Map: 08S-01W-34DB
Taxlot: 6100
24 Quad: STAYTON
Basin: 2 - Willamette
County: Marion
WM District: 16
WM Region: NW
LSD Elev: 558.00 Accy: 5.00 Datum: NGVD1929
Elev Source: 7.5-MINUTE MAP
[Groundwater Mapping Tool](#)



Maxar | Oregon Wa

Water Rights (Click to Collapse...)

Water Right PODs

POD	WRIS Details	Application	Permit	Cert	Transfers	Claim	supplemental	priority_date	Season of Use	max_rate_cfs
POD 1 - A WELL > BEAVER CREEK	WRIS					GR 323		3/31/1948	1/1 ~ 12/31	0.201
POD 1 - A WELL > BEAVER CREEK	WRIS	G 4426	G 4170		T 12720			6/3/1968	3/1 ~ 10/31	0.860
POD 1 - A WELL > BEAVER CREEK	WRIS				T 12437	GR 269		9/1/1943	3/1 ~ 10/31	0.267

Well Construction History (Click to Collapse...)

Well Construction History

Well Log Id	Well Log	Work Type	Startcard	Well Tag	Owner Name	First Water	Max Case. Diam.	Max Case. Depth.	Max Seal Depth.	Max Dr
MARI 9149	Log	NEW			TOWN OF SUBLIMITY		8			

Well Log	Aquifer	Aq at Max Depth	System Aquifer	Regional USGS Aquifer
MARI 9149	Columbia River Basalt	Late Tertiary Basalt Aq	Late Tertiary Basalt Aquifers	

Well Test

Well Log	Test Type	Yield(gpm)	Drawdown	Duration (hr)	Calculated Specific Capacity (gpm/ft)
MARI 9149	Pump	90.0	7.0		12.86

Lithology (Click to Collapse...)


Lithology

Received
NOV 21 2025
OWRD

14769 -

Start Depth	End Depth	Prim. Lithology	Lithology Desc.	Water Bearing Zone	Water Bearing Zone WL
0.00	21.00	Soil	Red Soil & Red Clay		
21.00	50.00	Clay	Yellow Clay		
50.00	60.00	Clay	Blue Clay		
60.00	90.00	Clay	Yellow Clay		
90.00	110.00	Clay	Clay & Rock		
110.00	118.00	Clay	Yellow Clay		
118.00	125.00	Clay	Blue Clay		
125.00	140.00	Clay	Gray Clay		
140.00	158.00	Clay	Red Clay & Gravel		
158.00	170.00	Clay	Brown Clay		
170.00	198.00	Conglomerate	Conglomerate		
198.00	212.00	Basalt	Gray Basalt		
212.00	232.00	Basalt	Black Basalt		
232.00	264.00	Basalt	Black Basalt		
264.00	270.00	Basalt	Gray Basalt		
270.00	279.00	Clay	Blue & Brown Clay		
279.00	294.00	Basalt	Porous Black Basalt		
294.00	347.00	Basalt	Black Basalt		
347.00	356.00	Basalt	Hard Black Basalt		
356.00	370.00	Basalt	Black Basalt		

[Download Diagram](#)



Well Construction

(Click to Collapse...)

Construction

Feature Type	Start Depth	End Depth	Diameter	Material Type
Casing	0.00	210.00	8.000	STEEL
Open Interval	210.00	370.00	8.000	OPEN HOLE

Measured Water Level

(Click to Collapse...)

Records/Page: 20

Measured Water Level

Date	Time	Water Level (BLSD)	WL Elev. (ft AMSL)	Organization	OWRD	Method	Status	MP Height
11/6/2007		155.00	403.00	OWNER	WATER RIGHT	UNKNOWN	UNKNOWN	
9/4/2007		210.00	348.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	
7/2/2007		215.00	343.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	
5/4/2007		212.00	346.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	
4/16/2007		209.00	349.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	
2/21/2007		172.00	386.00	OWNER	WATER RIGHT	UNKNOWN	UNKNOWN	
1/8/2007		179.00	379.00	OWNER	WATER RIGHT	UNKNOWN	UNKNOWN	
12/28/2006		171.00	387.00	OWNER	WATER RIGHT	UNKNOWN	UNKNOWN	
11/1/2006		155.00	403.00	OWNER	WATER RIGHT	UNKNOWN	UNKNOWN	
8/21/2006		223.00	335.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	
7/13/2006	11:50:00	144.00	414.00	OWNER	WATER RIGHT	ETAPE	UNKNOWN	
7/13/2006	08:02:00	144.00	414.00	OWNER	WATER RIGHT	ETAPE	UNKNOWN	
7/11/2006	12:35:00	144.00	414.00	OWNER	WATER RIGHT	ETAPE	UNKNOWN	
7/11/2006	08:02:00	144.00	414.00	OWNER	WATER RIGHT	ETAPE	UNKNOWN	

7/10/2006	15:20:00	144.00	414.00	OWNER	WATER RIGHT	ETAPE	RISING	
7/10/2006	13:10:00	199.00	359.00	OWNER	WATER RIGHT	ETAPE	PUMPING	
7/10/2006	09:10:00	200.00	358.00	OWNER	WATER RIGHT	ETAPE	PUMPING	
7/10/2006	09:04:00	144.00	414.00	OWNER	WATER RIGHT	ETAPE	UNKNOWN	
6/7/2006		206.00	352.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	
5/10/2006		204.00	354.00	OWNER	WATER RIGHT	UNKNOWN	PUMPING	

1 2 3

Available Data

(Click to Collapse...)

Aquifer Test Completed:

Water Chemistry:

OWRD Recorder:

Geophysical Log Completed:

Flowing Well:

Other OWRD Recorder:

Saline:

Rock Geochemistry:

Other Documents/Images

(Click to Collapse...)

Image/Document Library

No data matches search criteria.

 - View Hydrograph

Received
NOV 21 2025
OWRD

14769 -


STATE ENGINEER
Salem, Oregon

9149
Well Record

STATE WELL NO. 8/1W-34K(1)
COUNTY Marion
APPLICATION NO. GR-323

OWNER: Town of Sublimity
MAILING ADDRESS: City Hall
CITY AND STATE: Sublimity, Oregon

LOCATION OF WELL: Owner's No. 1
NW 1/4 SE 1/4 Sec. 34 T. 8 S. R. 1 W., W.M.
Bearing and distance from section or subdivision
corner 21.45 chains North and 22.7 chains West
from the SE corner of Section 34, Lot 8, Block 2,
Sublimity, Oregon



Altitude at well 550 feet Interpolated

TYPE OF WELL: Drilled Date Constructed Mar. 1948

Depth drilled 370 Depth cased 210

Section 34

CASING RECORD:

8-inch casing set from 0 to 210 feet
rock wall - 210 to 370 feet

FINISH:

unknown

AQUIFERS:

basalt from 212 to 370 feet

WATER LEVEL:

68 feet below land surface

PUMPING EQUIPMENT: Type H.P.
Capacity G.P.M.

WELL TESTS:

Drawdown 7 ft. after hours pumping 90 G.P.M.
Drawdown ft. after hours G.P.M.

USE OF WATER Municipal 90 gpm Temp. °F. 19

SOURCE OF INFORMATION GR-305

DRILLER or DIGGER

ADDITIONAL DATA:

Log yes Water Level Measurements Chemical Analysis Aquifer Test

REMARKS:

Received
NOV 21 2025
OWRD

State Well No. 8/1W-34K(1)
County Marion
Application No. GR-323

Owner: Town of Sublimity Owner's No. #1
Driller: _____ Date Drilled March 1948

Received
NOV 21 2025
OWRD

14769 -

Site Identification

(Click to Collapse...)

GW LogID: MARI 9170 [Well Log Database](#)
GW Well Tag Number:
Tag Verified on Well: No
Site Type: WELL
Primary Use: UNUSED
Unused Status:
Site Source Organization:
Site Source OWRD:
Established By: KARL WOZNAK
Established Date: 11/21/2001
Bonded Company:
Stage: COMPLETE

Location

(Click to Collapse...)

Latitude/Longitude
Latitude: 44.83674400 **Horiz. Error:** 25.00
Longitude: -122.78335200 **Datum:** WGS1984
Lat/Long Source: SITE VISIT AND IMAGERY
Location
TRSQQ: WM 8.00S1.00W35NWNW
Tax Map: 081W35 00600
Taxlot: 600
24 Quad: STAYTON
Basin: 2 - Willamette
County: Marion
WM District: 16
WM Region: NW
LSD Elev: 550.00 **Accy:** 1.00 **Datum:** NAVD1988
Elev Source: LIDAR
[Groundwater Mapping Tool](#)



Maxar | Oregon Water Resources Department and Bureau of Land M... Pow

Water Rights

(Click to Collapse...)

Water Right PODs

POD	WRIS Details	Application	Permit	Cert	Transfers	Claim	supplemental	priority_date	Season of Use	max_rate_cfs	rate_cfs	rate_cfs_est	TRSQQ
POD 1 - A WELL > BEAVER CREEK	WRIS	G 2419	G 2219		T 7285, T 8179			8/15/1962	3/1 ~ 10/31	0.110	0.110		WM8.00S1.00W35NWNW
POD 1 - A WELL > BEAVER CREEK	WRIS	G 4426	G 4170	94088	T 12720		•	6/3/1968	1/1 ~ 12/31	0.070	0.070		WM8.00S1.00W35NWNW

Well Construction History

(Click to Collapse...)

Well Construction History

Well Log Id	Well Log	Work Type	Startcard	Well Tag	Owner Name	First Water	Max Case Diam.	Max Case Depth	Max Seal Depth	Max Depth	Completed Depth	Complete Date
MARI 9170	LOG	NEW			ROBERT J SCHUMACHER		12			470.00	300.00	12/1/1967
MARI 9160	LOG	DEEPENING			ROB SCHUMACHER		12			470.00	470.00	11/12/1986

Well Log	Aquifer	Aq at Max Depth	System Aquifer	Regional USGS Aquifer	Local USGS Aquifer
MARI 9170	Columbia River Basalt	Late Tertiary Basalt Aq	Late Tertiary Basalt Aquifers		Columbia River Basalt Group
MARI 9160	Columbia River Basalt	Late Tertiary Basalt Aq	Late Tertiary Basalt Aquifers		Columbia River Basalt Group

Well Test

Well Log	Test Type	Yield(gpm)	Drawdown	Duration (hr)	Calculated Specific Capacity (gpm/ft)
MARI 9170	Pump	800.0	107.0	1.0	7.48

Lithology

(Click to Collapse...)


Lithology

Received
 NOV 21 2025
 OWRD

14769 -

Start Depth	End Depth	Prim. Lithology	Lithology Desc.	Water Bearing Zone	Water Bearing Zone WL
0.00	5.00	Clay	Red Clay		
5.00	10.00	Clay	Yellow Clay		
10.00	20.00	Clay	White Clay		
20.00	26.00	Clay	Yellow Clay		
26.00	56.00	Tuff	Welded Gray Tuff		
56.00	110.00	Basalt	Hard Basalt		
110.00	117.00	Basalt	Vesicular Basalt		
117.00	140.00	Basalt	Hard Basalt		
140.00	185.00	Basalt	Vesicular Basalt		
185.00	235.00	Basalt	Very Hard Basalt		
235.00	260.00	Basalt	Vesicular Basalt		
260.00	274.00	Basalt	Very Hard Basalt		
274.00	300.00	Basalt	Vesicular Basalt		
300.00	340.00	Basalt	Hard Basalt		
340.00	344.00	Basalt	Fractured, Vesicular, Gray & Green Basalt		
344.00	364.00	Basalt	Hard Gray Basalt	Yes	
364.00	367.00	Basalt	Fractured Vesicular Gray Basalt		
367.00	379.00	Basalt	Hard Basalt		
379.00	380.00	Basalt	Vesicular Black & Gray Basalt	Yes	
380.00	454.00	Basalt	Hard Gray Basalt		
454.00	455.50	Basalt	Fractured Basalt	Yes	
455.50	463.00	Basalt	Hard Black & Gray Basalt		
463.00	468.00	Basalt	Fractured Black Basalt		
468.00	470.00	Basalt	Hard Black Basalt		

[Download Diagram](#)



Well Construction

(Click to Collapse...)

Construction				
Feature Type	Start Depth	End Depth	Diameter	Material Type
Seal	0.00	59.00	16.000	CEMENT GROUT
Casing	0.00	59.50	12.750	STEEL
Open interval	59.50	470.00	12.000	OPEN HOLE

Measured Water Level

(Click to Collapse...)

Records/Page: 20

[Find](#)

Measured Water Level

Received
NOV 21 2025
OWRD

14769 -

Date	Time	Water Level (BLSD)	Wt. Elev (ft AMSL)	Organization	OWRD	Method	Status	MP Height
7/17/2025	10:36:00	152.49	397.51	OWRD	GWATER	ETAPE	STATIC	0.89
4/15/2025	11:16:00	141.58	408.42	OWRD	GWATER	ETAPE	STATIC	0.89
1/16/2025	13:35:00	144.82	405.18	OWRD	GWATER	ETAPE	STATIC	0.89
10/18/2024	11:03:00	150.89	399.11	OWRD	GWATER	ETAPE	STATIC	0.89
7/12/2024	13:41:00	148.28	401.72	OWRD	GWATER	ETAPE	STATIC	0.89
4/19/2024	09:59:00	140.97	409.03	OWRD	GWATER	ETAPE	STATIC	0.89
1/30/2024	14:11:00	143.08	406.92	OWRD	GWATER	ETAPE	STATIC	0.89
10/25/2023	13:30:00	148.52	401.48	OWRD	GWATER	ETAPE	STATIC	0.89
7/20/2023	11:33:00	150.18	399.82	OWRD	GWATER	ETAPE	STATIC	0.89
4/25/2023	12:46:00	139.55	410.45	OWRD	GWATER	ETAPE	STATIC	0.89
1/25/2023	13:00:00	142.69	407.31	OWRD	GWATER	ETAPE	STATIC	0.89
10/7/2022		149.26	400.74	OWRD	GWATER	ETAPE	STATIC	0.89
7/19/2022	12:23:00	143.90	406.10	OWRD	GWATER	ETAPE	STATIC	0.89
4/22/2022	12:02:00	141.01	408.99	OWRD	GWATER	ETAPE	STATIC	0.89
1/28/2022	12:30:00	143.51	406.49	OWRD	GWATER	ETAPE	STATIC	0.89
10/25/2021	10:57:00	148.06	401.94	OWRD	GWATER	ETAPE	STATIC	0.89
7/21/2021	15:22:00	149.53	400.47	OWRD	GWATER	ETAPE	STATIC	0.89
4/21/2021	13:44:00	140.41	409.59	OWRD	GWATER	ETAPE	STATIC	0.89
1/27/2021	13:23:00	141.91	408.09	OWRD	GWATER	ETAPE	STATIC	0.89
10/16/2020	14:24:00	148.09	401.91	OWRD	GWATER	ETAPE	STATIC	0.89

Flow Meter/Power Meter

(Click to Collapse...)

Records/Page: 20

Find

Flow Meter/Power Meter

Organization	OWRD	Date	Water Use Year	Final Use (af)	FM Reading Last Year	FM Reading	FM Multiplier	FM Units	FM Rollover Nbr	FM Rollover Value	Final Use Source	Final Use Determin
OWRD	GROUNDWATER SECTION	7/17/2025							0	0		
OWRD	GROUNDWATER SECTION	4/15/2025							0	0		
OWRD	GROUNDWATER SECTION	1/16/2025							0	0		
OWRD	GROUNDWATER SECTION	10/18/2024							0	0		
OWRD	GROUNDWATER SECTION	7/12/2024							0	0		
OWRD	GROUNDWATER SECTION	4/19/2024							1	0		
OWRD	GROUNDWATER SECTION	1/30/2024							1	0		
OWRD	GROUNDWATER SECTION	10/25/2023							1	0		
OWRD	GROUNDWATER SECTION	7/20/2023							1	0		
OWRD	GROUNDWATER SECTION	4/25/2023							1	0		
OWRD	GROUNDWATER SECTION	1/25/2023							1	0		
OWRD	GROUNDWATER SECTION	10/7/2022							1	0		
OWRD	GROUNDWATER SECTION	7/19/2022							1	0		
OWRD	GROUNDWATER SECTION	4/22/2022							1	0		
OWRD	GROUNDWATER SECTION	1/28/2022							1	0		
OWRD	GROUNDWATER SECTION	10/25/2021							1	0		

Received
NOV 21 2025

OWRD

14769 -

OWRD	GROUNDWATER SECTION	1/27/2021							1	0		
OWRD	GROUNDWATER SECTION	10/16/2020							1	0		
OWRD	GROUNDWATER SECTION	7/16/2020							1	0		
OWRD	GROUNDWATER SECTION	4/23/2020							1	0		

1 2

Available Data

(Click to Collapse...)

Aquifer Test Completed:
Geophysical Log Completed:

Water Chemistry:
Flowing Well:
Saline:
Rock Geochemistry:

OWRD Recorder:
Other OWRD Recorder:

Other Documents/Images

(Click to Collapse...)

Image/Document Library

No data matches search criteria.

Other Identifiers

(Click to Collapse...)

Other Identifiers

Identity Name	Identity	Is Duplicate	Description	Link
USGS SITE ID	445013122465601		U.S. Geological Survey Siteid	Report

[View Hydrograph](#)

Received
NOV 21 2025
OWRD

14769 -

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

RECEIVED

DEC 5 1967

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

SALEM OREGON

State Well No.

8/1W-35D

State Permit No.

G-4426

(1) OWNER:

Name Robert J. Schumacher

Address Rt. 1 Box 34

Sublimity, Ore.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐Cable ☒ Jetted ☐☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

123/4 Diam. from 1/2+0 ft. to 59 1/2 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

c level 93 ft. below land surface Date 9/1/67

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static levelWas a pump test made? ☒ Yes ☐ No If yes, by whom? Stettler

d: 800 gal./min. with 107 ft. drawdown after 1 1/2 hrs.

" 710 " 89 " 1 1/2 "

" 600 " 82 " 1 1/2 "

Bailer test 500 gal./min. with 60 ft. drawdown after 1 1/2 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used Cement Grout

Depth of seal 59 ft.

Diameter of well bore to bottom of seal 16 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoDid any strata contain unusable water? ☐ Yes ☐ No

Type of water depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☐ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 8/1W-35D

1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 113/4

Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Red clay	0	5	
Yellow clay	5	10	
White clay	10	20	
Yellow clay	20 26	26	11ft
Grey welded tuffs	26	56	
Basalt -hard	56	110	
Basalt-vesicular	110	117	93ft
Basalt very hard	117	140	
Basalt vesicular	140	185	
Basalt very hard	185	235	
Basalt vesicular	235	260	
Basalt very hard	260	274	
Basalt very hard	274	300	

Received

NOV 21 2025

OWRD

Work started 10/16/67 19 Completed 12/1/67 19

Date well drilling machine moved off of well 12/1/67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harry A. Robinson Date 12-5-67
(Drilling Machine Operator)

Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson
(Person, firm or corporation) (Type or print)

Address 2214 Front St. NE Salem, Ore.

[Signed] Harry A. Robinson
(Water Well Contractor)

Contractor's License No. 22 Date 12/5/67 19

RECEIVED

MIRI 9160 84/W-3566
Rep.

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

NOV 21 1986

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Bob Schumacher
Address 8144 135th Ave. SE
City Sublimity State OR Zip 97385

(2) TYPE OF WORK:

☐ New Well ☒ Deepen ☐ Recondition ☐ Abandon

(3) DRILL METHOD:

☒ Rotary Air ☐ Rotary Mud ☐ Cable ☐ Other

(4) PROPOSED USE:

☐ Domestic ☐ Community ☐ Industrial ☒ Irrigation
☐ Thermal ☐ Injection ☐ Other

(5) BORE HOLE CONSTRUCTION:

Original Depth of Completed Well 470 ft.
Special Standards date of approval NA

HOLE	From	To	Material	From	To	Amount
meter						sacks or pounds
orig						

How was seal placed? Method ☐ A ☐ B ☐ C ☐ D ☐ E
☐ Other orig

Backfill placed from ft. to ft. Material NA

Gravel placed from ft. to ft. Size of gravel NA

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<u>NA</u>			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner:	<u>NA</u>			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Location of shoe(s) orig

(7) PERFORATIONS/SCREENS:

☐ Perforations Method NA
☐ Screens Type Material NA

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
NA						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

☐ Pump ☐ Bailer ☒ Air ☐ Artesian

Yield gal/min	Pumping level	Drill stem at	Time 1/2 hr
1200		470	2

Temperature of water NA Depth Artesian Flow Found NA

Was a water analysis done? ☐ Yes By whom NA

Did any strata contain water not suitable for intended use? ☐ Too little

☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other NA

Depth of strata:

LOCATION OF WELL by legal description:

County Marion Latitude " Longitude "
Township 8S N or S, Range 1W E or W, WM.
Section 35 NW 1/4 NW 1/4
Tax Lot Lot Block Subdivision
Street Address of Well (or nearest address) SAME AS OWNER

(10) STATIC WATER LEVEL:

119 ft. below land surface. Date 11-12-86
Artesian pressure NA lb. per square inch. Date NA

(11) WELL LOG:

Ground elevation NA

Material	From	To	WB?	SWL
Basalt Grey Hard	302	340		
Basalt Grey Some green				
semi-fract &				
vesicular	340	344		
Basalt Grey Hard	344	364	H2O	
Basalt Grey Fract. &				
Vesicular	364	367		
Basalt Grey Hard	367	379		
Basalt Visic Blk-Gry	379	380	H2O	
Basalt Hard Grey	380	454		
Basalt Fract. Semi	454	455.5	H2O	
Basalt Blk-Gry Hard	455.5	463		
Basalt Semi Fract Blk	463	468		
Basalt Blk Hard	468	470		

Received

NOV 21 2025

OWRD

Date started 11-10-86 Completed 11-12-86

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Chad Star Date 11-19-86

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Chad Star Date 11-19-86

Company Staco Well Services Co. Job No. 14769