NOTICE TO WATER WELL CONTRACTOR		*	
	LL REPORT A	,	
of this report are to be flied with the	OREGON Detate Well No.	8/1-3/	4 🔾
STATE ENGINEER, SALEM, OREGON 07510 (10 7 7) 196 APlease tyl within 30 days from the date 12 (10 7 7) 10 not write:			Щ.
	State Permit N	0	
of well completion.			<u> </u>
(1) OWNER:	(11) LOCATION OF WELL:		
Name Ralph A Jack	County Marion Driller's well number		
Address Star Route, Silverton, Ore	1/4 1/4 Section T. R.		
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner		
New Well M Deepening Reconditioning Abandon	300 W, 300 S, of N.E, cor		
If abandonment, describe material and procedure in Item 12.	of sec 3. R.IE, T.8S.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):			24
Rotary E Driven [] Demostic Windows []	(12) WELL LOG: Diameter of well !	elow casing	8
Cable	Depth drilled 300 ft. Depth of compl	eted well 300)ft.
ACARTYC TYCMATY TO	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,		
CASING INSTALLED: Threaded Welded M. 8. "Diam. from Q ft. to 19. ft. Gage . 250.	with at least one entry for each change of formation. Report each change		
" Diam. fromft. toft. Gage 1.5.2	in position of Static Water Level as drilling pro		
" Diam. from	MATERIAL	From To	SWL
	Top soil red	$\frac{Q}{Z}$	
PERFORATIONS: Perforated? Yes No.	Basalt blk. kxxkr m.	7 7	
Type of perforator used	Basalt blk. h.	17 3/	
Size of perforations in. by in.	Basalt grey, h.	34 5	
perforations from	Basalt grey, with brn		
perforations from	seams. m.	%I 58	
perforations from tt. to tt.	Rock brn, s.	58 63	
perforations fromft, toft,	Basalt grey, x.h. Clatstone 1t brn.m.	63 8I 8I 86	
(A) CODETING.	Basit d.grev. h .	86 128	
(7) SCREENS: Well screen installed? Yes Y No	Basalt weathered, brn.m	I28 I/.5	
Manufacturer's Name Model No.	Basalt grey, brn seams, h	I45 I55	
Diam Slot size Set from ft. to ft.	Basalt weathered brn m.	I55 I7I	-
Diam. Slot site Set from ft. to ft.	Basalt grey, h.	17T 180	
(8) WATER LEVEL: Completed well. 30	Basalt potra6+, m,	T80 T95	
	Basalt gray, x,h. Basalt weathered, porage	T95 288	
	brn, s, w.b.	288 300	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? Tyes to No It yes, by whom?	0.00		
Yield: gal./min. with ft. drawdown after hrs.	Work started 8-28-67 19 Complet		
r 300. I3I " I "	Date well drilling machine moved off of well	8-30-67	19
n n n	Drilling Machine Operator's Certification:		
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best		
Artesian flow g.p.m. Date	knowledge and belief.		
Temperature of water ♀ ♂ Was a chemical analysis made? ☐ Yes 🙀 No	[Signed Orilling Manine Operator)	Date 9-30	., 19.6
(10) CONSTRUCTION:	1 0	300	
Well seal-Material used Bentonite & cuttings	Drilling Machine Operator's License No. 322		
Depth of sealft.	Water Well Contractor's Certification:		
Diameter of well bore to bottom of sealin,	This well was drilled under my jurisdiction and this report is		
Were any loose strata cemented off? [] Yes XNo Depth	true to the best of my knowledge and belief. NAME R. Stadeli & Sons		
Was a drive shoe used? □ Yes ☆ No	NAME R. DURGELL & DONS (Person, firm or corporation) (Type or print)		
Did any strata contain unusable water? Yes No	Address Route 3, Box 16 9, Silverton, Ore		
Type of water? depth of strata	01001.1		
Method of sealing strata off	[Signed] Taul K. Stadelii		
Was well gravel packed? ☐ Yes K No Size of gravel:	(Water Well Contractor)		
Gravel placed from ft. to ft.	Contractor's License No2.9.6 Date	0-3	196.7
(USE ADDITIONAL SHEETS IF NECESSARY)			