

CLAG

WELL B

015157

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED

OCT 10 WATER WELL REPORT

STATE OF OREGON G-4270 G-3608 (Please type or print)

State Well No. 6/1-5 J G-9820 State Permit No. G-3374

(1) OWNER:

Name Mr. Victor Schneider
Address Rte. 1, Box 53 Mt. Angel, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number 2
Bearing and distance from section or subdivision corner 2250 ft. north & 1200 ft. west of S.E. corner of section 5, T6 S., R.1 E.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 1' above to 119 ft. Gage .250

(7) PERFORATIONS:

Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Bentonite & puddled clay
Depth of seal 18 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [X] No
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? XX depth of strata XX
Method of sealing strata off XX

(10) WATER LEVELS:

Static level 74 ft. below land surface Date 7/25/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? Drillers
Yield: 400 gal./min. with 32 ft. drawdown after 3 hrs.
Bailer test XX gal./min. with XX ft. drawdown after XX hrs.
Artesian flow XX g.p.m. Date XX
Temperature of water XX Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 198 ft. Depth of completed well 198 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil-brown, Clay-brown, Rock-grey & brown, etc.

Water is coming in the last 40 ft.

RECEIVED

AUG 27 2008

WATER RESOURCES DEPT SALEM, OREGON

Work started July 18, 1966 Completed July 23, 1966
Date well drilling machine moved off of well Aug. 1, 66 19

(13) PUMP:

Manufacturer's Name Jacuzzi
Type: Turbine H.P. 25

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons
Address Rte. 3, Box 169, Silverton, Oregon

Drilling Machine Operator's License No. 322 & 84

[Signed] Paul R. Stadel (Water Well Contractor)

Contractor's License No. 296 Date 10/7/66, 19

CLAC 57334
C19C
57334

STATE OF OREGON
WATER SUPPLY WELL REPORT
(as required by ORS 537.765)

WELL I.D. # L 50528
START CARD # 142646

Instructions for completing this report are on the last page of this form.

(1) LAND OWNER Well Number _____
Name PHYLLIS SCHNEIDER
Address 36612 S. FARM RD.
City MT. ANGEL State OR Zip 97362

(2) TYPE OF WORK
 New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other _____

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well 271 ft.
Explosives used Yes No Type _____ Amount _____

HOLE			SEAL			
Diameter	From	To	Material	From	To	Sacks or pounds
8"	198	271				

How was seal placed: Method A B C D E
 Other ORIGINAL

Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: <u>ORIGINAL</u>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner: <u>NONE</u>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Drive Shoe used Inside Outside None
Final location of shoe(s) _____

(7) PERFORATIONS/SCREENS:
 Perforations Method NONE
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailer Air Flowing Artesian
Yield gal/min 150 Drawdown N/A Drill stem at _____ Time 1 hr.

Temperature of water 56° Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for _____ little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

(9) LOCATION OF WELL by legal description:
County CLACKAMAS Latitude _____ Longitude _____
Township 6S N or S Range 1E E or W. WM.
Section 5 NE 1/4 SE 1/4
Tax Lot 1900 Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) 36612 S. FARM RD. MT. ANGEL, OR 97362

(10) STATIC WATER LEVEL:
151 ft. below land surface. Date 9-13-01
Artesian pressure _____ lb. per square inch Date _____

(11) WATER BEARING ZONES:
Depth at which water was first found 233'

From	To	Estimated Flow Rate	SWL
233'	271'	150 GPM	151'

(12) WELL LOG:
Ground Elevation _____

Material	From	To	SWL
CLAYSTONE GREY HARD	198	224	
SILTSTONE BLUE	224	228	
SILTSTONE DARK GREY	228	233	
SANDSTONE GREY/GRN	233	271	151'

FOR ORIGINAL WELL LOG INFORMATION
SEE: CLACK 015156/7

Westerberg Drilling, Inc.
36728 S. Kropf Rd.
Molalla, OR 97038
RECEIVED
OCT 11 2001
WATER RESOURCES DEPT.
SALEM, OREGON

Date started 9-13-01 Completed 9-13-01

(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.
Signed Byron B. Stadel WWC Number 1358 Date 9-24-01

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.
Signed Stu N. Stadel WWC Number 688 Date 9-24-01

RECEIVED
AUG 27 2008
WATER RESOURCES DEPT.
SALEM, OREGON