

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

160 Additional
MARI
19643
POA

ED
7s/2w/16ba
(START CARD) # 65312
195

(1) OWNER: Well No _____
Name Clarence Simmons Farms
Address 4998 Blue Grass Lane NE
City Silverton State OR Zip 97381

(2) TYPE OF WORK
 New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other _____

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well 156 ft.
Explosives used Yes No Type _____ Amount _____

HOLE			SEAL			Sacks or pounds
Diameter	From	To	Material	From	To	
12	0	22	cement	0	22	33
8	22	156	-	-	-	

How was seal placed: Method A B C D E
 Other _____

Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 8"	+1	156	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 156

(7) PERFORATIONS/SCREENS:

Perforations Method Air
 Screens Type Holte Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
118	139		1000	1/4 x 1		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailer Air Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
450	10" NA	141	1 hr.

Temperature of water 56 Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

LOCATION of WELL by legal description:
Latitude _____ Longitude _____
7 S N or S Range 2W E or W. WM.
Section 16 NE 1/4 NW 1/4
Tax Lot _____ Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) Lardon Rd.

(10) STATIC WATER LEVEL:
12.5 ft. below land surface. Date 4-10-95
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
Depth at which water was first found 30 ft.

From	To	Estimated Flow Rate	SWL
30	48	5	
46	108	50	
108	156	200	12 1/2 ft

(12) WELL LOG:
Ground Elevation _____

Material	From	To	SWL
Top soil - brown	0	5	
Clay, silty, brown	5	30	
Clay, gray silty water	30	48	
Gravel, coarse w/silty sand black	48	55	
Gravel, coarse, sandy black	55	67	
sandy, light gravel lots of water	67	87	
Gravel, heavy sand, water	87	92	
Gravel heavy, lots of water	92	108	
Gravel, clean, heavy, lots lots of water	108	-	
Medium Gravel, some Fine heavy sand	140	-	
	-	156	

Date started 4/5/95 Completed 4/11/95

(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

WWC Number _____
Signed Steve Zimmerman Date 4/13/95

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

WWC Number 1358
Signed Debra B. Stude Date 4-13-95

RECEIVED ORIGINAL & FIRST COPY-WATER RESOURCES DEPARTMENT SECOND COPY-CONSTRUCTOR THIRD COPY-CUSTOMER

00728
NOV 24 2008
WATER RESOURCES DEPT
SALEM, OREGON

RECEIVED RECEIVED

MAX. 6917

File Original JUN 1 1959

JUN 1 1959 WATER WELL REPORT

G-3520

State Well No. 7/24-9

STATE ENGINEER STATE ENGINEER STATE OF OREGON

State Permit No.

(1) SALEM, OREGON SALEM, OREGON

Name H.C. TOELLE
Address 5603 LARDON ROAD SALEM ORE.

(2) LOCATION OF WELL:

County Marion Owner's number, if any-
S.W. 1/4 S.W. 1/4 Section 9 T. 7 S.R. 2W. W.M.
Bearing and distance from section or subdivision corner
975.00' N 26°30' E and 242.00' S 89°30' E
From the most westerly south east corner of John Gilmore Div. C. Section 9, T. 7 S.R. 2W. W.M. Marion County Oregon

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic X Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

8" Diam. from 1 ft. to 137' ft. Gage 1"
" Diam. from ft. to ft. Gage 4"
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? No
Type of perforator used MILLS TYPE
SIZE of perforations 5/16 in. by 2" in.
530 perforations from 1 ft. to 135' ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed No
Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes To what depth? 8" ft.
Material used in seal- PUMP COVERED
Did any strata contain unusable water? Yes No
Type of water? SANDY Depth of strata 69' to 69 1/2'
Method of sealing strata off CASER + BACKFILL

(10) WATER LEVELS:

Static level 10 ft. below land surface Date 5-4-59
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] H.C. Toelle Date 5-4-59 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? STEETLER SUPPLY
Yield: 600 gal./min. with 84 ft. drawdown after 1 hrs.
" 450 " 61 " 1 "
" 200 " 21 " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysis made? No

(12) WELL LOG:

Diameter of well 8" 1-D inches.
Depth drilled 137' ft. Depth of completed well 137' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include TOPSOIL, CLAY YELLOW COLOR, CLAY BLUE COLOR, CLAY YELLOW-STICKY, CLAY-YELLOW-SAND, WATER SAND-FINE, CEMENTED GRAVEL, WATER SAND + GRAVEL 3", CEMENTED GRAVEL W/B, WATER SAND + GRAVEL 1", CEMENTED GRAVEL, WATER GRAVEL 3", CEMENTED GRAVEL.

Existing POA

Work started 4-28 1959 Completed 5-4-1959

(13) PUMP:

Manufacturer's Name BERKLEY
Type: TURBINE H.P. 2

Well Driller's Statement:

"This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. Sneed + SONS (Person, firm, or corporation) (Type or print)
Address 2505 BROOKS ST SALEM, O.

Driller's well number

[Signed] J.A. Sneed (Well Driller)

License No. 6 Date 5-4-1959

RECEIVED

(SEE ADDITIONAL SHEETS IF NECESSARY)

NOV 24 2008

WATER RESOURCES DEPT SALEM, OREGON

T 10728