

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

OCT 24 1994

PLEASE TYPE OR PRINT IN INK

SALEM, OREGON

Start Card 63012

**(1) OWNER:**

Name Jim Waliser  
 Address RT 2 Box 357-B  
 City Milton Freewater State Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven   
 Rotary Mud  Dug   
 Cable  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Thermal:  Withdrawal  ReInjection   
 Other: Piezometric  Grounding  Test

**(5) CASING INSTALLED:**

Steel  Plastic   
 Threaded  Welded   
 10" Diam. from 1 ft. to 30 ft. Gauge 0250

**LINER INSTALLED:**

Steel  Plastic   
 Threaded  Welded   
 8" Diam. from 22 ft. to 180 ft. Gauge S410

**(6) PERFORATIONS:**

Perforated?  Yes  No Liner  
 Size of perforations in. by in.  
 672 perforations from 120 ft. to 182 ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 Air test 300 gal./min. with drill stem at 180 ft. 2 hrs.  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m.  
 Temperature of water 54 Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Special standards: Yes  No   
 Well seal—Material used BentONite  
 Well sealed from land surface to 29 ft.  
 Diameter of well bore to bottom of seal 15 1/4 in.  
 Diameter of well bore below seal 10 in.  
 Amount of sealing material 32 sacks  pounds   
 How was cement grout placed? \_\_\_\_\_

Was pump installed? NO Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
 Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL by legal description:**

County Umatilla SW 1/4 NW of Section 33  
 Township 6 North, Range 35 East, WM.  
 (Township is North or South) (Range is East or West)  
 Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 MAILING ADDRESS OF WELL (or nearest address) County Road

**(11) WATER LEVEL of COMPLETED WELL:**

Depth at which water was first found 68 ft.  
 Static level 50 ft. below land surface. Date 9-7-94  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 10"  
 Depth drilled 192 ft. Depth of completed well 182 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL                   | From | To  | SWL |
|----------------------------|------|-----|-----|
| Brn Soil + Gravel          | 0    | 2   |     |
| Tan Silt + Builders        | 2    | 12  |     |
| Loose Gravel Brn Silt      | 12   | 16  |     |
| Brn Silt Cemented Gravel   | 16   | 22  |     |
| Tan Silt Cemented Gravel   | 22   | 68  |     |
| Brown Silt Cemented Gravel | 68   | 128 | 50  |
| Grey cemented Gravel       |      |     |     |
| Clean water Bearing        | 128  | 180 | 50  |
| Brown Silt loose Gravel    | 180  | 192 | 50  |

**RECEIVED**

FEB 12 2009

WATER RESOURCES DEPT  
 SALEM, OREGON

Date work started 8-30-94 /completed 9-7-94  
 Date well drilling machine moved off of well 9-7 1994

**(unbonded) Water Well Constructor Certification (if applicable):**  
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] \_\_\_\_\_ Date \_\_\_\_\_, 19 \_\_\_\_\_

**(bonded) Water Well Constructor Certification:**  
 Bond \_\_\_\_\_ Issued by: AcetNA  
 (number) (Surety Company Name)  
 On behalf of Pro-Drill Inc  
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) [Signature]  
 (Water Well Constructor)

(Dated) 9-7-94

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion.

SP-46866-090