

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMAT WATER WELL REPORT
2937

RECEIVED

STATE OF OREGON APR 18 1975 State Well No. 4W/29E-29 6d
(Please type or print) STATE ENGINEER State Permit No.
SALEM, OREGON Gossler #4

(1) OWNER:

Name LOY GOSSLER
Address Route #3 Box 323A
Hermiston, Oregon 97838

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
Diam. from 18 ft. to 0 ft. Gage 221 ft. Gage .375
" Diam. from 0 ft. to 221 ft. Gage .375
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Farmore Pendleton
Was a pump test made? Yes No If yes, by whom?
Yield: 1557 gal./min. with 103 ft. drawdown after 4 hrs.
1921 138 5
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow none g.p.m.
Temperature of water 74 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement grout
Well sealed from land surface to 221 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 114 sacks
Number of sacks of bentonite used in well seal none sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Flugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to

(10) LOCATION OF WELL:

County Umatilla Driller's well number
Section 29 T. 4N R. 29E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 282 ft.
Static level ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 16
Depth drilled 1172 ft. Depth of completed well 1172 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---------------------------|------|-----|-----|
| sand | 0 | 55 | |
| Broken brn. rock (sur. W) | 55 | 66 | 39 |
| gravel | 66 | 75 | |
| brown clay | 75 | 98 | |
| gravel | 98 | 105 | |
| Brkn brn rock | 105 | 145 | |
| gry clay | 145 | 166 | |
| brkn brn rock | 166 | 180 | |
| stky blue clay | 180 | 183 | |
| brkn black rock | 183 | 193 | |
| blue clay with rock | 193 | 207 | |
| porous blk. rock | 207 | 240 | |
| drk gray basalt | 240 | 250 | |
| blk. basalt | 250 | 280 | |
| gry basalt | 280 | 320 | |
| gry clay | 320 | 370 | |
| blk baslt clay seams | 370 | 390 | |
| blk & brn bas., clay sms | 390 | 420 | |
| gray basalt | 420 | 450 | |

Work started 5/14/ 1974 Completed 3/19 19 75
Date well drilling machine moved off of well 3/24/75 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

(Signed) [Signature] Date 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 545

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name [Signature] (Type or print)
Address Rt. 1 box 116 Milton-Freewater Ore.

(Signed) [Signature] (Water Well Contractor)

Contractor's License No. 204 Date 19

RECEIVED

MAY 15 2009

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

UMAT
2881

State Well No. 4N/29E-20dd

State Permit No. N of Feedville

APR 18 1978

(1) OWNER:

Name IVAN + VERNON CRAY
Address CIRCLE C RANCH, SALEM, OREGON
ECHO OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
14" Diam. from 0 ft. to 185 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? VALLEY PUMP CO.
Flow: 2357 gal./min. with UMAT ft. drawdown after _____ hrs.
1970 . 6.3 . 4 .
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. _____
Temperature of water 82 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used NEAT CEMENT
Well sealed from land surface to 185 ft.
Diameter of well bore to bottom of seal 18 in.
Diameter of well bore below seal 14 in.
Number of sacks of cement used in well seal 80 sacks
How was cement grout placed? _____
Was a drive shoe used? Yes No Plugs _____ Size _____ Location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number 01-78
SE 1/4 SE 1/4 Section 20 T. 4N. R. 29 E W.M.
Bearing and distance from section or subdivision corner
SW 1/4 MJZ

(11) WATER LEVEL: Completed well.

Depth at which water was first found 300 ft.
Static level 297 ft. below land surface. Date 4-2-78
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8" BELOW
Depth drilled 1361 ft. Depth of completed well 1361 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|------------------|------|------|-------|
| SOIL CLAY GRAVEL | 0 | 110 | |
| SOFT GREY BASALT | 110 | 175 | |
| HARD " " | 175 | 300 | |
| BROKEN " " | 300 | 330 | water |
| MED. " " | 330 | 400 | |
| " " " | 400 | 485 | |
| BROKEN " " | 485 | 575 | |
| MED GREY " " | 575 | 889 | |
| SOFT " " | 889 | 995 | |
| BROKEN " " | 995 | 1010 | water |
| HARD " " | 1010 | 1220 | |
| BROKEN " " | 1220 | 1274 | water |
| MED. " " | 1274 | 1286 | |
| HARD " " | 1286 | 1321 | |
| BROKEN " " | 1321 | 1359 | water |
| HARD " " | 1359 | 1361 | |

Work started 1-19 19 78 Completed 2-12 19 78
Date well drilling machine moved off of well 2-12 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Wallace Date 4-6 19 78
(Drilling Machine Operator)

Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Wallace Well Drilling Co.
(Person, firm or corporation) (Type or print)

Address Pennington, Or.
[Signed] Wallace
(Water Well Contractor)

Contractor's License No. 523 Date 4-6 19 78

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-2464-119

T. 10879

MAY 15 2009

WATER RESOURCES DEPT
SALEM, OREGON

RECEIVED

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

RECEIVED

MAY - 5 1977 State Well No. 4M/29E-29dd

WATER RESOURCES DEPARTMENT Permit No. _____
SALEM, OREGON G-7086

UMATILLA #3
2935

(1) OWNER:

Name MORIE KOESTER #3 well
Address Box 42A STANFIELD

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from +2 ft. to -111 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? AIR
Yield: 1000 gal./min. with 300 ft. drawdown after 1 hrs.
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. _____
Temperature of water 63 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in. TO 137
Number of sacks of cement used in well seal 10 sacks TO 925
How was cement grout placed? POURED IN
DRT SPACE BETWEEN 12"
AND 16" PIPE THEN
WITH DRAW 16" PIPE
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL: #3 Home Place

County UMATILLA Driller's well number _____
SE 1/4 SE 1/4 Section 29 T. 4 N. R. 29 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 82 ft.
Static level 70 ft. below land surface. Date 4-22-77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12" TO 137
Depth drilled 925 ft. Depth of completed well 925 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|-----------------|------|-----|-----|
| SAND + SOIL | 0 | 12 | |
| GRAVEL | 12 | 81 | |
| SANDSTONE | 81 | 82 | |
| GRAVEL | 82 | 94 | |
| SANDSTONE | 94 | 102 | |
| BROWN BASALT | 102 | 115 | |
| Black | 115 | 245 | |
| Black w/GR 5/5 | 245 | 250 | |
| Black * | 250 | 370 | |
| w/GR SS | 370 | 410 | |
| Black | 410 | 465 | |
| " SOFT | 465 | 490 | |
| Black | 490 | 590 | |
| Black x Red w/5 | 590 | 607 | |
| Black | 607 | 620 | |
| Black w/GR/5-5 | 620 | 660 | |
| Black | 660 | 765 | |
| Black w/SS | 765 | 855 | |
| Black w/RED/SS | 855 | 893 | |
| Black | 893 | 925 | |

Work started 3-22 1977 Completed 4-22 1977
Date well drilling machine moved off of well 4-22 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jerry Harsin Date 4-22 1977
(Drilling Machine Operator)

Drilling Machine Operator's License No. 993

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Jerry and Nell Drilling
(Person, firm or corporation) (Type or print)

Address 8543 SW Douglas DR Prineville

[Signed] Jerry and Nell
(Water Well Contractor)

Contractor's License No. 344 Date 4-22 1977

RECEIVED

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-4886-118

WATER RESOURCES DEPT
SALEM, OREGON

T-10879

MAY 15 2008

NOTICE TO WATER WELL CONTRACTOR:
The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

OCT 6 1977 STATE OF OREGON
(Please type or print)

UMAT
2934

State Well No. 4N/29E29dd
State Permit No. _____

SALEM, OREGON

(1) OWNER:

Name MORIE KOESTER
Address Box 42A Stanfield, OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from EXISTING ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from NA ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name NA
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? DRILLER
1000 gal./min. with 100 ft. drawdown after 1 hrs.
Ballast test _____ gal./min. with _____ ft. drawdown after _____ hrs.
_____ g.p.m.
Temperature of water 72 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used NA
Well sealed from land surface to _____ ft.
Diameter of well bore to bottom of seal _____ in.
Diameter of well bore below seal _____ in.
Number of sacks of cement used in well seal _____ sacks
How was cement grout placed? _____
Was a drive shoe used? Yes No Plug _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Matilla Driller's well number #3
SE 1/4 SE 1/4 Section 29 T. 4N R. 29E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 945 ft.
Static level 70 ft. below land surface. Date 4-22-77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12 1/4
Depth drilled 25 ft. Depth of completed well 950 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|------------------|-----------------|-----|-----|
| GREY BASALT | 925 | 945 | |
| BK SCORIA W IRON | 945 | 950 | |
| PYRITE and GCL | | | |
| Reamed | 9 1/2 to 12 1/4 | 137 | 600 |
| Drilled | 8 3/4 | 925 | 950 |

Work started 8-20 1977 Completed 8-25 1977
Date well drilling machine moved off of well 8-25 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Jerry Bural Date 8-25, 1977
(Drilling Machine Operator)
Drilling Machine Operator's License No. 933

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Jerry Bural Well Driller
(Person, firm or corporation) (Type or print)
Address 5543 S.W. Douglas St. Beav.
[Signed] Jerry Bural
(Water Well Contractor)
Contractor's License No. 544 Date 8-25, 1977

RECEIVED

MAY 15 1977

(USE ADDITIONAL SHEETS IF NECESSARY)
WATER RESOURCES DEPT
SALEM, OREGON

SP-6052-119

T 10879