

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.785)

NW3
 WASH
 1130

RECEIVED

MAY 11 1989

SP24/da

(START CARD) # 9982

(1) OWNER:
 Name Oregon Garden Products
 Address 3150 SE Minter Bridge Rd.
 City Hillsboro State OR Zip 97123

Well Number # 3-89-1

(9) LOCATION OF WELL by legal description:
 County Wash. Latitude _____ Longitude _____
 Township 1S Nor S. Range 2W E or W, WM _____
 Section 7 NE 14 SE 14
 Tax Lot _____ Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) 3150 SE Minter Bridge Rd., Hillsboro, OR 97123

(2) TYPE OF WORK:
 New Well Deepen Recon/Elon Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Cable
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(5) BORE HOLE CONSTRUCTION:
 Special Construction approved Yes No Depth of Completed Well 182 ft.
 Explosives used Type _____ Amount _____

Diameter	HOLE		Material	SEAL		Amount sacks or pounds
	From	To		From	To	
13 1/2"	0	65	cem/gel	0	65	43 sacks
13 1/2"	65	182	sand pack	65	182	---
6 1/2"	182	209	drill gel			---

How was seal placed? Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from 65 ft. to 182 ft. Size of gravel #4 & #8 Aqua

(6) CASING/LINER:

Casing	Diameter	From	To	Gauge	Material			
					Steel	Plastic	Welded	Threaded
	8	+1	109	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8	129	140	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8	145	159	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8	179	182	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of above(s) _____

(7) PERFORATIONS/SCREENS:

Perforations Method _____
 Screens Type Wire wound Material L.C. steel

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
109	129	.030		8	pipe	<input checked="" type="checkbox"/>	<input type="checkbox"/>
140	145	.030		8	pipe	<input checked="" type="checkbox"/>	<input type="checkbox"/>
159	179	.030		8	pipe	<input checked="" type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailor Air Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
66		70	1 hr.
82		80	2 hr.
92		90	4 hr.
103		100	5 hrs.

Temperature of water _____ Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: _____

(10) STATIC WATER LEVEL:
23 ft. below land surface. Date 4/25/89
 Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:

Depth at which water was first found 109

From	To	Estimated Flow Rate	SWL
109	129	100 gpm	23
140	145	"	"
159	179	"	"

(12) WELL LOG: Ground elevation _____

Material	From	To	SWL
Rock & clay fill	0	1	
Gray clay	1	2	
Wood & fill material	2	27	
Soft brown silty clay	27	49	
Soft gray silty clay	49	109	
Medium to coarse black sand	109	129	
occ. clay interbed			
Sticky gray-brown clay	129	134	
Soft brown sandy clay	134	140	
Fine to coarse brown sand	140	144	
Sticky gray clay	144	161	
Medium to coarse brown sand	161	177	
Sticky gray clay	177	209	

Date started 3/16/89 Completed 4/26/89

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
 WWC Number _____
 Signed _____ Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. all work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.
 WWC Number 266
 Signed [Signature] Date 4/20/89

ORIGINAL & FIRST COPY - WATER RESOURCES DEPARTMENT SECOND COPY - CONSTRUCTOR THIRD COPY - CUSTOMER 8809C 7/86

RECEIVED

MAY 19 2009

WATER RESOURCES DEPT
 SALEM, OREGON

NWS

APR 21 1989

WASH

009603

B. J. Taylor

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

WATER RESOURCES DEPT.
SALEM, OREGON

(START CARD) # 9983

(1) OWNER: Well Number #5 - 89
Name Oregon Garden Products

Address _____
City _____ State _____ Zip _____

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Cable
 Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well 170 ft.
Yes No

Diameter	HOLE		SEAL		Amount sacks or pounds
	From	To	Material	From To	
1 3/4"	0	62	Cement	0 62	42 Sacks
6"	62	170	Sandpack	62 170	
6 1/2"	170	210	Drillgel	170 210	

How was seal placed: Method A B C D E
 Other
Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from 62 ft. to 170 ft. Size of gravel #8 & #4

(6) CASING/LINER:

Casing	Diameter	From	To	Gauge	Material			
					Steel	Plastic	Welded	Threaded
	8	+1	95	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8	135	146	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8	156	161	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8	166	170	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Line:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) _____

(7) PERFORATIONS/SCREENS:

From	To	Slot size	Number	Diameter	Type		Casing	Liner
					Wire wound	Material		
95	135	.030		8"	Pipe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
146	156	.020		8"	Pipe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
161	166	.030		8"		<input type="checkbox"/>	<input type="checkbox"/>	

(8) WELL TESTS: Minimum testing time is 1 hour

Yield gal/min	Drawdown	Drill stem at	Time
60		70	1 hr.
72		80	2 hr.
90		90	3 hr.

Temperature of water _____ Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata _____

(9) LOCATION OF WELL by legal description:
County Wash Latitude _____ Longitude _____
Township 1S Nor S, Range 2W E or W, WM _____
Section 7 NE SE _____
Tax Lot _____ Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) 3150 SE Minter
Bridge Rd. Hillsboro, OR 97123

(10) STATIC WATER LEVEL:
17 ft. below land surface. Date 4/17/89
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:

Depth at which water was first found 92

From	To	Estimated Flow Rate	SWL
92	126	90 gpm	17
129	134	90 gpm	"
143	155	90 gpm	"
160	166	90 gpm	"

(12) WELL LOG: Ground elevation _____

Material	From	To	SWL
Topsoil	0	1	
Dark Brown Clay	1	3	
Soft Brown Silty Clay	3	13	
Fine Muddy Brown Sand	13	15	
Soft Lt. Gray - Brown Clay	15	17	
Soft Brown Silty Clay	17	45	
w/ Fine Sand Streaks			
Soft Gray Silty Clay	45	57	
Fine Gray Sand	57	65	
Soft Gray Silty Clay	65	92	
Fine to Medium Coarse Black Sand	92	108	
Sand			
Sticky <input checked="" type="checkbox"/> Gray Clay	108	109	
Fine to Coarse Black Sand	109	126	
Sticky Gray Clay	126	129	
Fine to Coarse Black Sand	129	134	
Sticky Gray Clay	134	140	
Sticky Brown Clay	140	143	
Fine to Coarse Brown Sand	143	155	
Sticky Light Brown Clay	155	161	
Fine to Coarse Brown Sand	161	166	
Sticky Gray Clay occ. Sand	166	210	
Streaks			

Date started 4/12/89 Completed 4/18/89

(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed _____ Date _____ WWC Number _____

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed *[Signature]* Date 4/17/89 WWC Number 1266

T 10882

MAY 19 2009