

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

2360
 MARI...

NOV 20 1989

Well 2

5S/2W/10Cb

WATER RESOURCES DEPT.
 SALEM, OREGON

(START CARD) # 7022

(1) OWNER: Well Number _____
 Name DeConinck Farms - Andrew DeConinck
 Address 6381 Deconinck Rd. NE
 City Woodburn State OR Zip 97071

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Cable
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(5) BORE HOLE CONSTRUCTION:
 Special Construction approval Yes No Depth of Completed Well 166 ft.
 Explosives used Type _____ Amount _____

HOLE			SEAL			Amount sacks or pounds
Diameter	From	To	Material	From	To	
20"	0	20	Bentonite	0	20	36 sacks
16"	20	166				

How was seal placed: Method A B C D E
 Other QAR 690-210-340
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 16"	+1 1/2	166 1/2	.375	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 166 1/2'

(7) PERFORATIONS/SCREENS:
 Perforations Method Mills knife
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
134'	150'	3/8x3	384			<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailor Air Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
900	47'		1 hr.
900	52'		5 hrs.
1000	60'		1 hr.

Temperature of water 54degrees Depth Artesian Flow Found _____
 Was a water analysis done? Yes No By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: _____

(9) LOCATION OF WELL by legal description:
 County Marion Latitude _____ Longitude _____
 Township 5S N or S, Range 2W E or W, WM.
 Section 10 NW 1/4 SW 1/4
 Tax Lot _____ Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) 6381 DeConinck Rd NE Woodburn, OR 97071

(10) STATIC WATER LEVEL:
26' ft. below land surface. Date 10/27/89
 Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
 Depth at which water was first found 126'

From	To	Estimated Flow Rate	SWL
126	157	1000 gpm	26'

(12) WELL LOG: Ground elevation _____

Material	From	To	SWL
Top soil	0	1	
Clay sandy brown	1	28	
Clay sticky blue	28	38	
Clay sandy blue	38	42	
Clay blue	42	51	
Clay sticky blue	51	71	
Clay blue hard	71	74	
Clay sticky blue	74	76	
Clay sandy	76	103	
Clay grey sandy	103	110	
Clay grey, sand, gravel	110	116	
Sand, gravel, clay grey hard	116	126	
Gravel small	126	137	
Gravel large	137	153	
Sand, gravel, wood	153	157	
Clay sticky blue	157	159	
Clay sandy grey	159	166	

Date started 9/28/89 Completed 10/27/89

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
 WWC Number _____
 Signed _____ Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. all work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.
 WWC Number 783
 Signed Ivan Mason Date 11/17/89

**WATER WELL REPORT
STATE OF OREGON**

MARI... 2350

RECEIVED

State Well No. SS/2W-9da

PLEASE TYPE OR PRINT IN INK
FEB 7 1985

State Permit No. _____

WATER RESOURCES DEPT

SALEM, OREGON DIVISION OF WELL:

(1) OWNER:

Name Andrew DeConinck
Address 876 Church St.
City Woodburn State OR 97071

County Marion Driller's well number 42
NE $\frac{1}{4}$ SE $\frac{1}{4}$ Section 9 T. 55 R. 2W W.M.
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

Address at well location: 6381 Deconinck Rd. NE Woodburn, OR.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: _____ Withdrawal Reinjection

(4) PROPOSED USE (check):

(11) WATER LEVEL: Completed well.

Depth at which water was first found 108 ft.
Static level 12 ft. below land surface. Date Jan 7/85
Artesian pressure _____ lbs. per square inch. Date _____

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
12" Diam. from 7 1/2 ft. to 160 1/2 ft. Gauge 250
" Diam. from _____ ft. to _____ ft. Gauge _____

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 160 ft. Depth of completed well 158 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

LINER INSTALLED:

" Diam. from _____ ft. to _____ ft. Gauge _____

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used mills knife
Size of perforations 3/8 in. by 3 in.
360 perforations from 130 ft. to 142 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

MATERIAL	From	To	SWL
Top Soil	0	1	
Clay Brown	1	34	
Clay Grey	34	90	
Sandy Clay Grey	90	90 1/2	
Clay Grey Gravel	104	108	
Sand Gravel	108	111	
Sand Silt	111	119	
Sandy Clay Grey	119	127	
Gravel Sand	127	129 1/2	12
Sand	144	153	
Clay Grey	153	160	

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
a pump test made? Yes No If yes, by whom?
Well: _____ gal./min. with _____ ft. drawdown after _____ hrs.
Air test _____ gal./min. with drill stem at _____ ft. _____ hrs.
Bailer test 40 gal./min. with 3 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used port. land cement grout
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 24 sacks
How was cement grout placed? pumped
Was pump installed? n.p. Type in HP _____ Depth _____ ft.
Was a drive shoe used? Yes No Plug _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Work started 12/12 1984 Completed Jan 7 1985
Date well drilling machine moved off of well Jan 7 1985

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] _____ Date _____, 19____

Bonded Water Well Constructor Certification:
Bond 87-76-5318-9 Issued by: State Form
(number) Surety Company Name _____
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Grossen's Well Drilling
(Person, firm or corporation) (Type or print)
Address 19927 Mill Ck Rd. Scotts Mills
[Signed] Ivan Grossen
Water Well Constructor
Date Jan 10, 1985

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion. SP*45292-690

1 19920

Proposed Well 4

MARI 59731

STATE OF OREGON WATER SUPPLY WELL REPORT

WELL I.D. # L 75909 START CARD # 163488

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number Name Ronald & Joan DeConinck Address 6381 DeConinck Rd. NE City Woodburn State OR Zip 97071

(2) TYPE OF WORK [X] New Well [] Deepening [] Alteration (repair/recondition) [] Abandonment

(3) DRILL METHOD: [] Rotary Air [] Rotary Mud [X] Cable [] Auger [] Other

(4) PROPOSED USE: [] Domestic [] Community [] Industrial [X] Irrigation [] Thermal [] Injection [] Livestock [] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [] Yes [X] No Depth of Completed Well 148 ft. Explosives used [] Yes [X] No Type Amount

Table with columns: HOLE Diameter, From, To, SEAL Material, From, To, Sacks or pounds. Includes entries for cement and 5% bentonite.

How was seal placed: Method [] A [] B [X] C [] D [] E [] Other Backfill placed from 148 ft. to 218 ft. Material concrete Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes casing and liner details.

(7) PERFORATIONS/SCREENS: Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Includes screen and bottom plate details.

(8) WELL TESTS: Minimum testing time is 1 hour. [X] Pump [] Bailer [] Air [] Flowing Artesian. Table with Yield gal/min, Drawdown, Drill stem at, Time.

Temperature of water 53 Depth Artesian Flow Found Was a water analysis done? [] Yes By whom Did any strata contain water not suitable for drinking? [] Salty [] Muddy [] Odor [] Colored [] Other Depth of strata:

(9) LOCATION OF WELL by legal description: County Marion Latitude Longitude Township 5S N or S Range 2W E or W. WM. Section 10 NW 1/4 SE 1/4 Tax Lot 900 Lot Block Subdivision Street Address of Well (or nearest address) 15884 Arbor Grove Rd NE, Woodburn, OR

(10) STATIC WATER LEVEL: 14 ft. below land surface. Date 4/28/06 Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES: Depth at which water was first found 84'

Table with columns: From, To, Estimated Flow Rate, SWL. Includes entry for 84 to 142 ft with 1500 gpm flow rate.


(12) WELL LOG: Ground Elevation

Table with columns: Material, From, To, SWL. Lists soil layers from Topsoil to Sand & gray silty clay.

Date started 2/2/06 Completed 5/9/06 (unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief. Signed [Signature] WWC Number 1704 Date 6/1/06

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief. Signed [Signature] WWC Number 783 Date 6/1/06



T 10924