

WATER WELL REPORT
STATE OF OREGON

K LAM
2078C

RECEIVED

JUL 21 1981

State Well No. *365/27-22C*

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name Kenneth Allison
Address 2028 Reclamation
City Klamath Falls State OR 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
Cased Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
12" Diam. from +1 ft. to 277 ft. Gauge 250
" Diam. from " ft. to " ft. Gauge "

LINER INSTALLED:

" Diam. from " ft. to " ft. Gauge "

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Valley Pump
Id: 1500 gal/min. with 33 ft. drawdown after 1 hrs.
Air test gal/min. with drill stem at _____ ft. hrs.
Bailer test gal/min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m.
Temperature of water 56 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement & 5% Bentonite
Well sealed from land surface to 276 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 94 sacks
How was cement grout placed? Pumped from bottom of casing up to the ground surface.

Was pump installed? NO Type _____ HP _____ Depth _____ ft.
Was a drive shoe used? Yes No Plug _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
E 1/2 1/4 SW 1/4 Section 22 T. 36 S. R. 12 E. W.M.
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____
Address at well location: _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 142 ft.
Static level 23 ft. below land surface. Date 7-7-81
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12" & 8"

Depth drilled 597 ft. Depth of completed well 597 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy Top Soil	0	1	
Pumice & Gravel	1	19	
Brown Clay	19	36	
Blue Clay	36	41	
Yellow Clay & Pumice	41	50	
Brown Sandstone	50	59	
White Pumice	59	70	
Brown Clay	70	76	
Green Clay	76	81	
Black Sand	81	82	
Blue Clay	82	139	
Black Cinder Rock	139	141	
Blue Shale	141	142	
Blue Clay with Streaks of -			
White Pumice	142	168	23'
Blue Clay	168	210	
Brown Clay with Streaks of -			
Brown Sand	210	222	23'
Blue Clay with Streaks of -			
Black Sand	222	234	23'
Continued On Another Sheet			

Work started 6-8 19 81 Completed 7-7 19 81
Date well drilling machine moved off of well 7-7 19 81

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Stephen A. Hughes Date 7-9, 19 81
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1171

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Norm Sevey Well Drilling, Inc.
(Person, firm or corporation) (Type or print)
Address 800 Old Midland Rd. Klamath Falls, OR 97601
[Signed] Norm Sevey
(Water Well Contractor)
Contractor's License No. 408 Date 7-9-81, 19 81

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

MAR 11 2010

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690

T 11029

WATER RESOURCES DEPT
SALEM, OREGON

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

KLAMATH
10447

MAY - 6 1992

36S/12E/28aa
 (START CARD) # 32789

(1) OWNER: Well Number: 2
 Name Terry L. Hager
 Address P.O. Box 85
 City Beatty State OR Zip 97621

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Cable
 Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:
 Special Construction approval Yes No Depth of Completed Well 267 ft.
 Explosives used Yes No Type _____ Amount _____

HOLE			SEAL			Amount sacks or pounds
Diameter	From	To	Material	From	To	
16	0	180	Cement & Bent.	0	180	103sks
10	180	267				1/2 sk

How was seal placed: Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Casing/Liner	Diameter	From	To	Gauge	Material			
					Steel	Plastic	Welded	Threaded
Casing	12	1	180	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of sheets: None

(7) PERFORATIONS/SCREENS:
 Perforations Method _____
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailer Air Flowing Artesian
 Yield gal/min 1700 Drawdown _____ Drill stem at 130' Time 1 hr.

Temperature of water 51 F Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other none
 Depth of strata: _____

(9) LOCATION OF WELL by legal description:
 County Klamath Latitude _____ Longitude _____
 Township 36 S N. or S. Range 12 E E or W. WM. _____
 Section 28 NE 1/4 NE 1/4
 Tax Lot 100 Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) MP 39 Highway
104 E. Beatty, OR

(10) STATIC WATER LEVEL:
37' ft. below land surface. Date 4, 1, 92
 Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:

Depth at which water was first found 40 ft.

From	To	Estimated Flow Rate	SWL
40	75	50 gpm	26
79	182	250 gpm	26
182	267	2000 gpm	23

(12) WELL LOG: Ground elevation 4250

Material	From	To	SWL
Sandy Top Soil	0	1	
Cemented Gravel & Pumice	1	9	
White Pumice	9	56	26
Blue Clay	56	65	
White Pumice	65	75	26
Yellow Clay	75	79	
Black Sandstone	79	82	26
White Pumice	82	182	26
Broken Brown Lava Rock	182	205	23
Broken Black Rock	205	267	23

Date started 4-1-92 Completed 4-7-92

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Stephen R. Hughes WWC Number _____
 Date 4-16-92

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. all work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed Stephen R. Hughes WWC Number 777
 Date 4-16-92

1 11029

WELL TEST REPORT

Interstate PUMP COMPANY, INC.

503/882-3464 — 7209 SOUTH SIXTH STREET
KLAMATH FALLS, OREGON 97603

For: William Rajnus Jr.

MAY 6 1992

Terry Hager

WATER RESOURCES DEPT. Date Tested 10 April 1992
SALEM, OREGON

P.O. Box 85 Beatty, OR 97621

Location of Well South of Hagers place Beatty, Oregon

Inside Diameter 12"

Depth _____

Feet of _____ Inch Casing.

Driller Sevey Well Drilling

130 Feet of 10 Inch Column and 3 Stage 12 Inch Bowls.

Test Done By Lee Campbell

Static Water Level at Start of Test 27 (?)

CAPACITY GPM	PUMPING LEVEL	DRAWDOWN	TIME	CONDITION OF WATER (SANDY, MUDDY, CLEAR, ETC.)
1200	87 Ft.		12:00PM	Clear
1700	130 Ft.		1:00PM	"
1500	125 Ft.		2:00PM	"
1400	105 Ft.		3:00PM	"
1400	89 Ft.		3:30PM	"
1100	81 Ft.		4:00PM	"
			4 Hr. Total Test	

RECEIVED

MAR 11 2010

WATER RESOURCES DEPT
SALEM, OREGON

TEMPERATURE _____

Static Water Level After Pump Test _____

REMARKS: _____

T 11029

Signed by Lee Campbell