

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

UMAT
1224

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

Date Well No.

3N/28E34

NOV 1 1976

State Permit No.

SPARKS

(1) OWNER:

Name Glen Maddox
Address P. O. Drawer P, Moses Lake, Wa. 98837

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from +1 ft. to 44 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Valley Pump
Yield: 3260 gal./min. with 17 ft. drawdown after 8 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 44 ft.
Diameter of well bore to bottom of seal 26 in.
Diameter of well bore below seal 15 in.
Number of sacks of cement used in well seal 105 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

WATER RESOURCES DEPT.
(10) LOCATION OF WELL:

County Umatilla Driller's well number #1
1/4 1/4 Section 34 T. 3N R. 28E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 404 ft.
Static level 425 ft. below land surface. Date 9/20/76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 830 ft. Depth of completed well 830 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Gravel cemented	2	36	
Basalt broken brown	36	39	
Basalt med hard brown	39	57	
Basalt med black	57	77	
Basalt hard black	77	100	
Basalt soft blk(quartz & clay)	100	117	
Basalt hard black	117	144	
Basalt soft brown	144	160	
Basalt soft black	160	177	
Basalt med black	177	186	
Basalt soft black & blue clay	186	200	
Basalt soft black	200	227	
Basalt med black	227	262	
Basalt soft black	262	270	
Basalt hard black	270	272	
Basalt soft black	272	287	
Basalt med black	287	295	
Basalt hard black	295	330	

Work started 8/20 1976 Completed 9/10 1976
Date well drilling machine moved off of well 9/10 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Richard F. Prister Date 10/1, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1007

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Steve Moore
(Person, firm or corporation) (Type or print)

Address P. O. Box P, Moses Lake, Wa. 98837

[Signed] Steve Moore
(Water Well Contractor)

Contractor's License No. 628 Date 10/1, 1976

RECEIVED

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*4668-119

T 11040

MAR 22 2010

WATER RESOURCES DEPT
SALEM, OREGON

October 28, 1976

RECEIVED
NOV 1 1976
WATER RESOURCES DEPT.
SALEM, OREGON

Water Resources Department
1178 Chemeketa Street N. E.
Salem, Oregon 97310

Re: File #G-5820 - Permit #G-5812

Gentlemen:

As you can see from the enclosed well log, this well yields 3,260 gallons per minute. This is sufficient water to irrigate the ground that this permit applies to, so it will not be necessary to drill another well. I hope this meets with your approval.

Sincerely yours,

Glen Maddox

GLEN MADDOX
P. O. Drawer P
Moses Lake, Wa. 98837

RECEIVED
MAR 22 2010
WATER RESOURCES DEPT
SALEM, OREGON

11040

STATE OF OREGON
WATER SUPPLY WELL REPORT
(as required by ORS 537.765)

UMAT
50476

RECEIVED

WELL I.D.# 408754
Sparks Reconditioned

MAR 14 1997

(START CARD) # 096888

Instructions for completing this report are on the last page of the WATER RESOURCES DEPT.

(1) OWNER: Well Number _____

Name SIMPLot
Address PO BOX 850
City Humilton State OR Zip 97838

(2) TYPE OF WORK
 New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well _____ ft.
Explosives used Yes No Type _____ Amount _____

HOLE			SEAL			
Diameter	From	To	Material	From	To	Sacks or pounds

How was seal placed: Method A B C D E
 Other

Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) _____

(7) PERFORATIONS/SCREENS:

Method		Type		Material	
From	To	Slot size	Number	Diameter	Tube/pipe size

(8) WELL TESTS: Minimum testing time is 1 hour

<input type="checkbox"/> Pump	<input type="checkbox"/> Bailer	<input type="checkbox"/> Air	<input type="checkbox"/> Flowing Artesian
Yield gal/min	Drawdown	Depth stem at	Time
			1 hr.

Temperature of water _____ Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

(9) LOCATION OF WELL by legal description:
County Umatilla Latitude _____ Longitude _____
Township 3N N or S Range 28E E or W. WM.
Section 34 NE 1/4 8E 1/4
Tax Lot _____ Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) _____

(10) STATIC WATER LEVEL:
482 ft. below land surface. Date 2-27-97
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:

Depth at which water was first found _____

From	To	Estimated Flow Rate	SWL

(12) WELL LOG:
Ground Elevation _____

Material	From	To	SWL
<u>clean out obstruction in well and seem 12" steel pipe to bottom</u>			

RECEIVED
MAR 22 2010
WATER RESOURCES DEPT
SALEM, OREGON

Date started 2-20-97 Completed 3-5-97

(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

WWC Number 1683
Signed TONY BOWMAN Date 3-5-97

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

WWC Number 544
Signed Tony Bunde Date 3-5-97

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

UMAT 1215

WATER WELL REPORT

STATE OF OREGON (Please type or print)

(Do not write above this line)

RECEIVED

MAY 25 1976

State Well No. 3N/28E-24

WATER RESOURCES DEPT. No. LEL#1

SALEM, OREGON

(1) OWNER:

Name G & L FARMS INC. Address 807 W. TAMARACK HERMISTON, OREGON

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Cable [] Dug [] Driven [] Jetted [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) CASING INSTALLED:

16" Diam. from +1 ft. to -49 ft. Gage 250

(6) PERFORATIONS:

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Yield: 2000+ gal./min. with ft. drawdown after hrs. AIR LIFT

(9) CONSTRUCTION:

Well seal-Material used NEAT CEMENT Well sealed from land surface to 49 ft. Diameter of well bore to bottom of seal 20 in. Diameter of well bore below seal 16 in. Number of sacks of cement used in well seal 50 sacks

(10) LOCATION OF WELL:

County AMATILLA Driller's well number 04-76 SW 1/4 SE 1/4 Section 26 T. 3N R. 28 E. W.M.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 306 ft. Static level 330 ft. below land surface. Date 4-20-76 Artesian pressure NONE lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 16" to 10 1/2" Depth drilled 1,012 ft. Depth of completed well 1,012 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Silt, Sand (0-14), Gravel Clay (14-30), Med Hard Brown Basalt (30-65), Hard Grey (65-85), Med Hard Grey (85-127), Soft Grey (127-135), Hard Grey (135-256), Med Hard Grey (256-281), Hard Grey (281-306), Soft, Broken, Seams (306-331) WATER, Hard Grey (331-452), Broken Grey w/scapstone (452-456) WATER, Hard Grey Basalt (456-588), Broken w/seam (588-638) WATER, Hard Grey (638-888), Broken w/scapstone (888-913) WATER, Hard Grey Basalt (913-988), Broken Basalt (988-988) WATER, Hard Grey Basalt (988-1012)

Work started 2-26 1976 Completed 4-20 1976 Date well drilling machine moved off of well 4-24 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Gerald A. Wallace Date 5-23 1976

Drilling Machine Operator's License No. 986

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name Wallace Well Drbg. Co. Address Box 892 PENDELTON

[Signed] Everett A. Wallace (Water Well Contractor) Contractor's License No. 583 Date 5-23 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

UMAT
1216

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

MAY 25 1976 State Well No.

WATER RESOURCES DEPT. State Permit No.

SALEM, OREGON

67242
3N/20E-26
LCL#2

(1) OWNER:

Name L & B FARMS INC.
Address P.O. Box 611
ECHO, ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 81 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No. If yes, by whom? _____
Yield: 1000 gal./min. with _____ ft. drawdown after _____ hrs.
AIR LIFT " " " " " "
" " " " " " " "
Baller test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow NONE g.p.m.
Temperature of water 67 Depth artesian flow encountered NONE ft.

(9) CONSTRUCTION:

Well seal—Material used NEAT CEMENT
Well sealed from land surface to 81 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 14 in. to 450 ft.
Number of sacks of cement used in well seal 50 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water 5 GAL. WATER PER BAG CEMENT lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County UMATILLA Driller's well number 7-76
NE 1/4 NW 1/4 Section 26 T. 3N R. 28 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 327 ft.
Static level 330 ft. below land surface. Date 5-7-76
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 14" TO 450 ft.

Depth drilled 911 ft. Depth of completed well 911 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SAND, SILT	0	4	
CLAY	4	12	
GRAVEL	12	38	
BROWN BASALT	38	67	
HARD GREY BASALT	67	145	
BROKEN RED BASALT	145	165	
HARD GREY BASALT	165	274	
BROKEN GREY BASALT	274	295	
HARD GREY BASALT	295	327	
BROKEN SOAPSTONE	327	341	WATER
HARD GREY BASALT	341	425	
BROKEN GREY SOAPSTONE	425	435	WATER
HARD GREY BASALT	435	601	
BROKEN GREY BASALT	601	608	
HARD GREY BASALT	608	615	
BROKEN GREY BASALT	615	650	
MED. HARD GREY	650	870	
BROKEN GREY BASALT	870	901	WATER
HARD GREY BASALT	901	911	

Work started 4-26 1976 Completed 5-7 1976
Date well drilling machine moved off of well 5-7 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Garrett A. Wallace Date 5-23, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name WALLACE WELL DRILLING CO.
(Person, firm or corporation) (Type or print)

Address BOX 22 PENDLETON, O.R.

[Signed] Garrett A. Wallace
(Water Well Contractor)

Contractor's License No. 523 Date 5-23, 1976

RECEIVED

USE ADDITIONAL SHEETS IF NECESSARY

SP*45636-119

T 11040

WATER RESOURCES DEPT
SALEM, OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED 6-750
30/28K-23
State Well No. _____
JAN 19 1977
State Permit No. _____

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

(Do not write above this line)
WATER RESOURCES DEPT.

(1) OWNER:

Name G.L. FARNS
Address P.O. Box
KCHO, ORE.

UMAT
1214

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

16" Diam. from +1 ft. to -60 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
_____ gal./min. with _____ ft. drawdown after _____ hrs.
EST-2000 GPM AIR BNT " " " " " "
" " " " " " " " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
_____ gal./min. with _____ ft. drawdown after _____ hrs.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used HEAT CEMENT
Well sealed from land surface to 60 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 30 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

SALEM, OREGON
County UMATILLA Driller's well number LEL #3
NW 1/4 NW 1/4 Section 23 T. 3N. R. 28 E.W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well

Depth at which water was first found 40 ft.
Static level 51 ft. below land surface. Date 12-18-76
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8" below
Depth drilled 936 ft. Depth of completed well 936 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY SOIL	0	12	
SOFT BROWN BASALT	12	40	water
HARD GREY BASALT	40	127	
BROKEN RED W/SLAPSTONE	127	140	water
GREY BASALT	140	172	
BROKEN RED W/SLAPSTONE	172	190	WATER
VERY HARD GREY BASALT	190	272	
GREY W/SLAPSTONE	272	277	
MED. HARD GREY BASALT	277	415	
VERY HARD GREY	415	478	
SOFT GREY BASALT	478	489	
HARD GREY	489	638	1.38
SOFT GREY	638	645	
MED. HARD GREY	645	670	
BROKEN RED	670	702	WATER
HARD GREY	702	814	
BROKEN GREY	814	842	2mtr 842
HARD GREY	842	912	
BROKEN GREY	912	936	WATER
Work started	12-3	1976	Completed 12-18 1976
Date well drilling machine moved off of well	12-18	1976	

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Richard Date 1-17 1977
(Drilling Machine Operator)
Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WABACE WELL DRG. CO.
(Firm or corporation) (Type or print)
Address TEMPLETON, ORE.
[Signed] Richard
(Water Well Contractor)
Contractor's License No. 583 Date 1-17 1977

RECEIVED
(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45856-119

T 11040

MAR 22 2010
WATER RESOURCES DEPT
SALEM, OREGON

RECEIVED

UMAT 5816

3N/28E/236 46860

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

MAY 17 1993

WATER RESOURCES DEPT. SALEM, OREGON

(START CARD) #

(1) OWNER: Name L & L Farms Address P.O. Box 63 City Echo State OR Zip 97826

(2) TYPE OF WORK: [] New Well [x] Deepen [x] Recondition [] Abandon

(3) DRILL METHOD: [x] Rotary Air [] Rotary Mud [] Cable [] Other

(4) PROPOSED USE: [] Domestic [] Community [] Industrial [x] Irrigation [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [] Yes [x] No Depth of Completed Well 1055 ft.

Table with columns: HOLE Diameter, From, To, SEAL Material, From, To, Amount sacks or pounds. Includes handwritten entries for 14" and 8" diameters.

How was seal placed: Method [] A [] B [] C [] D [] E [] Other

Backfill placed from ___ ft. to ___ ft. Material ___ Gravel placed from ___ ft. to ___ ft. Size of gravel ___

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes handwritten 'N/A' for casing.

Final location of shoe(s) ___

(7) PERFORATIONS/SCREENS: Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Table with columns: Yield gal/mln, Drawdown, Drill stem at, Time. Includes handwritten '1500+' and '1055'.

Temperature of Water 62° Depth Artesian Flow Found ___ Was a water analysis done? [] Yes [] No

(9) LOCATION OF WELL by legal description: County Umatilla Latitude ___ Longitude ___ Township 3N N or S. Range 28E E or W. WM. Section 23 NW 1/4 NW 1/4 Tax Lot 7100 Lot ___ Block ___ Subdivision ___ Street Address of Well (or nearest address) Echo, OR 97826

(10) STATIC WATER LEVEL: 349 ft. below land surface. Date 1-26-93 Artesian pressure ___ lb. per square inch. Date ___

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL. Includes handwritten '978' and '300'.

(12) WELL LOG: Ground elevation ___

Well log table with columns: Material, From, To, SWL. Includes handwritten notes: 'Reconditioning & Deepening Procedure', 'Existing hole was: 14" from 0 to 500, 8" from 500 to 936, Well was reamed to 14" from 500 to 600, Well was deepened from 936 to 1055.', 'Gray basalt 936-978, Black basalt with green soapstone 978-986 WB, Gray basalt 986-1055'.

RECEIVED MAR 22 2010 WATER RESOURCES DEPT SALEM, OREGON

Date started 12-22-93 Completed 1-26-93

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief. Signed ___ Date ___ WWC Number ___

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief. Signed Patrick Wallace Date 2-20-93 WWC Number 1218

T 11040