



Oregon

Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

January 20, 2023

BEVERLY FARLEY
15243 COUNTRYSIDE DRIVE
AURORA, OR 97002

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 14234	Permit: G 13131 *	CLAC0053487	CLAC0053487	06/09/1998	REJECTED	None	A WELL (L-14907)
G 14234	Permit: G 13131 *	CLAC0053487	CLAC0008792	06/05/1996	APPROVED	Multiple Well	A WELL (L-14907)

Please contact me if you have any questions.

Sincerely,

Travis Brown
971-301-3088
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File



Oregon

Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

January 20, 2023

BEVERLY FARLEY
15243 COUNTRYSIDE DRIVE
AURORA, OR 97002

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 14234	Permit: G 13131 *	CLAC0053487	CLAC0053487	06/09/1998	REJECTED	None	A WELL (L-14907)
G 14234	Permit: G 13131 *	CLAC0053487	CLAC0008792	06/05/1996	APPROVED	Multiple Well	A WELL (L-14907)

The test was rejected for the following reason(s):

- o Rising water levels during the pumping phase of the test indicate that pumping was not constant.

Please contact me if you have any questions.

Sincerely,

Travis Brown
971-301-3088
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File



Oregon

Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

January 20, 2023

BEVERLY FARLEY
15243 COUNTRYSIDE DRIVE
AURORA, OR 97002

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 14234	Permit: G 13131 *	CLAC0053487	CLAC0053487	06/09/1998	REJECTED	None	A WELL (L-14907)
G 14234	Permit: G 13131 *	CLAC0053487	CLAC0008792	06/05/1996	APPROVED	Multiple Well	A WELL (L-14907)

The pumping test conducted June 9-10, 1998 was rejected for the following reason(s):

- o Rising water levels during the pumping phase of the test indicate that pumping was not constant.

Please contact me if you have any questions.

Sincerely,

Travis Brown
971-301-3088
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File

