

Baker City Aquifer Storage and Recovery (ASR) Feasibility Report

PREPARED FOR
Baker City



PREPARED BY
Groundwater Solutions, Inc.



Groundwater Solutions Inc.

IN ASSOCIATION WITH
Anderson Perry &
Associates, Inc.




and
Stettler Supply Company

JUNE 2003



**Baker City
Aquifer Storage and Recovery (ASR) Feasibility
Report**



Prepared for:

City of Baker City

Prepared by:

Groundwater Solutions, Inc.

In Association with:
Anderson Perry & Associates
Stettler Supply Company

June 2003

RECEIVED

OCT 03 2003

WATER RESOURCES DEPT.
SALEM, OREGON

Table of Contents

Executive Summary.....	1
Benefits of ASR.....	1
ASR Project Scope	1
Feasibility Study Results	2
Uncertainties.....	3
Conclusions and Recommendations.....	3
1.0 Introduction	6
1.1 Purpose and Objectives	6
1.2 Project Scope	7
2.0 Hydrogeologic Characterization.....	10
2.1 Physical Setting	10
2.2 Geology	10
2.3 Geologic Structures	11
2.4 Hydrogeology	11
Groundwater Development	12
3.0 Aquifer Testing.....	16
3.1 Step-Rate Test	17
3.2 Constant Rate Test.....	17
3.3 Aquifer Parameter Estimation	18
4.0 Water Quality Compatibility	21
4.1 Native Groundwater Quality	21
General Chemistry.....	21
Regulated Constituents.....	23
Mineral Stability.....	23
4.2 Recharge Source Water Quality	23
General Chemistry.....	23
Suspended Sediment.....	24
Mineral Stability.....	24
4.3 Mixing Analysis	24
Geochemical Modeling Results.....	25
Disinfection By-Products	26
5.0 Recharge Water Availability	33
5.1 General.....	33
5.2 Winter Season.....	33
5.3 Winter Recharge.....	34
5.4 Summer Season	34
6.0 Recharge Analysis	36
6.1 Introduction	36
6.2 Aquifer Characteristics	36
6.3 Target Injection and Pumping Rates and Storage Volume	37
Winter-time Injection Criteria	37
Summer-time Injection Criteria.....	37
Pumping Criteria	38

6.4 Assessment of Target Injection and Recovery Rates	38
6.5 Evaluation of Available Storage Volume.....	40
6.6 Capture of Stored Water by Other Wells.....	40
7.0 Conclusions, Uncertainties, and Recommendations.....	42
7.1 Conclusions	42
7.2 Uncertainties.....	42
7.3 Recommendations	43
8.0 Conceptual ASR System Design, Operation, and Cost Update	46
8.1 Conceptual ASR Design and Operation.....	46
Recharge.....	46
Withdrawal	47
8.2 ASR Program Cost Update.....	47
References	51

Tables

Table 3-1: Well Data for Well Locations within ½ Mile of the Baker City Reservoir Well
Table 4-1: Summary of Native Groundwater and ASR Source Water Quality Testing
Table 5-1: Projected Future Water System Demands
Table 6-1: Estimated Drawup and Drawdown During ASR Operations at the Reservoir Well
Table 8-1: Phase 2 Pilot Project Updated Cost Estimate

Figures

Figure 1-1: Project Location Map
Figure 2-1: Geologic Map
Figure 2-2: Geologic Cross Section A-A'
Figure 2-3: Geologic Cross Section B-B'
Figure 4-1: Stiff Diagram Illustrating Major Cations & Anions
Figure 4-2: Piper Diagram Illustrating Water Quality Signatures
Figure 4-3: Baker City Reservoir Well Water Quality Trends
Figure 4-4: Mountain Line Turbidity and Well Flow Data
Figure 6-1: Assessment of Target Injection and Recovery Rates
Figure 8-1: ASR Preliminary Site Plan
Figure 8-2: Hydraulic Profile

Appendices

Appendix A: Well Logs
Appendix B: Aquifer Test Analysis and Results
Appendix C: Laboratory Water Quality Data
Appendix D: ASR Head Buildup/Drawdown Calculations
Appendix E: Phase 2 ASR Scope of Work
Appendix F: ASR Process Narrative – Stettler Supply Company

Executive Summary

This report presents the results of a study to investigate the feasibility of Aquifer Storage and Recovery (ASR) as a technology to provide a reliable emergency or peak supply of 2.5 million gallons per day (MGD) of potable drinking water to the City of Baker City. ASR is defined as the underground storage of treated water in a suitable aquifer during times when there is excess water available (e.g., winter and spring) and then recovery of the stored water during months when the water is needed to meet peak or emergency water demands.

Benefits of ASR

ASR offers the City a number of potential benefits including:

- Increasing the volume of water available to the City to meet peak summer water demands,
- Increasing the reliability of the backup/emergency source provided by the Reservoir Well in the event that there is a fire in the watershed,
- More effectively utilizing high quality water that would otherwise be spilled or diverted from the City's system when available supply from the watershed exceeds demand, and
- Improving the quality of the water produced by the Reservoir Well.

Implementation of ASR at the Reservoir Well site is a cost effective alternative compared with developing additional production wells elsewhere because there are substantial costs involved in finding sites, obtaining the water rights, drilling the wells, and building the pump stations and infrastructure to deliver the water. Groundwater development without ASR may not be sustainable due to the limited amount of natural groundwater recharge in this region and native groundwater quality is generally less acceptable compared to surface water sources. ASR in contrast, stores high-quality surface water from the City's watershed in the aquifer, and the quality of the recovered water is very similar.

ASR Project Scope

The study focused on a number of technical issues relating to ASR feasibility including suitability of the local aquifer for storing water, water quality compatibility between the injected source water and native groundwater, water availability for recharge, quantity of water that can be injected, stored and recovered, and the water level response at the Reservoir Well during injection and pumping. The study also presents a conceptual ASR system design, operational scheme, and updated Phase 2 pilot testing cost estimate. The work performed for the feasibility study and Phase 2 pilot testing provides the City with information necessary to prove the feasibility and effectiveness of ASR, and at the same time, provides information to the Oregon Water Resources Department (OWRD) that is required as part of the ASR permitting process.

Feasibility Study Results

The results of the feasibility study indicate that there is sufficient water available from the watershed in the winter and early summer to conduct recharge, the aquifer is capable of storing at least 115 million gallons (MG) of high quality water at the Reservoir Well site, and the well should be capable of producing water at a rate of 1800 gpm for a period of at least 45 days without overpumping the aquifer or producing poor quality water. We estimate that it may be possible to store 165 MG and recover this water at a rate of 1,800 gpm in a given year, which will extend the summer recovery period to between 60 and 90 days, based on the following assumptions:

- The well efficiency can be maintained
- The size of the aquifer is not limited
- The aquifer does not become less permeable
- Seeps do not develop

According to historical records, the Reservoir Well production typically decreases to 1,000 gpm or less within 30 days of continuous pumping, and the quality of the water degrades to the point where residents complain. Over the last 25 years, the City has pumped approximately 560 MG from the aquifer and there has been a 73-foot decline in static water level, which indicates that even sporadic, un-sustained pumping has exceeded the natural rate of groundwater recharge. ASR will substantially improve and extend the sustainable production capacity of the well and improve the quality of water produced after extended periods of pumping. In addition, ASR will stop “mining” of the aquifer that has occurred over the past 25 years.

The quality of the recovered water will be similar to the quality of the mountain line water (which is excellent) and no adverse chemical reactions are expected as a result of mixing surface water with native groundwater. Because the watershed periodically produces water containing suspended sediment (turbidity), particularly in the early winter and spring, attention must be given to making sure that injection is not occurring when turbidity values exceed 1 NTU. Recharge water containing elevated turbidity values will clog the well and reduce injection and pumping capacity. Any reduction in pumping capacity will be a significant concern to the City. The City has an automatic turbidity monitoring system and 24-hour auto-dialer that will trigger an alarm if turbidity values exceed the target threshold. In addition, the mountain line water will be stored in a 4.5 MG contact chamber prior to being boosted to the ASR well; and because of its size and dilution capacity, the reservoir provides additional protection from turbidity events.

Even with the attention given to monitoring turbidity, ASR wells will clog over a period of time. Reduction in injection and pumping capacity caused by clogging can be managed by periodically backflushing the well (stop injection and pump to waste) in order to remove sediment from the well. Depending on the amount of observed clogging, it may be necessary to remove the pump and aggressively redevelop the well every 2 to 3 years.

Uncertainties

The feasibility study identified several uncertainties that will require further investigation during the ASR pilot testing. The uncertainties include:

1. The ability of the ASR well to maintain target injection and pumping rates. This will depend upon the well efficiency over time, storage zone size and permeability, and actual rate of clogging caused by turbidity and possibly entrained air. Several measures should be implemented to maintain the injection and pumping capacity including:
 - Flushing the water lines in the system that provide injection source water to remove particulates prior to starting injection.
 - Closely monitoring the quality of water being injected, and monitoring water levels in the well for changes in specific capacity.
 - Implementing a regular program of backflushing the well and pumping it to remove particulates introduced into the well during injection.
 - Periodically pulling the pump and aggressively redeveloping the well.
2. The long-term impact of injection and pumping of the deeper basalt aquifer zone on the shallow tuffaceous sediments beneath the valley floor north of the fault. The short-term aquifer testing showed that there is limited connection between the two aquifers and so there should be limited loss of stored water due to movement across the inferred fault boundary or due to capture by other pumping wells in the area. Monitoring of water levels in response to longer-term injection and pumping will be necessary to resolve this question.
3. It is predicted that the water level rise in the aquifer will eventually exceed the 1977 historic high water level in the basalt aquifer, potentially creating or enhancing seeps and springs. Monitoring the potential for surface discharges during pilot testing will be necessary.

Conclusions and Recommendations

On the basis of the technical analysis presented in this report, we do not see any fatal flaws for developing ASR at the Reservoir Well site and recommend proceeding with phase two of the project – ASR Pilot Testing at the Reservoir Well. The scope for Phase 2 consists of the following tasks. These activities are required by OWRD under the ASR rules.

- **Task 1 Permitting:** Obtain 5-year Limited License from OWRD
- **Task 2 ASR Design and Construction:** Design and construct well, pump station, and system modifications to accommodate ASR at the Reservoir Well site
- **Task 3 ASR Work Plan:** Prepare pilot testing work plan for submittal to OWRD
- **Task 4 ASR Pilot Testing:** Conduct injection, storage, and recovery testing and monitoring at Reservoir Well as required by OWRD

- *Task 5 ASR Analysis and Report: Assess sustainable injection and pumping rates, storage volume, water quality improvement and aquifer response to ASR*
- *Task 6 ASR Operations Plan: Develop operational parameters and O&M plan for City use*

A number of improvements and modifications will be required at the Reservoir Well site in order to retrofit the system for ASR. These improvements include the following:

- New booster pump at the 4.5 MG chlorine contact chamber and variable frequency drive (VFD) that allows adjustable rates of injection.
- New piping that conveys recharge water from the booster pump to the Reservoir Well.
- New recharge loop, piping, valves, and controls at the well head that permit injection down the pump column. Building modifications are required to accommodate the additional piping in the pump house.
- New pump to waste piping that permits discharge of wastewater from startup and back flushing.
- New liner casing in the well to 500 feet to protect the pump from falling rocks (there is presently only 20 feet of casing and open borehole to total depth).
- New pump, pump head, and pump column. The existing motor will be reused.
- New system controls and monitoring at the chlorine building that allow manual operation with automatic safety overrides.

The estimated cost for these improvements and associated engineering costs for permitting, system design, construction oversight, pilot testing, monitoring, and reporting are within the range presented previously. The total estimated cost for Phase 2 ranges from \$425,000 to \$458,000. A range of cost is presented because there are a number of elements that must be resolved during the design phase. Typical annual operation and maintenance costs during ASR pilot testing are approximately \$30,000 to \$40,000. These costs include the additional monitoring and laboratory testing fees required by OWRD for the Limited License. These estimates also assume that City staff will complete the majority of the data collection in the field and that they will maintain and operate the ASR system with limited technical support. It has been our experience that these costs can be reduced after the first year of successful full-scale operation, due to a reduction in monitoring, assuming OWRD approves. From past experience, the cost to pull the pump and redevelop the well every 2 to 3 years to remove sediment from the well that could not be removed by backflushing is approximately \$20,000.

The initial testing can last up to 5-years under the Limited License. After sufficient data regarding aquifer response, operational data, and lack of impacts are obtained to demonstrate ASR feasibility, the City would then apply for a full-scale ASR permit. It is possible that this could be accomplished after one or two years of operation. Assuming that the results of the pilot testing are favorable, the City will have a fully functional full-scale ASR system at the conclusion of Phase 2.

The next steps of the project will include the following:

- Meet with OWRD to discuss the project (pre-application meeting July 2003)
- Complete and file a Limited License application and ASR work plan (July 2003)
- Work closely with the City to prepare design drawings and specifications for the well and pump station improvements (summer 2003)
- Obtain ASR Limited License after 30-day comment period (September 2003)
- Assess the condition of the well using a down-hole camera and install a steel liner to protect the new pump (fall 2003 after summer pumping season)
- Construct well and pump station improvements (fall 2003)
- Begin pilot recharge testing (winter 2003/2004)
- Begin recovery of stored water (summer 2004)

1.0 Introduction

1.1 Purpose and Objectives

The City would like to develop an emergency water supply source and to increase its supply of water to meet peak water demands in the summer by storing surplus water derived from its watershed using Aquifer Storage and Recovery (ASR) technology. The City's goal is to develop an ASR system with at least 2.5 million gallons per day (MGD) recovery capacity that is sustainable for at least 45 days in the summer months. If the City is able to achieve this goal, it will realize a number of benefits including:

- Increasing the volume of water available to the City to meet peak summer water demands,
- Increasing the reliability of the backup/emergency source provided by the Reservoir Well in the event that there is a fire in the watershed,
- More effectively utilizing high quality water that would otherwise be spilled or diverted from the City's system when available supply from the watershed exceeds demand, and
- Improving the quality of the water produced by the Reservoir Well.

The City has excess high-quality water available from its unfiltered surface water sources and a limited amount of above ground reservoir storage. In the past, the City has had to spill water from its reservoir during the winter months or during other times of the year when water demands are low and there is an excess supply from the surface water sources. The City would like to be able to store this excess water and avoid having to spill it. In the fall and springtime, the source water can become unusable due to turbidity events that exceed drinking water standards. During these events, the City must rely on its backup water supply well to meet distribution demands. The City intends to evaluate the feasibility of ASR by utilizing its existing backup production well as an ASR test well. Because this well is a key part of the City's water system, any modification or testing that is done must ensure that the well is not out-of-service for an extended period of time and that no chemical reactions occur that could degrade the quality of produced water or the production capacity of the well.

Implementation of ASR at the Reservoir Well site is a cost effective alternative compared with developing additional production wells elsewhere because there are substantial costs involved in finding sites, obtaining the water rights, drilling the wells, and building the pump stations and infrastructure to deliver the water. Groundwater development without ASR may not be sustainable due to the limited amount of natural groundwater recharge in this region and native groundwater quality is generally less acceptable compared to surface water sources. ASR in contrast, stores high-quality surface water from the City's watershed in the aquifer and the quality of the recovered water is very similar.

1.2 Project Scope

Figure 1-1 is a map showing the project location. The project has been broken down into two phases: Phase 1 – ASR Feasibility Evaluation and Phase 2 – ASR Pilot Testing Program. The Phase 1 feasibility evaluation described in this report was designed to provide the City with key information needed to identify fatal flaws and to determine the feasibility of ASR at its backup well location. It also provides information required by OWRD as part of the ASR permitting process and it is intended that the report will be submitted to OWRD. The Phase 2 pilot-testing program is also a required element of the ASR permitting process and it is designed to demonstrate ASR feasibility and to provide the City with needed operational data. If the City decides to proceed with Phase 2, the Reservoir Well will be retrofitted to allow ASR operation and the first year of testing and monitoring will provide important information concerning water quality compatibility, aquifer response to recharge, optimal injection and recovery rates, back flushing frequency to remove suspended solids introduced into the well, and well performance data. The Phase 2 program will be conducted to test the well at full-scale operation so that it can provide significant emergency or peaking capacity during the first year of operation.

The Phase 1 feasibility study scope of work included the following tasks:

Task 1 – Preliminary Water Quality Compatibility – Reviewed available water quality data and conducted limited sampling and analysis to determine the likelihood for a fatal flaw to exist, prior to continuing with the project.

Task 2 – Hydrogeology Characterization – Constructed geologic cross sections through the project study area to further define the nature, extent, and character of the target aquifer and to assess how recharge water will move in the subsurface.

Task 3 – Aquifer Testing – Installed a water level access tube in the Reservoir Well, monitored water levels in several nearby wells, and conducted an aquifer test at the Reservoir Well to measure well performance and aquifer characteristics including transmissivity, storage coefficient, and boundary conditions. This information was used to estimate the target recharge rate, pumping rate, and the amount of water that can be stored.

Task 4 - Water Quality Compatibility Evaluation – Conducted detailed geochemical testing and geochemical modeling to predict the likelihood for reactions to occur that might clog the well or affect taste of the recovered water. Groundwater samples were also tested for all drinking water constituents as required by the ASR rules.

Task 5 – Water Availability Analysis – Reviewed City water supply and production data to confirm that an adequate quantity of water is available for recharge in the winter and early summer.

Task 6 – Recharge Analysis – Used aquifer parameter information estimated in Task 2 to predict target injection and pumping rates, target storage volume, and water level increase during injection and drawdown during pumping.

Task 7 – Conceptual ASR System Design, Operation, and Cost – Prepared a conceptual design for the booster pump and wellhead modifications required to permit ASR operation at the Reservoir Well. Described ASR operation sequence. Reviewed previously prepared ASR construction cost estimates.

Task 8 – Preliminary ASR Feasibility Report – Prepared a report documenting findings from the preceding tasks.

Findings from each of these tasks are presented in the following sections beginning with the hydrogeologic characterization.




Figure 1-1
Baker City ASR
Study Area

 **Groundwater Solutions Inc.**
 1118 SE Willamette Ave. Tillamook, Oregon 97142
 503.737.8777 • 503.737.8788 • groundwatersolutions.com

2.0 Hydrogeologic Characterization

The hydrogeologic setting, which includes the general geology, structure and hydrogeologic conditions of the City of Baker area is described in this section and is primarily based on work by the United States Geologic Survey (1976) and Brooks, McIntyre and Walker (1976). The physical setting of the area also is described in this section. Appendix A contains drillers logs for the deeper wells located in the study area.

2.1 Physical Setting

Baker City is located within the Baker Valley, which is a northwest trending valley. The elevation of the City ranges from approximately 3,400 to 3,600 feet mean sea level (msl), while the topographic highs surrounding the valley reach altitudes of around 8,900 feet msl. These highland areas supply the majority of recharge to streams and groundwater in the area from both rain and snow melt. Baker City receives on average 10.5 inches of rain per year and 27 inches of snow per year according to the National Weather Service.

2.2 Geology

The general geologic units in the Baker City region are presented in Figure 2-1 and are described from youngest to oldest below.

Alluvium - Qal

This unit consists of stream channel sands, gravels, silts, and decomposed basalt and it includes unconsolidated colluvium material (debris deposited at the base of slopes by gravity) and decomposed basalt. The decomposed basalt is commonly found near the base of hill slopes as part of the colluvium deposits. These deposits normally are less than 10 feet thick in the study area, however thicker sequences of colluvium material are present along the base of the hills.

Tuffaceous Sedimentary Rocks – Tst

This unit consists of poorly consolidated lacustrine (lake bed) and fluvial (stream) deposits. The lacustrine deposits contain tuffaceous clay, siltstones, and sandstones. The origin of the material is volcanic before it is re-worked in either a lacustrine or fluvial environment. Overall, these sediments were deposited in a low-energy environment and are up to 520 feet thick in the study area. The tuffaceous sediments also contain coarser-grained fluvial deposits consisting of gravels, pebble and cobble conglomerates, sandstones and siltstones. Locally, some thin basalt units can be found underlying the tuffaceous sedimentary layers. In general, coarse-grained tuffaceous sediments can yield sufficient quantities of water for municipal use (greater than several hundred gallons per minute). However, wells completed in the finer-grained tuffaceous sediments do not normally yield sufficient quantities of water for municipal use.

Basalt – Tb

This unit consists of a series of basalt flows. Individual basalt flows can vary greatly in thickness from several feet to greater than 100 feet thick. Groundwater in the basalt is predominantly derived from interflow zones, which represent the contact between individual basalt flows. These interflow zones are typically rubbly and porous, and thus can transmit water easily. Groundwater also is produced from fractured zones in the more massive interior flows, if sufficient structural deformation and/or fracturing has occurred. Tuffaceous sedimentary rocks are also found in the interflow zones.

Intrusive Igneous Complex – Trqd

This unit consists of intrusive igneous rocks ranging from peridotite to albite granite. The intrusive rocks in the region have been altered by regional metamorphism. Steeply dipping dikes that range from several inches to 10 feet in width are commonly found cross cutting the intrusive rocks. This unit is considered to have little groundwater development potential.

2.3 Geologic Structures

Geologic structures have an important influence on groundwater flow in the basalts as well as the basin tuffaceous sediments. Faults and folds influence groundwater flow by promoting or impeding both lateral and vertical groundwater flow. Baker Valley is structurally controlled by northwest-trending normal faults (see Figure 2-1). Geologic cross sections parallel and perpendicular to the structural fabric in the area are shown in Figures 2-2 and 2-3. The vertical scales of the cross sections were exaggerated to better display subsurface conditions. Overall faulting has down-dropped the basalts to the northeast, resulting in a graben structure. Tuffaceous sediments were deposited in the graben structure. In the Baker Valley the tuffaceous sediments (Tst) deposited in the graben are up to 520 feet thick.

The size of the faulted basalt block directly influences how much water can be withdrawn and/or stored (injected) in a particular basalt flow sequence. If a particular part of the aquifer is bounded by faults that limit its size, injection into this unit will cause water levels to rise high enough to create springs. The effects of the faults on the hydrogeology in the Baker area is not completely understood, however, aquifer test data did help to better understand its influence on the target test area – Reservoir Well. A more detailed discussion is presented in the aquifer test section of this report.


2.4 Hydrogeology

The principle aquifer in the area is hosted in the basalt unit and the majority of flow, as previously outlined, within the basalt is concentrated in interflow zones. Groundwater also is hosted in the tuffaceous sediments and alluvium units. The basalts can be highly productive if permeable interflows are encountered and/or if secondary fracturing has enhanced the basalts permeability. The potential yield of the tuffaceous sediments can vary depending on the amount of coarse-grained material encountered and also depends on the amount of cementation of the formation and its clay content.

The primary source of recharge to the aquifers is rainfall and snowmelt in the Elk Horn Range. The groundwater flow is typically to the northwest and matches the topography. The depth to groundwater in the basalts in the upland portion of the study area is around 3,560 feet msl, whereas the groundwater elevation in the valley (graben) is at 3,450 feet msl. A range fault along the base of the hill, as shown in Figure 2-1, most likely acts as a hydrogeologic barrier between the upland and valley hydrogeologic regimes, which would account for the head difference between the basalt and tuffaceous sediments. Overall, it is believed that the shallow groundwater flow path in the vicinity of the Reservoir Well is most likely supplemented by a deeper groundwater flow path, which discharges northwest to the Powder River.

Groundwater Development

An inventory of wells in the Baker City area was completed around the Reservoir Well to obtain hydraulic, as well as hydrogeologic information about local wells. The inventory was limited to wells greater than 200 feet in depth. Reported yields of wells in the inventory range from 5 to 2000 gallons per minute (gpm). Specific capacity in the area wells exhibited a wide range of values from 0.04 gpm/ft to 20 gpm/ft. Specific capacity is a ratio of a wells yield per foot of drawdown (gpm/ft). Specific capacity can be used to assess the relative performance of a well and the productivity of the aquifer. The wells with lower productivity and specific capacity could be the result of wells completed in the finer-grained tuffaceous sediments or they could represent wells completed in the basalts without significant interflow zones. The wells with higher yields in general are larger diameter and deeper, and most likely intercepted interflow zones.



Geology

	Qal - Alluvium- unconsolidated silt, sand, and gravel
	Qtg - Colluvium - unconsolidated gravel, cobbles, and boulders with intermixed clay,silt, and sand
	Tst - Tuffaceous sedimentary rocks - poorly consolidated, water laid silicic volcanic ash, clay, siltstone, and sandstone
	Tb - Basalt - composed of numerous seperate basalt flows

Legend

A ————— A'

Geologic Cross Section

0 1,000 2,000 Feet

= Well w/ ID

Note: Well ID is linked to Table 1

Normal Fault ball on downthrown side

Figure 2-1
Geologic Map
Baker City ASR



Groundwater Solutions Inc.
 1758 SE Milwaukie Ave. Portland, Oregon 97202
 ph:503 219.8799 fax:503 239.8940 w:groundwatersolutions.com

LEGEND

- Qal** Alluvium — unconsolidated silt, sand, and gravel
- Tst** Tuffaceous Sedimentary Rocks — poorly consolidated, water laid silicic volcanic ash, tuffaceous clay, siltstone and sandstone
- Tb** Basalt — composed of numerous separate basalt flows
- IF** Interflow Zone
-  Static Water Level and Date
-  Possible Normal Fault

- #1148**  Well number
-  Well
- TD=800'**  Total depth

0 1000'
7.5X Vertical Exaggeration
100'



Groundwater Solutions Inc.

FIGURE 2-2
Geologic Cross Section A-A'
BAKER CITY A.S.R.P. PROJECT


LEGEND

- Qal** Alluvium — unconsolidated silt, sand, and gravel
- Tst** Tuffaceous Sedimentary Rocks — poorly consolidated, water laid silicic volcanic ash, tuffaceous clay, siltstone and sandstone
- Tb** Basalt — composed of numerous separate basalt flows
- Trqd** Granite — Intrusive
- IF** Interflow Zone
-  Static Water Level and Date


 Possible Normal Fault

#1136 — Well number
 Well
 TD=575' — Total depth

0 1000'
 7.5X Vertical Exaggeration
 100'



LOOKING NORTHEAST



Groundwater Solutions Inc.

FIGURE 2-3
 Geologic Cross Section B-B'
 BAKER CITY AOR PROJECT

3.0 Aquifer Testing

Aquifer testing was performed at the Baker City Reservoir Well to measure aquifer parameters including transmissivity and storage coefficient. This information was later used in the ASR recharge and pumping analysis (see Section 6.0) to predict water level draw-up (mounding) during injection and drawdown during pumping under several ASR injections and pumping scenarios.

Aquifer testing consisted of a step-rate drawdown test and a 5-day constant rate aquifer test. The step drawdown test consisted of four 1-hour consecutive steps and the constant rate aquifer test consisted of pumping the Reservoir Well at a rate of 1500 gpm for approximately 120 hours. Water levels in the Reservoir Well were monitored during pumping and also for approximately 216 hours during recovery. Water levels in the Paul Hill well and Golf Course well also were measured during the pumping and recovery phase of the test. Appendix B contains manual water level data, water level plots, and a detailed description of the methods used to calculate aquifer parameters.

Water quality sampling and testing was also completed during the aquifer testing. A water quality compatibility evaluation related to the ASR feasibility analysis is included in Section 4.0.

Drawdown and recovery data were used to compute aquifer transmissivity and storage coefficient. Transmissivity is a measure of the productivity of an aquifer in terms of thickness and permeability of the aquifer matrix. The storage coefficient is a measure of how much water can be released from the aquifer given a unit decline in the hydraulic head. Specific capacity was also computed on the basis of the pumping test data. It is an index for how a given well performs and it is calculated by dividing the discharge rate by the drawdown (or drawup during injection). The specific capacity index takes into account both the productivity of the aquifer (transmissivity) and the efficiency of the well. Specific capacity, transmissivity, and aquifer boundary conditions are used to determine what injection and pumping rates can be sustained at an ASR well because they influence the drawdown and drawup in the well for a given storage or pumping volume. A more detailed discussion of how these aquifer and well parameters were used to calculate target injection rates, pumping rates, and storage volume is presented in Section 6.0.

Prior to initiating the tests, it was necessary to lift up the pump and install a water level access tube so that water levels could be measured in the well (the existing airline was not functional). This proved problematic because the lifting ears on the pump head broke off as the crane began to lift the pump and column. Inspection of the pump head indicated that the metal casting was probably defective. In order to avoid further damage to the pump head, a lifting plate was fabricated. The pump was then lifted and a PVC access tube was installed in the well to allow measurement of the water level. Because a crack was observed in the pump head, a second support was fabricated to take the weight off of the pump head after the pump was lowered back into place following the aquifer testing.

Deep wells within the study area that could be affected by ASR testing were identified. Wells located closest to the Reservoir Well that might serve as observation wells during the testing were identified utilizing OWRD well log data and local knowledge from City staff (see Table 3-1). City staff obtained permission from several well owners to allow monitoring of water levels prior to and during the tests. Water levels were monitored for several weeks prior to the start of the aquifer tests by City staff at the Golf Course well, Paul Hill well, Reservoir Well, and Ellingson well (see Figure 2-1). Due to access limitations, consistent measurements could not be obtained at the Ellingson well and only limited data were obtained from the Golf Course well. A pressure transducer and data logger were installed at the Reservoir Well and Paul Hill well to allow automated water level monitoring (these are the only wells that had sufficient room for the transducer). A summary of the aquifer tests is presented below and Appendix B provides a more detailed description of the tests.

3.1 Step-Rate Test

In order to determine the performance of the Reservoir Well, a step-drawdown test was completed. This testing provides a baseline from which to compare future changes to well performance resulting from ASR. A step-drawdown test is conducted by pumping a well at successively higher pumping rate over an equal interval of time. For this test the Reservoir Well was pumped at 500, 1,000, 1,500, and 2,000 gallons per minute for one-hour intervals. The step test data was used to pick a pumping rate for the constant rate test and to assess head losses in the well due to laminar flow. Based on step test data, the Reservoir Well's laminar flow losses as a percentage of total head losses are approximately 59 percent. This indicates the well has moderate efficiency, which is typical of most open-hole basalt wells. On the basis of the step-test results, a constant rate of 1,500 gpm was chosen for the constant rate test.

3.2 Constant Rate Test

A constant rate test was also conducted for a period of 5 days at the Reservoir Well to determine the following:

- Calculate transmissivity of the aquifer.
- Determine the specific capacity of the well and project the specific capacity over long-term pumping.
- Identify possible boundaries to the aquifer that might limit the ASR storage volume.
- Measure the potential response in the valley fill sediments due to pumping in the basalt aquifer. This was accomplished by measuring water levels at the Paul Hill well during the constant rate test. This well is located on the opposite side of the basin fault from the Reservoir Well.

The initial pre-test static water level in the well was approximately 250 feet below ground surface (it was originally 177 feet below ground surface when the well was drilled 25 years ago). The constant rate test was conducted over a 5-day period from January 24th to January 30th, 2003. The well was pumped at a rate of 1,500 gpm and drawdown was

measured in the Reservoir Well and the Paul Hill well. The maximum drawdown after 7,200 minutes (120 hours or 5 days) was approximately 90 feet. A response was not observed in the Paul Hill well during the constant rate test. Recovery data also was collected after the pump was turned off. A summary of the aquifer test data interpretation is presented below.

3.3 Aquifer Parameter Estimation

Graphs of the aquifer test data are presented in Appendix B. A transmissivity of 2,800 gallons per day per foot (gpd/ft) was calculated using drawdown data. A transmissivity value of 7,300 gpd/ft was calculated using recovery data. The transmissivity estimate from the recovery phase of the test is considered to be more representative because it is less affected by fluctuations in pumping rate. The 5-day specific capacity of the well was approximately 16.5 gpm/ft. The storage coefficient was not calculated from test data since it requires a response in an observation well; no response in the Paul Hill observation well was measured during the constant rate test. Since the aquifer test results indicate the aquifer is confined or semiconfined, a storativity estimate for the basalt at the Reservoir Well site would normally range from 1×10^{-5} to 1×10^{-3} .

The moderate transmissivity and low storativity values commonly found in basalts indicate that the formation will readily yield water to wells but the drawdown (and drawup) effects will be large and transmitted over long distances (miles). Low storativity values also mean that the basalt aquifer is vulnerable to overpumping, which can result in significant water level declines. It should be noted that ASR is particularly beneficial in this setting because it augments the naturally low rate of groundwater recharge and reduces the impacts from pumping. Because the water level in the well did not recover fully following the pumping phase, some amount of groundwater was apparently removed from storage. This indicates that recharge to the aquifer is probably limited, which is consistent with the observation that water levels have declined on the order of 70 feet since the well was drilled.

The drawdown and the recovery curves for the constant rate test do not suggest that a no-flow hydraulic boundary was intercepted during the 5-day constant rate test. Instead of a sharp rate of change in the drawdown curve, which is indicative of a no-flow boundary, the drawdown curve for the Reservoir Well shows a steady decline (see Figure B-5, Appendix B). This same type of response has been observed in pump test data collected from other basalt-hosted wells (e.g., Beaverton ASR No. 1). This is not to say that the cone of depression (or cone of head rise during injection) after more than 5-days of pumping would not encounter a no-flow boundary. However, the greatest impact on drawdown and drawup is directly related to boundaries intercepted early by the cone of depression (or cone of head rise). The cone of depression (and cone of rise) propagates less and less over time assuming a constant rate of pumping (injection).

The drawdown curve does shed some light however on the hydrogeologic regime in the Reservoir Well area. In general, the juxtaposition of the basalts and the tuffaceous sediments caused by faulting appears to have some implications on the hydrogeologic framework of the area. Constant rate pump test data from the Reservoir Well shows a

diminishing transmissivity and specific capacity with time as the cone of depression expands. The data does not suggest that the fault contact between the basalt and the tuffaceous sediments acts as a no-flow boundary but behaves more like a leaky boundary. This suggests that there is some connection between the water bearing units in the basalt and the tuffaceous sediments present in the valley. However, no response was observed in the Paul Hill well and so the degree of connection is muted due to the leaky boundary. It is believed that the cone of depression during the constant rate test most likely propagated parallel to the hill and took on an elliptical shape, and as it extended, it most likely encountered less and less transmissive interflow zones. This observation highlights some of the heterogeneity of the basalt system around the Reservoir Well.

**Table 3-1
Well Data for Wells Located within 1/2 mile of the Baker City Reservoir Well**

Well ID	Township	Range	Section	Address	Owner	Date Drilled	Depth Drilled (feet)	Casing or Borehole diameter (inches)	Screen Interval	SWL (feet bgs)	Date of SWL	Capacity gpm	DD (feet)	Specific Capacity gpm/ft	Use	Misc. Info
1148	19	9S	40E	Reservoir Well	Baker City	Jul-77	800	16	NA	177	Jul-77	1500			Municipal	Baker City Well No. 1
1136	18	9S	40E		Paul V. Hill	Apr-55	575	12	NA	29	May-77	1100	166	6.6	Irrigation	
1163	20	9S	40E		Ellingson Timber Co.	Nov-65	650	10	122'-157', 272'-287', 538'-618'	8	Nov-65	2000	100	20.0	Irrigation	
1145	19	9S	40E		Dave Erwin (Briggs)	Jun-79	520	6	NA	287	Jun-79	200	153	1.3	Test Well	
2197	19	9S	40E	900 Story Ln	Mike Voboril	Sep-95	498	8/liner 6"	435'-495'	190	Sep-95				Domestic	
1935	19	9S	40E	6770 Greenridge	Alpine Timber Corp.	Oct-92	465	8/Liner 7"	410'-450'	300	Oct-92				Domestic	No water found
1780	19	9S	40E	3975 Indiana St.	Robert P. Ellingson	Jul-89	362	6	NA	240	Jul-89	50	122	0.4	Irrigation	
1153	20	9S	40E		Baker Municipal Golf Course	Sep-77	349	8	NA	85	Sep-77	320	141	2.3	Municipal/Irrigation	
2022	9	9S	40E	1205 17th St.	Steve Bogart	Apr-94	330	6	290'-330'	50	Apr-94	25	280	0.1	Domestic	Well in Sand and Clay
1140	19	9S	40E	1241 4th St.	Park Taylor	Mar-72	305	6" to 197' 5.75" to TD	100'-122' perf 198'-TD open	10	Feb-72	4.5	120	0.0	Domestic	
1142	19	9S	40E	2350 C St.	Serita Rasmussen	Sep-81	345	6/Liner 4"	NA	290	Sep-81				Domestic	

SWL = static water level
bgs = below ground surface

Refer to Figure _ for well locations.



Groundwater Solutions Inc.

4.0 Water Quality Compatibility

This section presents a discussion of water quality compatibility between the native basalt groundwater and recharge source water for the project. This analysis was performed to assess the potential for adverse chemical reactions that could occur as a result of mixing City of Baker potable drinking water with native groundwater in the aquifer. Adverse reactions that could occur include precipitation of minerals (e.g., iron or manganese hydroxides) that could clog the aquifer or well, and dissolution of minerals in the aquifer that could mobilize metals or affect taste and odor. The analysis was conducted utilizing results of sampling the Reservoir Well and the City of Baker water system at the clear well.

Samples collected from the Reservoir Well and clear well (referred to here as the mountain line source) were tested for geochemical parameters relating to water quality compatibility and potability. In addition, the sample from the Reservoir Well was tested for the full suite of regulated and unregulated drinking water parameters as outlined in the ASR rules. Analytical testing conducted on the well sample included:

- Field parameters, including pH, electrical conductivity (EC), and temperature
- Disinfection by-products
- Total and Fecal Coliform
- Geochemical constituents (anions and cations)
- Metals
- Miscellaneous constituents – e.g., color, odor, etc.
- Radionuclides – Gross Alpha and Gross Beta
- Synthetic Organic Compounds
- Volatile Organic Compounds

Results from the testing are presented in Table 4-1. Because chemical testing for metals and organic compounds was not performed on the mountain line sample, the table includes historical data for certain parameters collected at the clear well in the past. Laboratory analytical data sheets for samples collected for this project are presented in Appendix C. The following sections present a discussion of native groundwater quality, recharge water quality, and the results of a mixing analysis utilizing the geochemical model PHREEQC.

4.1 Native Groundwater Quality

General Chemistry

In general, the native groundwater quality is good with a moderate amount of dissolved minerals (184 mg/L total dissolved solids [TDS]). The water is considered hard (154 mg/L) relative to what most people consider hard (greater than 50 mg/L). The water has

a slightly alkaline pH (8.01), and is relatively low temperature (14.7 °C). The water had no color and is also considered to be non-corrosive (corrosivity = 0.23).

Figures 4-1 and 4-2 are Stiff and Piper diagrams that illustrate the chemical signature of the groundwater compared with the Baker City mountain line water. These diagrams are commonly used to graphically illustrate the dominant cations and anions dissolved in the water and to aid in comparing two water samples. The groundwater is a calcium-magnesium-bicarbonate type water. As can be seen from the shape and size of the polygon on the Stiff diagram, the native groundwater is significantly more mineralized than the recharge source water and has a different chemical signature based on the relative proportions of dissolved cations and anions. This difference in chemical signature will be important during future ASR pilot testing as we track the recovery of the stored water. As discussed later in this section, we expect the recovered ASR water to be more like the recharge source water and so ASR will actually improve the water quality near the ASR well by reducing the concentration of dissolved ions.

The groundwater has a total organic carbon content (6.7 mg/l), which suggests this water will have a low potential to promote the formation of disinfection by-products when chlorinated water is injected into the aquifer or when it is recovered and then rechlorinated.

Iron and manganese is often elevated in basalt/volcanic groundwater; however, the iron concentration measured at the Reservoir Well was less than 0.1 mg/L (the detection limit). The manganese concentration was above the secondary drinking water standard (0.05 mg/L) at a concentration of 0.09 mg/L. Manganese does not pose a risk to human health; it is an aesthetic standard that can affect taste and can discolor laundry and bathroom fixtures.

Figure 4-3 presents a plot of several water quality parameters measured at the well during a 30-day pumping period in 1999. The plot shows that water quality changed at different times during the period but that there was not a significant increase in concentration of any of the parameters, including iron and manganese, as pumping continued. These results are inconsistent with past observations whereby the City reports that the water quality produced by the well tends to degrade and produces a light brown floc in the chlorine contact chamber after extended periods of continuous pumping (within about 10 days). This is not uncommon in aquifers that experience substantial drawdown caused by pumping and where zones that contain poor quality groundwater contribute an increasing percentage of the total production from the well. The reasons for this apparent discrepancy are not understood and this emphasizes the importance of doing water quality monitoring during a later full-scale field-testing phase.

No direct measurement of dissolved oxygen or oxidation/reduction potential was made in the field at the wellhead. However, we expect the native groundwater to be somewhat deficient in oxygen and in a reduced state given that layers of volcanic rock and clay confine the groundwater system.

Regulated Constituents

Parameters that have regulatory standards (e.g., metals, nitrate, volatile organic compounds, pesticides) and are indicative of contamination were either not detected or were detected at levels below the applicable regulatory criteria. Unregulated organic parameters and Total and Fecal Coliform also were not detected in the native groundwater sample.

Mineral Stability

A geochemical model (PHREEQC) was used to assess the equilibrium state of the native groundwater with respect to common minerals associated with basalt/volcanic aquifers. The analysis is used to determine whether the water is undersaturated, supersaturated, or at equilibrium with a particular mineral in solution. Undersaturated means that there is a tendency for this water to dissolve minerals present in the subsurface. Supersaturated means that the water has a tendency to precipitate the mineral. Equilibrium means that the water does not have a tendency to either dissolve or precipitate a mineral. Understanding the equilibrium state of the water helps us to understand what will occur when recharge water and native groundwater are mixed.

Based on the geochemical modeling, native groundwater at the Reservoir Well is undersaturated with respect to calcite (calcium carbonate) and dolomite (calcium magnesium carbonate). Iron oxyhydroxide is not a concern in the groundwater due to the absence of iron in the water. The groundwater is undersaturated with respect to manganese-containing minerals (e.g., tendency to dissolve rather than precipitate), which explains why there is somewhat elevated dissolved manganese in the groundwater. The very low level of dissolved aluminum in the groundwater indicates that clay minerals in the aquifer (including kaolinite, montmorillonite, illite) are insoluble and will tend to stay in solid form.

4.2 Recharge Source Water Quality

General Chemistry

The water sample collected from the clear well (mountain line source) has excellent quality with a low dissolved mineral content (TDS) of 42 mg/L that is typical of a surface water origin. The water is a calcium-magnesium bicarbonate type water. The water is considered slightly hard (51 mg/L) relative to what most people consider hard (greater than 50 mg/L). The water has a slightly alkaline pH (7.4) and has an alkalinity of 24.6 mg/L.

Metals and organic compounds that have regulatory standards (e.g., MCLs) have either been not detected in previous sampling episodes or were detected at levels below the applicable regulatory criteria. Total iron and dissolved iron were not detected in the source water.

The concentration of total organic carbon is also considered low (0.98 mg/L) and so the formation potential for disinfection by-products is expected to be low.

Suspended Sediment

Suspended solids or turbidity present in recharge source water can be a significant concern because it can clog the ASR well and reduce its efficiency and pumping/injection capacity. The City has a long history of carefully tracking turbidity in the mountain line source. During periods of elevated turbidity, typically during the spring snowmelt period, the City may shut down the mountain line source and operate its well. Figure 4-4 presents a plot of clear well turbidity versus time and Reservoir Well pumping data for 2001. As can be seen from the 2001 data plot, elevated turbidity has been observed in both the late fall and during the spring and summer. In order to minimize the chance for turbidity events to impact the City's water system, the City has since been shutting down flow to the mountain line from lower elevation drainages when turbidity begins to increase. This practice has significantly decreased the frequency of turbidity events reaching the clear well.

The turbidity of the ASR source water should be less than 1.0 NTU, and preferably less than 0.5 NTU. Because the watershed is subject to unpredictable turbidity events that can occur if the weather becomes suddenly warmer, the City monitors incoming mountain line turbidity on a continuous basis. An alarm sounds if the turbidity exceeds 1 NTU. Because the ASR source water will be drawn from the 4 mg reservoir, there will be adequate time to shut down ASR injection before the turbidity in the reservoir reaches 1 NTU.

Even very good quality recharge water will gradually clog an ASR well. With proper monitoring of the source water and well performance and proper design of the system, impacts from clogging can be effectively managed. The well can be back flushed (pumped to waste) on a periodic basis to remove sediment from the well. In order to maximize the removal of fines that have accumulated in the well, we recommend that the target injection rate be 60 to 70 percent of the pumping rate. The optimal back flushing frequency can be established during the pilot-testing phase of the project.

Mineral Stability

The geochemical modeling results show that the mountain line source water is undersaturated with respect to most mineral assemblages; meaning that it is not at equilibrium and it has a tendency to dissolve minerals like calcite, dolomite or quartz minerals, if these minerals are present in the aquifer. Because iron and manganese were not detected in the mountain line source water, there is little or no iron or manganese mineral (hydroxides) to be concerned with.

4.3 Mixing Analysis

An analysis of water quality compatibility was performed for the ASR source water (Baker City water derived from the mountain line) and native groundwater (represented by the Reservoir Well). The purpose of this assessment was to determine if chemical reactions could occur as a result of mixing the recharge water with the native groundwater that might adversely affect ASR well performance, flow properties of the basalt aquifer, or recovered water quality. The evaluation was conducted by interpreting Stiff (Figure 4-1) and Piper (Figure 4-2) geochemical diagrams and by performing an

analysis of the equilibrium status of a theoretical mixture of the source water and native groundwater using the PHREEQC geochemical model. The modeling was performed to predict possible geochemical effects, such as mineral precipitation or dissolution, that might occur when the recharge water and native groundwater are mixed. The modeling was performed using a theoretical 50:50 mixture of native groundwater and ASR source water. This is the worst-case mixing relationship that could produce adverse chemical reactions. Due to a lack of Eh (oxidation-reduction potential) data for these samples, values were assumed for the mixing analysis. To be conservative, we assumed that the recharge source water (mountain line water) was highly oxidized (especially after chlorination) and that the native groundwater was reduced. This is commonly the case and represents a worst-case scenario for assessing whether or not iron or manganese containing minerals are likely to precipitate and clog the well when the two waters are mixed in the aquifer.

As the recharge water is introduced into the ASR well, some native groundwater will be displaced and some will mix with the recharge water. The TDS immediately adjacent to the ASR well will be approximately the same value as the recharge water. Near the outer limits of the recharge water bubble, the water quality will gradually become a mixture between recharge water and native groundwater. The pH in the mixed zone is predicted to remain alkaline (pH = 8). Outside the mixed zone further away from the ASR well, the water quality will be identical to native groundwater. Because most of the recharge water will be withdrawn soon after it is injected every year, there will be no long-term change in water quality within the aquifer. If for some reason the native groundwater quality becomes unacceptable, the City would likely store more water than it would pump so that the recovered water more closely resembles the mountain line water quality.

Geochemical Modeling Results

Based on the available water chemistry data and geochemical modeling results (using PHREEQC), the recharge source water and receiving native groundwater appear to be chemically compatible and do not appear to present any fatal flaws for ASR. When the relatively oxidized recharge water mixes with non-oxidized (reduced) native groundwater in the aquifer near the ASR well, precipitation of calcite and dolomite that could clog the well is not predicted to occur. In fact, the geochemical modeling results indicate that these mineral assemblages are at equilibrium and do not have a tendency to either dissolve or precipitate. We anticipate that the recovered water chemistry will resemble the recharge water chemistry with each subsequent ASR cycle (injection, storage and recovery), particularly if additional recharge water is left in the aquifer from year to year.

Manganese in the mixed water is undersaturated with respect to manganese minerals and therefore is more likely to dissolve than to precipitate. Manganese dissolution and precipitation rates are very slow in natural systems and we are uncertain how much and in what form the manganese minerals are in. While not considered a fatal flaw to ASR implementation, manganese concentrations should be monitored closely during the pilot study phase to confirm these findings and to assess whether manganese concentrations increase above present levels and cause taste or staining problems. This will be particularly important in this case given the water quality degradation that has been

observed in the past when the well is pumped for an extended period of time.

Because iron and manganese precipitation and dissolution reactions are pH dependent, iron and manganese equilibrium, and hence the resultant concentration of dissolved iron and manganese in recovered water can often times be managed through pH adjustment (adding caustic to keep the pH elevated) at the ASR wellhead.

Well performance during injection should be monitored to determine if turbidity is beginning to clog pore openings near the well. If this is observed, the well can be periodically back flushed to remove the material. Aggressive redevelopment (pull the pump and physically and chemically treat the well) may also be needed periodically. For budgeting purposes, the City should plan to do this aggressive redevelopment every 2 - 3 years until pilot testing results indicate otherwise. If iron precipitation or manganese dissolution is found to be a problem during the pilot phase, consideration should be given to storing more water than is recovered each year so that the mixing zone where this reaction is most likely to occur is kept away from the ASR well. This should improve the quality of the recovered water over a longer time period and substantially reduce losses in well efficiency that might be caused by precipitation reactions.

If more than approximately 80 to 90 percent of the stored water is recovered, there will likely be a noticeable change in hardness and taste (probably related to dissolved manganese in the groundwater) at locations closest to the ASR well source. This change is very gradual but may be noticed by industries relying on a constant water quality or by residents who notice water spots on windows. This condition will not be any worse than what the City already experiences when it runs the well during turbidity events. Leaving more stored water in the aquifer can minimize these effects. From past experience, we have found that operation of the ASR system over many recharge cycles will improve the quality of the water produced by the well.

Disinfection By-Products

Chlorine and disinfection by-products will be introduced into the aquifer because the City water supply is disinfected. Residual chlorine concentrations will dissipate quickly (hours) as the recharge water comes into contact with the aquifer matrix. Disinfection by-products (DBPs) are produced as a result of chemical reactions between organic carbon present in the surface water or groundwater and chlorine. Disinfection by-products include haloacetic acids (HAAs) and trihalomethanes (THMs). Because the TOC of the native groundwater is low there is a lower potential for DBP formation after the chlorinated recharge water is introduced into the aquifer. It is anticipated that HAA concentrations will dissipate quickly in the aquifer (within days of storage) as a result of aerobic microbial degradation. THM concentrations may increase slightly after injection as a result of the reaction between the TOC present in the recharge water and chlorine; however, THM concentrations should decrease with time (within weeks of storage) due to anaerobic microbial activity. Dilution caused by mixing between recharge water and native groundwater is also expected to reduce DBP concentrations.

Table 4-1
Summary of Native Groundwater and ASR Source Water Quality Testing
Baker City ASR Evaluation

	Analyte	Lowest Regulatory Standard	Units	Regulatory Criteria	MDL	Native Groundwater Reservoir Well	Source Water Old Mountain Line
						Date	
						29-Jan-03	29-Jan-03 & 14-Oct-02
Bacteriological	Fecal Coliforms/E.Coli					<1	NT
	Total Coliform	<1/100 ML	CFU/100 ml	MML		<1	NT
Disinfection By-Products							
THM	Chloroform (Trichloromethane)	None	mg/L	URC	0.0005	ND	NT
THM	Bromodichloromethane	None	mg/L	None	0.0005	ND	NT
THM	Chlorodibromomethane	None	mg/L	None	0.0005	ND	NT
THM	Bromoform (Tribromomethane)	None	mg/L	URC	0.0005	ND	NT
	Total Trihalomethanes	0.08	mg/L	MCL		ND	NT
HAA	Dibromoacetic Acid	None	mg/L	None	0.001	ND	NT
HAA	Dichloroacetic Acid	None	mg/L	None	0.001	ND	NT
HAA	Monobromoacetic Acid	None	mg/L	None	0.001	ND	NT
HAA	Monochloroacetic Acid	None	mg/L	None	0.002	ND	NT
HAA	Trichloroacetic Acid	None	mg/L	None	0.001	ND	NT
	Total Haloacetic Acids	0.06	mg/L	MCL		ND	NT
Field Parameters							
	Temperature	None	Celsius	None	NA	14.7	7*
	Conductivity	None	mS/cm	None	NA	315	NT
	Dissolved Oxygen	None	mg/L	None	NA	NT	NT
	pH	6 - 8.5	Units	SMCL	NA	8.01	7.4*
	Turbidity	1 NTU	mg/L	MCL, MML	NA	NT	NT
	ORP	None	mV	None	NA	NT	NT
Geochemical							
	Bicarbonate	None	mg/L	None	2	92	246*
	Calcium	None	mg/L	None	0.1	30.9	8.95*
	Carbonate	None	mg/L	None	2	<1	<1*
	Chloride	250	mg/L	SMCL	1	Ø	3*
	Hardness (as CaCO3)	250	mg/L	SMCL	4	154	51*
	Magnesium	None	mg/L	None	0.05	16.3	2.18*
	Nitrate as N	10	mg/L	MML	0.05	<0.05	<0.05*
	Nitrite as N	1	mg/L	MCL	0.002	<0.002	<0.002*
	Potassium	None	mg/L	None	0.1	1.8	ND*
	Silica	None	mg/L	None	0.2	38.1	11.1*
	Sodium	20	mg/L	URC, SMCL	0.05	19	2.1*
	Sulfate	250	mg/L	URC, SMCL	5	39	ND*
	Total Alkalinity	250	mg/L	SMCL	2	92	246*
	Total Dissolved Solid	500	mg/L	SMCL	0.7	184	42*
	Total Organic Carbon	None	mg/L	None	0.5	6.7	0.98*
	Total Suspended Solids	None	mg/L	None	2	<1	2*
Metals							
	Aluminum	0.05	mg/L	SMCL	0.05	0.0071	0.0489*
	Antimony	0.006	mg/L	MCL	0.001	ND	ND*
	Arsenic	0.05	mg/L	MCL, MML	0.002	0.006	ND*
	Barium	1	mg/L	MCL, MML	0.05	ND	ND*
	Beryllium	0.004	mg/L	MCL	0.0005	ND	ND*
	Cadmium	0.005	mg/L	MCL, MML	0.001	ND	ND*
	Chromium	0.05	mg/L	MCL, MML	0.002	ND	ND*
	Copper	1.3	mg/L	MCL	0.005	ND	0.02*
	Iron (Total)	None	mg/L	None	0.05	<0.1	ND*
	Iron (Dissolved)	0.3	mg/L	SMCL	0.05	<0.1	ND*
	Lead	0.015	mg/L	MCL, MML	0.001	0.005	ND*
	Manganese (Total)	None	mg/L	None	0.02	0.12	ND*
	Manganese (Dissolved)	0.05	mg/L	SMCL	0.002	0.09	ND*
	Mercury	0.002	mg/L	MCL, MML	0.0004	ND	ND*
	Nickel	0.1	mg/L	MCL	0.004	ND	ND*
	Selenium	0.01	mg/L	MCL, MML	0.002	ND	ND*
	Silver	0.05	mg/L	MML, SMCL	0.005	ND	ND*
	Thallium	0.002	mg/L	MCL	0.0006	ND	ND*
	Zinc	5	mg/L	SMCL	0.01	ND	ND*
Miscellaneous							
	Odor	3	TON	SMCL	1 ton	ND	NT
	Color	15	ACU	SMCL	5 color units	ND	NT
	Methylene Blue Active Substance	0.5	mg/L	SMCL	0.05	NT	NT
	Corrosivity (Langelier Saturation Index)	Non-Corrosive	mg/L	SMCL	--	0.23	NT
	Fluoride	2	mg/L	MCL, MML, SMCL	0.5	0.3	NT
Radionuclides							
	Gross Alpha	15	pCi/L	MML	1	1.1	NT
	Gross Beta	50	pCi/L	MML	1.9	12.2	NT
	Radon	300	pCi/L	MML	Ø0.7	436	NT
Synthetic Organic Compounds (SOCs)							
Regulated SOCs							
	2,4,5-TP (Silvex)	0.01	mg/L	MCL, MML	0.0004	ND	ND**
	2,4-D	0.07	mg/L	MCL, MML	0.0002	ND	ND**
	Alachlor (Lasso)	0.002	mg/L	MCL, MML	0.0004	ND	ND**
	Atrazine	0.003	mg/L	MCL, MML	0.0002	ND	ND**
	Benzo(a)Pyrene	0.0002	mg/L	MCL	0.00004	ND	ND**
	BHC-gamma (Lindane)	0.0002	mg/L	MCL, MML	0.00002	ND	ND**
	Bis(2-ethylhexyl)adipate	0.4	mg/L	MCL	0.001	ND	ND**
	Bis(2-ethylhexyl)phthalate	0.006	mg/L	MCL, MML	0.001	ND	ND**
	Carbuturan	0.04	mg/L	MCL	0.001	ND	ND**
	Chlordane	0.002	mg/L	MCL	0.0004	ND	ND**
	Dalapon	0.2	mg/L	MCL	0.002	ND	ND**
	Dibromochloropropane (DBCP)	0.0002	mg/L	MCL	0.00002	ND	ND**
	Dinoseb	0.007	mg/L	MCL	0.0004	ND	ND**
	Diquat	0.02	mg/L	MCL	0.0004	ND	ND**
	Ethylene Dibromide (EDB)	0.00005	mg/L	MCL, MML	0.00001	ND	ND**
	Endothall	0.1	mg/L	MCL	0.01	ND	ND**
	Endrin	0.0002	mg/L	MCL, MML	0.00002	ND	ND**
	Glyphosate	0.7	mg/L	MCL, MML	0.01	ND	ND**
	Heptachlor	0.0004	mg/L	MCL, MML	0.00004	ND	ND**
	Heptachlor Epoxide	0.0002	mg/L	MCL, MML	0.00002	ND	ND**
	Hexachlorobenzene	0.001	mg/L	MCL, MML	0.0001	ND	ND**
	Hexachlorocyclopentadiene	0.05	mg/L	MCL, MML	0.0002	ND	ND**
	Methoxychlor	0.04	mg/L	MCL, MML	0.0002	ND	ND**
	Polychlorinated Biphenyls (PCBs)	0.0005	mg/L	MCL, MML	0.0002	ND	ND**
	Pentachlorophenol	0.001	mg/L	MCL, MML	0.00008	ND	ND**
	Picloram	0.5	mg/L	MCL, MML	0.0002	ND	ND**
	Simazine	0.004	mg/L	MCL, MML	0.0001	ND	ND**
	Toxaphene	0.003	mg/L	MCL, MML	0.001	ND	ND**
	Vydate (Oxamyl)	0.2	mg/L	MCL	0.002	ND	ND**
Unregulated SOCs							
	3-Hydroxycarbofuran	None	mg/L	None	0.004	ND	ND**
	Aldicarb	None	mg/L	None	0.002	ND	ND**
	Aldicarb Sulfone	None	mg/L	None	0.001	ND	ND**
	Aldicarb Sulfoxide	None	mg/L	None	0.003	ND	ND**

	Analyte	Lowest Regulatory Standard	Units	Regulatory Criteria	MDL	Native Groundwater Reservoir Well		Source Water
						29-Jan-03	14-Oct-02	Old Mountain Line
						Date	29-Jan-03	29-Jan-03 & 14-Oct-02
	Aldrin	None	mg/L	None	0.0001		ND	ND**
	BenzyI Butylphthalate	None	mg/L	None	0.001		ND	NT
	Butachlor	None	mg/L	None	0.001		ND	ND**
	Carbaryl	None	mg/L	None	0.004		ND	ND**
	Di-n-Butylphthalate	None	mg/L	None	0.001		ND	NT
	Dicamba	None	mg/L	None	0.0005		ND	ND**
	Dieldrin	None	mg/L	None	0.00001		ND	ND**
	Diethylphthalate	None	mg/L	None	0.001		ND	NT
	Dimethylphthalate	None	mg/L	None	0.001		ND	NT
	Di-n-octylphthalate	None	mg/L	None	0.001		ND	NT
	Methomyl	None	mg/L	None	0.004		ND	ND**
	Metolachlor	None	mg/L	None	0.002		ND	ND**
	Metribuzin	None	mg/L	None	0.001		ND	ND**
	Propachlor	None	mg/L	None	0.001		ND	ND**
Volatile Organic Compounds (VOCs)								
Regulated VOCs								
	1,1,1-Trichloroethane	0.2	mg/L	MCL, MML	0.0005		ND	ND**
	1,1,2-Trichloroethane	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	1,1-Dichloroethylene	0.007	mg/L	MCL, MML	0.0005		ND	ND**
	1,2,4-Trichlorobenzene	0.07	mg/L	MCL, MML	0.0005		ND	ND**
	1,2-Dichlorobenzene	0.6	mg/L	MCL, MML	0.0005		ND	ND**
	1,2-Dichloroethane (EDC)	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	1,2-Dichloropropane	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	1,4-Dichlorobenzene	0.075	mg/L	MCL, MML	0.0005		ND	ND**
	Benzene	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	Carbon Tetrachloride	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	Chlorobenzene	0.1	mg/L	MCL, MML	0.0005		ND	ND**
	cis-1,2-Dichloroethylene	0.07	mg/L	MCL, MML	0.0005		ND	ND**
	Ethylbenzene	0.7	mg/L	MCL, MML	0.0005		ND	ND**
	Dichloromethane (methylene chloride)	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	Styrene	0.1	mg/L	MCL, MML	0.0005		ND	ND**
	Tetrachloroethylene	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	Toluene	1	mg/L	MCL, MML	0.0005		ND	ND**
	trans-1,2-Dichloroethylene	0.1	mg/L	MCL, MML	0.0005		ND	ND**
	Trichloroethylene	0.005	mg/L	MCL, MML	0.0005		ND	ND**
	Vinyl chloride	0.002	mg/L	MCL, MML	0.0005		ND	ND**
	Total Xylenes	10	mg/L	MCL, MML	0.0005		ND	ND**
Unregulated VOCs								
	1,1,1,2-Tetrachloroethane	None	mg/L	None	0.0005		ND	ND**
	1,1,2,2-Tetrachloroethane	None	mg/L	None	0.0005		ND	ND**
	1,1-Dichloroethane	None	mg/L	None	0.0005		ND	ND**
	1,1-Dichloropropene	None	mg/L	None	0.0005		ND	ND**
	1,2,3-Trichloropropane	None	mg/L	None	0.0005		ND	ND**
	1,2,4-Trimethylbenzene	None	mg/L	None	0.0005		ND	NT
	1,3-Dichloropropane	None	mg/L	None	0.0005		ND	ND**
	2,2-Dichloropropane	None	mg/L	None	0.0005		ND	ND**
	Bromobenzene	None	mg/L	None	0.0005		ND	ND**
	Bromodichloromethane	None	mg/L	None	0.0005		ND	ND**
	Bromoform	None	mg/L	None	0.0005		ND	ND**
	Bromomethane	None	mg/L	None	0.0005		ND	ND**
	Chloroethane	None	mg/L	None	0.0005		ND	ND**
	Chloroform	None	mg/L	None	0.0005		ND	ND**
	Dibromochloromethane	None	mg/L	None	0.0005		ND	ND**
	Dibromomethane	None	mg/L	None	0.0005		ND	ND**
	o-Chlorotoluene	None	mg/L	None	0.0005		ND	ND**
	p-Chlorotoluene	None	mg/L	None	0.0005		ND	ND**

NOTE
mg/L = milligram per liter
MDL = Method Detection Limit
ND = Not detected at concentrations greater than the MDL
NT = Analyte not tested
MCL = Federal maximum contaminant level for drinking water
MML = DEQ's maximum measurable levels for groundwater
SMCL = Federal secondary maximum contaminant levels for drinking water
URC = Oregon Health Division unregulated contaminants for drinking water
* = 29-Jan-03 Sample Date
** = 14-Oct-02 Sample Date




Figure 4-1
Stiff Diagram Illustrating Major Cations & Anions




Figure 4-2
 Piper Diagram Illustrating Water Quality Signatures

**Figure 4-3
Baker City Reservoir Well
Water Quality Trends**





Figure 4-4
Mountain Line Turbidity and Well Flow Data
Baker City ASR Project



5.0 Recharge Water Availability

5.1 General

Water availability for recharge is one of the essential components of the ASR project. Also, the length of continuous availability is important. Minimizing the start/stop operation of injection will minimize the potential for air intrusion into the aquifer. The City of Baker City has targeted two time periods for injection: winter and early summer after springtime runoff. These two seasons appear to be the most effective time periods for continuous recharge. The winter season will most likely be the most reliable period for continuous recharge.

Water source for recharge will come from diversions located within the City's watershed. These diversions vary in capacity depending on the time of year, weather patterns, and snow pack. The major diversions are Mill Creek, Little Mill Creek, Marble Springs, Elk Creek, Little Marble Creek, Little Salmon Creek, Big Salmon Creek, and the Goodrich Reservoir. There are other minor diversions that produce less water and are very seasonal.

5.2 Winter Season

During winter, the City staff utilizes Mill Creek, Little Mill Creek, and Marble Springs to meet average use. Additionally, Elk Creek is used for peak periods during the winter, but only approximately once every two weeks.

Historical flow data from the City's reservoir outlet for the years 2000, 2001, and 2002 indicate an average water system demand of approximately 800 to 900 gallons per minute (gpm). This would mean that approximately 850 gpm of water supply is obtained from the combination of Mill Creek, Little Mill Creek, and Marble Springs. Based on review of the fall/winter data logging at Mill Creek and Little Mill Creek and discussions with staff, the approximate distribution of water supply from these sources is as follows:

Primary Source to Meet Wintertime Demand:	
Mill Creek	500 gpm
Little Mill Creek	150 gpm
Marble Springs	200 gpm
Total Estimated Water Supply	850 gpm

As previously mentioned, Elk Creek is also used in the winter but very sparingly. The estimated water supply from Elk Creek, based on staff observation, is approximately 400 gpm. Little Marble Creek produces approximately 100 gpm in the winter. Little and Big Salmon Creeks produce approximately 100 and 200 gpm, respectively, based on staff observation. Therefore, from secondary sources the following water supply is available for recharge during most of the winter season.

Secondary Source Available for Wintertime Recharge:	
Elk Creek	400 gpm
Little Marble Creek	100 gpm
Little Salmon Creek	100 gpm*
Big Salmon Creek	200 gpm*
Total Estimated Water Supply	800 gpm

* These sources may taper off depending on snow pack and weather conditions.

Additionally, the Goodrich Reservoir basin may be a source of water supply during winter months. It has been reported that there is approximately 200 to 300 gpm available from reservoir leakage and immediate downstream creeks and springs that are between the reservoir and the point of diversion. Also if in the future valving and piping were installed in order to operate the reservoir outlet during winter months, more water supply would be available -- approximately 400 to 500 gpm.

5.3 Winter Recharge

In summary, there appears to be enough water supply during winter to provide sufficient continuous recharge water for the ASR project. The amount of available supply could range from approximately 750 to 1,100 gpm based on the above data. Although this would mean that approximately 108 to 158 MG could be stored for a 100-day recharge period, it should be noted that these values could vary depending on snow pack and weather conditions. A very cold winter could have a major influence on water availability. Also, water system demands for Baker City could have an impact on the availability of recharge. As the population of Baker City increases, availability of recharge water during this time period will decrease. Refer to Table 5-1 for the projected future water system demands.

5.4 Summer Season

Early summer recharge water availability is more uncertain and will be highly dependent on weather conditions and turbidity levels. Average water system demand for June through July is approximately 2,300 to 3,100 gpm. The average water system demand for June alone is approximately 1,940 to 2,700 gpm. From discussions with staff and review of data log readings, water supply from the watershed is approximately as follows:

Available Water Supply During Early Summer:		
	Estimated Supply *	Water Rights
Mill Creek	1,500 gpm	2,805 gpm
Little Mill Creek	500 gpm	2,244 gpm
Marble Springs	400 gpm	2,244 gpm
Elk Creek	800 gpm	1,683 gpm
Little Marble Creek	100 gpm	561 gpm
Little Salmon Creek	---	561 gpm
Big Salmon Creek	800 gpm	2,244 gpm
Totals	4,100 gpm	12,343 gpm

* These flows can vary significantly. Additionally, Goodrich Reservoir water is used during this time period when demand in the system increases and/or when available water is not as much as shown.

Given the fact that the mountain line can carry only approximately 3,100 gpm, historic peak system demands during June and July are met by using the mountain line, the Marble Springs intertie line, and, on a less frequent basis, the City well.

Based on the data, it appears that approximately 1,000 to 2,160 gpm can be available for recharge in early summer. During a 28-day period, there would be approximately 40 to 50 MG (maximum recharge of 1,250 gpm) available.

**Table 5-1
Projected Future Water System Demands**

	Future Demand*			
	Existing Demand (gpm)	Low	Medium	High
Winter	850**	900	1,030	1,210
Spring	1,180	1,260	1,420	1,650
Early Summer	2,700	2,890	3,280	3,860
Summer	4,530	4,980	5,660	6,660

* Future water system demands are based on low, medium, and high population projections for a 20-year planning period as shown within the Baker City, Oregon, Water Facility Plan.

** Updated with current historical data. Current data was more accurate than previous data used within the Facility Plan.

6.0 Recharge Analysis

6.1 Introduction

This section presents a detailed evaluation ASR injection and pumping at the Baker City's Reservoir Well based on aquifer test results and other data gathered during the initial ASR feasibility evaluation. The general criteria used as guidelines for evaluating the hydrogeologic feasibility of ASR for the City's Reservoir Well includes the following:

1. A confined aquifer with a transmissivity greater than 10,000 gallons per day per foot that is not significantly bounded; lower transmissivities are permissible if headroom (area above the static water level) is available in the aquifer.
2. The target aquifer can store in excess of 100 MG of water at the well site, can sustain the injection rates necessary to achieve this storage volume during an injection season, and can support well yields of at least 500 to 700 gpm (0.7 to 1.0 MGD) during recovery.
3. The water level in the recharge well does not rise above ground surface during injection and does not drop below the pump intake during pumping.
4. The target aquifer does not have other wells that could capture stored water.

The analysis of ASR feasibility with respect to these criteria is presented in the following sections.

6.2 Aquifer Characteristics

The Reservoir Well is completed in a volcanic basalt aquifer consisting of numerous individual lava flows. The aquifer is considered to be confined or semiconfined with a transmissivity ranging from approximately 2,500 to 7,300 gpd/ft. A storativity estimate was not calculated since a response in the observation well was not seen during the aquifer test. However, storativity estimates for the basalt aquifers generally range from 1×10^{-5} to 1×10^{-3} . Groundwater flow within the aquifer occurs through permeable layers between individual lava flows and fractures in the rock. The nearby mountain-front fault appears to be a leaky boundary between the basalt aquifer and the volcanic sedimentary aquifer beneath the valley floor. This is inferred because there was no abrupt change in the drawdown slope during the aquifer test. Instead the drawdown curve gradually steepened with time (refer to drawdown plots in Appendix B), which suggests that the fault is leaky. This increasing slope also suggests a diminishing transmissivity and a reduction in specific capacity as the cone of depression propagates away from the well. Overall, even though the transmissivity is less than 10,000 gpd/ft, the specific capacity at the end of a prolonged pumping period (flow rate divided by the drawdown or drawup in the well) appears high enough (16.5 gpm/ft) to support continued pumping and/or injection at lower rates than where used during the constant rate test.

6.3 Target Injection and Pumping Rates and Storage Volume

Based on discussions with the City, the following operational scenarios for the proposed ASR project were developed and are described below. These parameters were used during the ASR evaluation process. The scenarios also include target injection/recovery rates and estimated storage volumes. In general, injection will occur using mountain-line water during the wintertime when turbidity is acceptable. Summer time injection will occur after the spring turbidity events and its primary purpose is to store excess mountain-line water that may otherwise be spilled.

Winter-time Injection Criteria

The following represents general ASR evaluation criteria for a wintertime recharge scenario.

- A total of **100 days** of injection were assumed based on:
 - Injection period from December 1 to April 30th each year (about 150 days).
 - A total of 40 days were assumed for shutdown due to turbidity events.
 - Back flushing will occur every three weeks, which results in an additional 10-days of lost injection time.
- The injection rate was assumed at 800 gpm, which is 44 percent of the maximum pumping rate for the well.
- Recharge water turbidity is less than 0.5 NTU during injection.
- Head buildup in the well casing cannot exceed a threshold criterion of 25 feet below ground surface.

Summer-time Injection Criteria

The following represents general ASR evaluation criteria for a summer time recharge scenario.

- A total of **28 days** of injection were assumed based on:
 - Injection period from June 15th to July 30th each year (about 45 days).
 - A total of 4 days were assumed for shutdown due to turbidity events.
 - Back flushing will occur every three weeks, which results in an additional 3-days of lost injection time.
 - An additional 10 days of lost injection time will occur due to cycling the system on and off due to changes in the water level in the clear well.
- The injection rate was assumed at 1250 gpm, which is 70 percent of the maximum pumping rate for the well.
- Recharge water turbidity is less than 0.5 NTU during injection.
- Head buildup in the well casing cannot exceed a threshold criterion of 25 feet below ground surface.

Pumping Criteria

The following represents general ASR evaluation criteria for pumping (recovery).

- Head buildup calculations from year-to-year assume that 100% of the stored water is removed; otherwise the head buildup in the injection well will exceed the ground surface during year 2 injection.
- The pumping rate assumed at 1800 gpm.

6.4 Assessment of Target Injection and Recovery Rates

ASR well injection and recovery rates are controlled by a number of factors including pressure available in the recharge piping, the available headroom (drawup) and drawdown in the well, aquifer transmissivity, well efficiency, and boundary conditions as they affect drawup and drawdown. Aquifer and well performance data were used to evaluate if target injection and recovery rates are feasible based on predictions of drawup and drawdown during typical ASR operations in the City's proposed ASR well. These predictions were based on projections of specific capacity changes and water level trends over time. Specific capacity is the injection rate or pumping rate divided by the water level drawup or drawdown. It provides a simple and convenient index for how the well is performing and for the extent to which clogging is reducing well efficiency. For example, if the well is becoming clogged, we will see a reduction in specific capacity over time. For the purposes of this analysis, the constant rate drawdown test data were used to estimate the specific capacity at the end of winter- and summer time injection periods. Table 6-1 summarizes the head buildup and drawdown in the proposed ASR well for wintertime and summer time injection. The predictions are shown graphically in Figure 6-1. Appendix D presents detailed assumptions and calculations of the ASR evaluation.

Table 6-1
Estimated Drawup and Drawdown During ASR Operation at the Reservoir Well

Scenario	Year 1 Water Level (bgs)	Year 2 Water Level (bgs)	Year 3 Water Level (bgs)
Winter Time Injection (800 gpm)	113 feet	89 feet	61 feet
Summer-Time Injection (1250 gpm)	71 feet	32 feet	
Recovery (1800 gpm)	398 feet	360 feet	315 feet

bgs = below ground surface

Scenario assumes that the stored water (winter- and summer-time) is fully recovered each year.

Head buildup in summer assumes no water removed during wintertime storage.

Drawdown is less from year-to-year since the water level is higher each year due to injection (mounding).

This assessment is based on an assumed maximum water level buildup that is 25 feet bgs in the ASR well during injection. This threshold was used because it is assumed that injection will be driven by a booster pump, and that the wellhead is not sealed to prevent water from discharging from the top of the casing. It is possible to design the wellhead for injection under pressure, but it is generally not desirable if it can be avoided because of design and construction costs. The threshold of 25 feet bgs provides a buffer between the water level in the well and the wellhead in case of unexpected fluctuations during injection.

The assessment of injection and recovery rates incorporate a number of assumptions involving short-term and long-term decreases in injection and pumping specific capacities due to head changes in the well and clogging. The key assumptions are documented in Appendix D. The most critical of these assumptions involves estimates of the injection and recovery specific capacities. The assumptions regarding differences between injection and pumping specific capacities, and reductions in specific capacity over time are based on analysis of trends observed during ASR operation in Beaverton, Oregon and based on direct ASR project experience with other basalt-hosted systems.

The specific capacity of an ASR well is expected to decrease with time because of clogging of the skin around the borehole due to the introduction of suspended particulates during injection. Regular backflushing (pumping to waste) is an important operational tool for reducing the decline in specific capacity by removing particulates from the aquifer in the immediate vicinity of the well. However, declines in specific capacity can be expected even with a regular program of back flushing because short-term backflushing typically will not completely restore the specific capacity of the well. Thus, the need to redevelop an ASR well to reverse long-term specific capacity declines should be expected as part of the operation and maintenance of an ASR system. Redevelopment entails removing the wellhead and pump assembly, and aggressively cleaning out the well by some combination of scrubbing, jetting and pumping. The interval between redevelopment episodes will depend on the initial specific capacity of the ASR well and the long-term rate of specific capacity decline.

Air entrainment also is another factor that can result in loss of specific capacity of the well. At the startup of injection, as the water is injected down the pump column, cascading water causes air to become entrained. If the entrained air is forced out into the aquifer it can cause the formation to be air-locked and thus result in a loss of the aquifer's ability to transmit water, which is translated into a loss in well specific capacity. Since the summer time injection plan includes cycling injection (many starts and stops) possible air entrainment becomes an even greater concern. Designing the ASR system to minimize or ideally eliminate possible air entrainment of the injection water should be a high priority in the design and operation of the proposed Reservoir ASR well.

Our analysis indicates that target ASR recovery and injection rates are feasible at the site under the most conservative scenario used for this analysis and given the assumptions

outlined above for wintertime and summer time injection. The analysis also indicates that the Reservoir ASR well may need to be redeveloped every 2 to 3 years to restore specific capacity so that the final injection water level during summer time is maintained below the threshold level of 25 feet bgs.

6.5 Evaluation of Available Storage Volume


Evaluation of the projected well and aquifer response during injection indicates at least 115 MG can be stored in the aquifer during the wintertime and that an additional 50 MG can be stored during the summer injection period for a total of 165 MG. If the stored water is recovered at a rate of 1,800 gpm, pumping could be sustained for 60 to 90 days without depleting the aquifer or causing water quality degradation. This assumes that the total volume is removed each year. If the stored water is not removed, then it is anticipated that only a limited amount of water can be injected during the subsequent recharge period until the water levels drop back down.

The water level in the aquifer after the winter and summer injection period (with 165 MG in storage) is predicted to reach 142 feet bgs. The static water level in 1977 was 177 feet bgs. Since the water level in the aquifer will be higher than what was recorded when the well was drilled, there is the possibility that seeps could occur along the slope of the hill if a preferential pathway (e.g., fracture) exists between the deeper confined aquifer and the ground surface. As is common in any ASR project, monitoring for the possibility of losing water through seeps will need to be done during pilot testing of the ASR system.

According to historical records, the Reservoir Well production typically decreases to 1,000 gpm or less within 30 days of continuous pumping and the quality of the water degrades to the point where residents complain. Over the last 25 years, the City has pumped approximately 560 MG from the aquifer and there has been a 73-foot decline in static water level, which indicates that even sporadic, un-sustained pumping has exceeded the natural rate of groundwater recharge. ASR will substantially improve and extend the sustainable production capacity of the well and improve the quality of water produced after extended periods of pumping. In addition, ASR will stop “mining” of the aquifer that has occurred over the past 25 years of operating the Reservoir Well.

6.6 Capture of Stored Water by Other Wells

Three large-capacity (>100 gpm) wells completed in the deep basalt that could capture stored ASR water have been identified in the general vicinity of the site. Baker 1145 (Erwin well) is located approximately 0.2 miles northwest of the Reservoir Well and has a capacity of 200 gpm. Baker 1163 (Ellingson Timber well) is located approximately 1.4 miles east of the Reservoir Well and has a capacity of 2,000 gpm. It is not known if these two wells are still in operation or what rate they are pumped. Baker 1153 (Golf Course well) is located approximately 0.9 miles east of the Reservoir Well and has a capacity of 320 gpm. Both Baker 1163 and 1153 are located on the opposite side of the fault boundary from the Reservoir Well. Because we did not see a water level response in the Golf Course well (Baker 1153) or Paul Hill well (Baker 1136) during the 5-day aquifer test, we do not believe that wells located north of the fault will capture stored water.



NOTE:

- (1) Head buildup in summer assumes no stored water removed during winter-time injection
- (2) Drawdown based on summer storage
- (3) Head buildups assume stored volume recovered each year
- (4) Since head buildup is higher each year the drawdown in the well relative to bgs is less each year

Figure 6-1
Assessment of Target Injection
and Recovery Rates



7.0 Conclusions, Uncertainties, and Recommendations

7.1 Conclusions

The analysis of the results of the aquifer tests, water quality compatibility analysis, and ASR recharge evaluation indicate that an ASR well system providing up to 2.5 MGD (1800 gpm) of peaking and or emergency capacity appears to be feasible at the site. With a target winter storage volume of 115 MG and recovery rate of 1,800 gpm, the well will provide about 45 days of peak or emergency supply. It also appears feasible to store an additional 50 MG during the early summer months if demand remains low and flow is available in the watershed. This will extend the summer peak pumping period to 60 to 90 days without overpumping the aquifer or causing water quality degradation. Our conclusions are based on a number of hydrogeologic factors including:

Aquifer Characteristics: The aquifer is confined or semiconfined and the transmissivity of the aquifer is estimated to be between 2,500 to 7,300 gpd/ft, which is less than the minimum criterion proposed in the initial ASR evaluation. However, the estimated specific capacity at the end of a proposed injection period, coupled with the large available headroom in the aquifer, indicate that ASR is still feasible at this site. The projected effects of aquifer boundaries observed during the aquifer test do not appear to be a significant limitation to achieving target injection and recovery rates and the target storage volume.

Injection Rates, Pumping Rates and Storage Volume: The thickness of the basalt unsaturated zone and relatively low groundwater levels in the aquifer provide for sufficient available drawdown and headroom (drawup) in the aquifer to achieve the target injection and recovery rates and storage volume.

Capture of Stored Water by Other Wells: No large capacity deep basalt wells were identified on the south side of the fault boundary that could capture stored ASR water. The potential effects of pumping wells located north of the fault should be further assessed through monitoring during pilot testing at the Reservoir Well.

These conclusions are based on use of data obtained from relatively short-term aquifer tests. Thus, the validity of these conclusions for a long-term ASR operational scenario is subject to some uncertainties that are discussed in the following section.

7.2 Uncertainties

The results of the Reservoir Well recharge evaluation indicate that ASR is feasible at this site; however, there are still some basic uncertainties about what the long-term injection and recovery capacity of the ASR system will be. ASR field-testing will be required to resolve these uncertainties. The key uncertainties are listed below:

1. The ability of the ASR well to maintain target injection and pumping rates. This will depend upon the well efficiency over time, storage zone size and permeability, and

actual rate of clogging caused by turbidity and possibly entrained air. High quality recharge water that is free of suspended sediment and air is a key factor for maintaining well efficiency. Recharge water with turbidity exceeding 0.5 NTU will clog the aquifer matrix and quickly reduce the specific capacity of the well. The result will be decreased injection and potentially decreased recovery rates. In addition, since the summer time injection scenario will include cycling on and off, the system should be designed to minimize air entrainment of the injection water. Maintaining the emergency production capacity of the Reservoir Well is a high priority. Several measures should be implemented to maintain the injection and pumping capacity including:

- Flushing the water lines in the system that provide injection source water to remove particulates prior to starting injection.
 - Closely monitoring the quality of water being injected, and monitoring water levels in the well for changes in specific capacity.
 - Implementing a regular program of backflushing the well and pumping it to remove particulates introduced into the well during injection.
 - Periodically pulling the pump and aggressively redeveloping the well.
2. The long-term impact of injection and pumping of the deeper basalt aquifer zone on the shallow tuffaceous sediments beneath the valley floor north of the fault is not well understood. The data from the aquifer test indicate that the boundary fault is leaky; however, no response was observed in the Paul Hill well. Consequently, there is some uncertainty associated with the potential for ASR operation to affect water levels in shallow wells in the tuffaceous sediments.
 3. Since the head rise in the aquifer is anticipated to exceed the 1977 historic water level in the basalt aquifer, creating or enhancing seeps and springs due to increased water levels in the basalt aquifer is a possibility. Monitoring the potential for surface discharges during pilot testing will be important. The monitoring would include measuring water levels in the Reservoir Well and other wells in the area, such as the close by domestic wells, the Paul Hill well, and the golf course well. Periodic visual surveys of potential seep areas also should be conducted during the wet season prior to and during pilot testing.

7.3 Recommendations

On the basis of the technical analysis presented in this report, we do not see any fatal flaws for developing ASR at the Reservoir Well site and recommend proceeding with phase two of the project – ASR Pilot Testing at the Reservoir Well. The scope for Phase 2 consists of the following tasks. These activities are required by OWRD under the ASR rules.

- *Task 1 – Permitting- Obtain 5-year Limited License from OWRD*
- *Task 2 – ASR Design and Construction – Design and construct well, pump station, and system modifications to accommodate ASR at the Reservoir Well site*

- *Task 3 – ASR Work Plan – Prepare pilot testing work plan for submittal to OWRD*
- *Task 4 – ASR Pilot Testing – Conduct injection, storage, and recovery testing and monitoring at Reservoir Well as required by OWRD*
- *Task 5 – ASR Analysis and Report – Assess sustainable injection and pumping rates, storage volume, water quality improvement and aquifer response to ASR*
- *Task 6 – ASR Operations Plan – Develop operational parameters and O&M plan for City use*

A number of improvements and modifications will be required at the Reservoir Well site in order to retrofit the system for ASR. These improvements include the following:

- New booster pump at the 4.5 MG chlorine contact chamber and variable frequency drive (VFD) that allows adjustable rates of injection.
- New piping that conveys recharge water from the booster pump to the Reservoir Well.
- New recharge loop, piping, valves, and controls at the well head that permit injection down the pump column. Building modifications are required to accommodate the additional piping in the pump house.
- New pump to waste piping that permits discharge of wastewater from startup and back flushing.
- New liner casing in the well to 500 feet to protect the pump from falling rocks (there is presently only 20 feet of casing and open borehole to total depth).
- New pump, pump head, and pump column. The existing motor will be reused.
- New system controls and monitoring at the chlorine building that allow manual operation with automatic safety overrides.

The estimated cost for these improvements and associated engineering costs for permitting, system design, construction oversight, pilot testing, monitoring, and reporting are within the range presented previously. The total estimated cost for Phase 2 ranges from \$425,000 to \$458,000. A range of cost is presented because there are a number of elements that must be resolved during the design phase. Typical annual operation and maintenance costs during ASR pilot testing are approximately \$30,000 to \$40,000. This includes the additional monitoring and laboratory testing fees required by OWRD under the Limited License. This estimate assumes that City staff will complete the majority of the data collection in the field and that they will maintain and operate the ASR system with limited technical support. It has been our experience that these costs can be reduced after the first year of successful full-scale operation, due to a reduction in monitoring assuming OWRD approves. From past experience, the cost to pull the pump and redevelop the well every 2 to 3 years to remove sediment from the well that could not be removed by backflushing is approximately \$20,000.

The initial testing can last up to 5-years under the Limited License. After sufficient data regarding aquifer response, operational data, and lack of impacts are obtained to

demonstrate ASR feasibility, the City would then apply for a full-scale ASR permit. It is possible that this could be accomplished after one or two years of operation. Assuming that the results of the pilot testing are favorable, the City will have a fully functional full-scale ASR system at the conclusion of Phase 2.

The next steps of the project will include the following:

- Meet with OWRD to discuss the project (pre-application meeting July 2003)
- Complete and file a Limited License application and ASR work plan (July 2003)
- Work closely with the City to prepare design drawings and specifications for the well and pump station improvements (summer 2003)
- Obtain ASR Limited License after 30-day comment period (September 2003)
- Assess the condition of the well using a down-hole camera and install a steel liner to protect the new pump (fall 2003 after summer pumping season)
- Construct well and pump station improvements (fall 2003)
- Begin pilot recharge testing (winter 2003/2004)
- Begin recovery of stored water (summer 2004)

8.0 Conceptual ASR System Design, Operation, and Cost Update

This section of the report presents a description of the conceptual ASR system design and operation and an update of the costs for implementing Phase 2 – pilot testing. Pilot testing is required by OWRD to prove ASR feasibility and it will provide important operational data to be used by the City during full-scale operation. The system will be designed and the pilot program developed so that the system will deliver up to 2.5 MGD during the first summer following the first recharge season (summer of 2004).

8.1 Conceptual ASR Design and Operation

A preliminary site plan illustrating the planned ASR system layout is presented in Figure 8-1. Figure 8-2 presents the hydraulic profile for the system as it relates to the existing infrastructure at the Reservoir Well site. The ASR system components and well improvements consist of the following:

- New booster pump at the 4.5 MG chlorine contact chamber and variable frequency drive (VFD) that allows adjustable rates of injection.
- New piping that conveys recharge water from the booster pump to the Reservoir Well.
- New recharge loop, piping, valves, and controls at the well head that permit injection down the pump column. Building modifications are required to accommodate the additional piping in the pump house.
- New pump to waste piping that permits discharge of wastewater from startup and back flushing.
- New liner casing in the well to 500 feet to protect the pump from falling rocks (there is presently only 20 feet of casing and open borehole to total depth).
- New pump, pump head, and pump column. The existing motor will be reused.
- Existing supply line from the well back to the chlorine building.
- New system controls and monitoring at the chlorine building that allow manual operation with automatic safety overrides.

The ASR system will consist of two individual and separate operations: 1) recharge, and 2) withdrawal. The control and safety functions for each operation will utilize equipment with parallel capability, when possible, to simplify the system and avoid duplication of cost and/or control function. The following narratives outline the preliminary concept of operational and safety functions for each operation:

Recharge

Recharge operation will consist of delivering water from the chlorine contact chamber through a new booster pump. This water will be diverted to the well via a new 10-inch diameter buried recharge line to be installed from the proposed booster pump location to

the well. Water will be delivered into the well through a series of control valves and ultimately down the pump column, through the bowl assembly and out the pump inlet. Adequate pressure is required to fill the pump column as quickly as possible in order to minimize the amount of air that is pushed down the well and out into the aquifer. This is accomplished by a combination of the booster pump pressure and frictional losses developed as the recharge water flows down the pump column and through the bowl assembly. The rate of flow will be controlled by a variable frequency drive at the booster pump that will allow the injection rate to be adjusted. For example, the initial flow rate will be high in order to fill the pump column and then gradually reduced so that it matches the available supply coming in from the mountain line. The system is intended to be controlled manually at the chlorine building and there will be a number of automatic safety overrides that will shut down the system if a problem develops.

Withdrawal

Normal operation of the well will not differ appreciably from the current operation, except for operation of the control valves and a short duration pump to waste sequence prior to pumping the water to the chlorine building. Well operation will be based on normal withdrawal of water from the existing well using a new vertical turbine pump (which will also be used for recharge purposes). Operation of the well pump is also intended to be a manual operation with appropriate operational and safety controls.


A more detailed description of the ASR system operation and schematic of the system prepared by Stettler Supply Company are presented in Appendix F.

8.2 ASR Program Cost Update

Phase 1 of the project was completed on budget except for additional expenditures relating to addressing the broken pump discharge head. The cost estimate prepared previously for Phase 2 of the project was reviewed using information developed for the ASR conceptual design and information obtained when the existing well pump was lifted and tested. The updated cost estimate for Phase 2 is within the range of costs presented in our original proposal even though items have been added to the project, including a steel liner casing to protect the new pump. Table 8-1 presents our cost estimate for the engineering and construction elements of the Phase 2 pilot project. We have presented a range of costs for the ASR construction activities because there are a number of elements in the design that have not been finalized. When the next level of preliminary design is completed, the construction cost estimate will again be updated. On the basis of what we know now, the estimated budget presented in Table 8-1 will be adequate to complete the project.

**Table 8-1
Phase 2 Pilot Project Cost Summary
Baker City ASR Project**

Phase 2 – Engineering			
Task 1 Permitting – ASR Limited License			\$15,000
Task 2 Well and Pump Condition			\$8,000
Task 3 ASR Work Plan			\$6,000
Task 4 ASR Design and Construction Management			\$57,000
Task 5 ASR Pilot Testing			\$60,000
Task 6 ASR Analysis and Reporting			\$20,000
Task 7 ASR Operational Plan			\$9,000
Subtotal			\$175,000
Phase 2 – Construction Costs			
	\$250,000	---	\$283,000
TOTAL PHASE 2	\$425,000	---	\$458,000



CITY OF
 BAKER CITY, OREGON
 ASR FEASIBILITY STUDY
 ASR PRELIMINARY SITE PLAN

FIGURE
 8-1

References

U.S. Geologic Survey, 1976, Geologic Map of the Oregon Part of the Baker 1° by 2° Quadrangle.

Brooks, H.C., McIntyre, J.R., Walker, G.W., 1976, Geology of the Oregon Part of the Baker 1° by 2° Quadrangle.

Baker City 50 year climate averages, www.weatherbase.com.

Cooper, H.H., Jr., Jacob, C.E., 1946, A generalized graphical method for evaluating formation constants and summarizing well field history. Trans. American Geophysical Union, 27, p. 526-534.

Appendix A: Well Logs

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

RECEIVED

WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

AUG 3 1977 STATE OF OREGON
(Please type or print)
WATER RESOURCES DEPT.
SALEM, OREGON (Do not write above this line)

*Baker
11-18*

State Well No. 95/408-1
State Permit No. G-7635

(1) OWNER: #1
Name CITY OF BAKER
Address BAKER, OREGON

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED: Threaded Welded
16" Diam. from +2 ft. to -20 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS: Perforated? Yes No.
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with _____ ft. drawdown after _____ hrs.
EST. 1500 GPM AIR LIFT
PUMP TEST WILL BE MADE LATER
Baller test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 68 Depth artesian flow encountered NONE ft.

(9) CONSTRUCTION:
Well seal—Material used NEAT CEMENT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? _____

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County BAKER Driller's well number 024-71
NW 1/4 SE 1/4 Section 19 T. 9 S. R. 40 E. W.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 195
Static level 177 ft. below land surface. Date 7-30
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: 16" to 500 FT
Diameter of well below casing 10"
Depth drilled 800 ft. Depth of completed well 800

Formation: Describe color, texture, grain size and structure of material and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation. Report each change position of Static Water Level and indicate principal water-bearing strata:

MATERIAL	From	To	SWL
SILT SOIL	0	2	
MED. HARD BROWN BASALT	2	68	
GREY BASALT	68	110	
BROWN BASALT	110	173	
BROKEN BROWN & SOAPSTONE	173	195	W.
SOFT BROWN & SOAPSTONE	195	236	
BROWN BASALT	237	270	
RED BASALT	270	276	W.L.
BROWN BASALT	276	316	
BROKEN BROWN "	316	320	W.L.
BROKEN & SOAPSTONE	320	355	
HARD GREY BASALT	355	381	
RED BROWN BASALT	381	400	W.L.
GREY "	400	505	
HARD GREY BROKEN	505	528	
GREY & SOAPSTONE	528	633	
HARD GREY BASALT	633	700	
SOFT GREY & BROKEN	700	711	W.L.
SOFT GREY	711	800	

Work started 7-18 1977 Completed 7-30 1977
Date well drilling machine moved off of well 8-1 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Wallace Date 8-1, 1977
(Drilling Machine Operator)
Drilling Machine Operator's License No. 886

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WALLACE WELL DRILLING CO
(Person, firm or corporation) (Type or print)
Address 6 SKYLINE DR. TENDLER
[Signed] Wallace
(Water Well Contractor)
Contractor's License No. 583 Date 8-1, 1977

Baker
1136

OBSERVATION WELL

WATER WELL REPORT

State Well No. 9/40 - 180(1)

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

COPY

STATE OF OREGON U-781

State Permit No. U-696

(1) OWNER:

Name Paul V. Hill
Address 1045 Riverside Drive
Reno, Nevada

(2) LOCATION OF WELL:

County Baker Owner's number, if any—"Charlie"
SW 1/4 SE 1/4 Section 18 T. 9S R. 40E W.M.
Bearing and distance from section or subdivision corner
568 feet North and 671 feet East of
the SW corner, Section 18

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

12 " Diam. from 0 ft. to 575 ft. Threaded Welded
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
SIZE of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 29 ft. below land surface Date April 1955
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 1100 gal./min. with 166 ft. drawdown after _____ hr
" 980 " 147 " " "
" 750 " 119 " " "
Baller test gal./min. with _____ ft. drawdown after _____ hr
Artesian flow _____ g.p.m. Date _____
Temperature of water 60 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 12 inches

Depth drilled 575 ft. Depth of completed well 575 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
Soil and Clay	0	38
Shale Gravel and Sand	38	60
Gravel and red clay, cemented gravel	60	180
Gravel & Shale, clay, gravel	180	286
Gravel and Clay	286	408
Granite, hard & Soft, soapstone	408	488
Clay, Soapstone, gravel	488	538
Granite	538	565
Clay, Soapstone	565	575

Work started September 7 19 54 Completed April 12 19 55

(13) PUMP:

Manufacturer's Name Fairbanks Morse
Type: Turbine H.P. 50

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Roy French
(Person, firm, or corporation) (Type or print)

Address Pendleton, Oregon

Driller's well number _____

[Signed] _____ (Well Driller)

License No. _____ Date _____, 19____

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

BAKE 1145

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON

State Well No. 95/40E-1966

(Please type or print)

State Permit No. _____

(Do not write above this line)

NEW owner said SE NW Sec 19

pg 1 of 2

(1) OWNER:

Name Dave Erwin
Address Box 773 Baker, Oregon 97814

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Aug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(10) LOCATION OF WELL:

County BAKER Driller's well number 79E30
NE 1/4 NW 1/4 Section 19 T. 9S R. 40E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 441 ft.
Static level 287 ft. below land surface. Date 6-25-79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 520 ft. Depth of completed well _____ ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy Boulders	0	6	
Basalt Weathered	6	90	
Basalt BK Hand	90	102	
Basalt BK	102	160	
Basalt Brown	160	179	
Basalt Dark Brown	179	195	
Basalt Red	195	254	
Basalt BK	254	284	
Basalt BK Hand Shrink	284	297	
Basalt Bk	297	345	
Basalt Red	345	356	
Basalt BK	356	390	
Basalt BK Hand Shrink	390	396	
Basalt BK	396	441	
Basalt Red	441	445	287
Basalt BK	445	520	
Temporary Sealed 200lb bentonite Mixed 4 pump around 8" casing to			

Work started 6-15 1979 completed 6-25 1979
Date well drilling machine moved off of well 6-25 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Erwin Erwin Date 7-25-79
(Drilling Machine Operator)

Drilling Machine Operator's License No. 604

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Wade Drilling Inc
(Partnership, firm or corporation) (Type or print)

Address Prarie City, Oregon

[Signed] Wade
(Water Well Contractor)

Contractor's License No. 282 Date 8-Aug 1979

RECEIVED

WATER RESOURCES DEP
SALEM, OREGON

AUG 9 - 1979

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 200 gal./min. with 15.3 ft. drawdown after 4 hrs.

Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used See item #12

Well sealed from land surface to _____ ft.

Diameter of well bore to bottom of seal _____ in.

Diameter of well bore below seal _____ in.

Number of sacks of cement used in well seal _____ sacks

Was cement grout placed? _____

Did a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

BAKE
3/97

RECEIVED

OCT 13 1995

(START CARD) #

95/402/19
56240

Instructions for completing this report are on the last page of this WATER RESOURCES DEPT.

(1) OWNER: Well Number SALEM, OREGON
Name Mike Voboril
Address 900 story Ln.
City Baker City State OR Zip 97814

(2) TYPE OF WORK
 New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well 498 ft.
Explosives used Yes No Type Amount

HOLE			SEAL			Sacks or pounds
Diameter	From	To	Material	From	To	
10	0	20	Holeplug	0	20	13 bags
8	20	498				

How was seal placed: Method A B C D E
 Other Poured into water
Backfill placed from ft. to ft. Material
Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6	+2	498	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 5 1/2" shoe @ 498'

(7) PERFORATIONS/SCREENS:

Perforations Method downhole
 Screens Type Material

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
435	495	1/2" x 1"	600			<input checked="" type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Baller Air Flowing Artesian
Yield gal/min Drawdown Drill stem at Time
22 480 1 hr.

Temperature of water 57°F Depth Artesian Flow Found
Was a water analysis done? Yes By whom
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other
Depth of strata:

(9) LOCATION OF WELL by legal description:
County Baker Latitude Longitude
Township 9S N or S Range 40E E or W. WM.
Section 19 SW 1/4 SE 1/4
Tax Lot 5005 Lot Block Subdivision
Street Address of Well (or nearest address) Same

(10) STATIC WATER LEVEL:
190 ft. below land surface. Date 9/18/95
Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES:
Depth at which water was first found 150'±

From	To	Estimated Flow Rate	SWL
150'		1	116
255'		5	14
450'	498'	30-20	190

(12) WELL LOG:
Ground Elevation

Material	From	To	SWL
Clay w/ broken rock	0	3	
Broken rock	3	15	
Fractured rock	15	25	
Broken/Fractured rock	25	80	
Hard rock w/ a few fractures	80	90	
Broken/Fractured rock	90	370	190
Hard rock w/ fractures	370	376	190
Broken/Fractured rock	376	450	190
Hard rock w/ fractures	450	457	190
Broken/Fractured rock	457	498	190

Date started 9/8/95 Completed 9/18/95

(bonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed G. P. R. WWC Number 1312 Date 9/18/95

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed C. P. R. WWC Number 494 Date 9-23-

BAKE
1935

JAN 19 1993

9S/40E/19
30067

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

WATER RESOURCES DEPT.
SALEM, OREGON

(START CARD)

(1) OWNER: Well Number: _____
Name Alpine Timber Corp.
Address PO Box 228
City Baker City State OR Zip 97814

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Cable
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well 440 ft.
Explosives used Yes No Type _____ Amount _____

HOLE		SEAL		Amount sacks or pounds
Diameter	From To	Material	From To	
17	0 32	Cement	0 32	24
8	32 465			

How was seal placed: Method A B C D E
 Other _____
Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

Casing	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	8	47	32	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:	7	45	450	125	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of sheets: _____

(7) PERFORATIONS/SCREENS:
 Perforations Method Torch
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
450	410	8	50	7		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailor Air Flowing Artesian
Yield gal/min 75 Drawdown _____ Drill stem at 420 Time 1 hr.

Temperature of water 58 Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

(9) LOCATION OF WELL by legal description:
County Baker Latitude _____ Longitude _____
Township 9S N or S. Range 40 E E or W. W
Section 19 SE $\frac{1}{4}$ NW $\frac{1}{4}$
Tax Lot _____ Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) 6770 Genesidy Baker City OR 97814

(10) STATIC WATER LEVEL:
300 ft. below land surface. Date 10-12
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:

Depth at which water was first found _____

From	To	Estimated Flow Rate

(12) WELL LOG: Ground elevation _____

Material	From	To
Soil clay & Rocks	0	20
Rock Brown	20	135
Broken Rock	135	200
Rock	200	410
Rock Blue Clay	410	465

Date started 10-5-92 Completed 10-12-92

(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my knowledge and belief.
Signed Carl P. Telen WWC Number 49
Date 10-13-92

(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above work performed during this time is in compliance with Oregon construction standards. This report is true to the best of my knowledge and belief.
Signed Carl P. Telen WWC Number 49
Date 10-13-92

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

Bake 1780

RECEIVED

JUL 19 1989

(START CARD) #

9S/40E/19
9296

(1) OWNER: Name Robert P Ellingson - III
 Address P.O. Box 466
 City BALZER State ORC Zip 97714

WATER RESOURCES DEPT WELL by legal description:
 SALEM OREGON
 County _____ Latitude _____ Longitude _____
 Township 9S N on 8 Range 40 (R) or W, W
 Section 19 NE SE
 Tax Lot 5009 Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) 3975 INDIANA

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Cable
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other TEST well

(5) BORE HOLE CONSTRUCTION:
 Special Construction approval Yes No Depth of Completed Well 360 ft.
 Explosives used Yes No Type _____ Amount _____

HOLE		SEAL		Amount	
Diameter	From To	Material	From To	sacks or pounds	
<u>10</u>	<u>0</u> <u>19</u>	<u>CEMENT</u>	<u>0</u> <u>19</u>	<u>8</u>	
<u>6</u>	<u>19</u> <u>362</u>				

How was seal placed: Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: <u>6</u>	<u>+</u>	<u>19</u>	<u>1.250</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) NO-19

(7) PERFORATIONS/SCREENS:
 Perforations Method _____
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tela/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailor Air Flowing Artesian
 Yield gal/min 50 Drawdown 122 Drill stem at 362 Time 1 hr.

Temperature of water 52 Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: 265

(10) STATIC WATER LEVEL:
240 ft. below land surface. Date 7-12
 Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
 Depth at which water was first found 265

From	To	Estimated Flow Rate	ft
<u>265</u>	<u>267</u>	<u>2</u>	<u>2</u>
<u>295</u>	<u>292</u>	<u>4 1/2</u>	<u>2</u>

(12) WELL LOG: Ground elevation _____

Material	From	To	ft
<u>CLAY + ROCK</u>	<u>0</u>	<u>5</u>	
<u>Basalt + CLAY</u>	<u>5</u>	<u>75</u>	
<u>Basalt</u>	<u>75</u>	<u>265</u>	
<u>SCORI - M-B</u>	<u>265</u>	<u>267</u>	<u>2</u>
<u>Basalt</u>	<u>267</u>	<u>285</u>	
<u>GRAVEL - Med - M-B</u>	<u>285</u>	<u>292</u>	<u>2</u>
<u>Basalt</u>	<u>292</u>	<u>360</u>	
<u>GRANITE</u>	<u>360</u>	<u>362</u>	

Date started 6-27-89 Completed 7-12-89

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my knowledge and belief.

WWC Number _____
 Signed _____ Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above work performed during this time is in compliance with Oregon construction standards. This report is true to the best of my knowledge and belief.

WWC Number 591
 Signed Bellevy Dennis Date 7-12-89

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

RECEIVED WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
SEP 22 1977 (Please type or print)
(Do not write above this line)

State Well No. 95/40E-206

State Permit No. _____

NC
Baker
1153

(1) OWNER: SALEM, OREGON
Name Baker Municipal Golf Course
Address Baker, Oregon

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED: Threaded Welded
" Diam. from 2 1/2 ft. to 3 1/2 ft. Gage 2.50
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS: Perforated? Yes No.
Type of perforator used factory mill
Size of perforations 1/8 in. by 2 3/4 in.
1530 perforations from 2 1/2 ft. to 3 1/2 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 320 gal./min. with 1 1/4 ft. drawdown after 3 hrs.
Compressor: " " " "

Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 48 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 15 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed?
pumped thru drill pipe
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel 3/8 pea
Gravel placed from 20 ft. to 3 1/2 ft.

(10) LOCATION OF WELL:
County Baker Driller's well number _____
SE 1/4 NW 1/4 Section 20 T. 9S R. 40E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 248 ft.
Static level 80 ft. below land surface. Date 9-15
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 349 ft. Depth of completed well 349 ft.
Formation: Describe color, texture, grain size and structure of materials and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata

MATERIAL	From	To	SWL
Top soil	0	1	
Fractured Basalt	1	12	
Sand Stone Dark Br with Br. Clay	12	55	
Sand Stone Red	55	70	
Sand Stone Blk	70	248	
Basalt Fractured	248	288	55
Basalt with streaks Clay Blue white	288	314	↑
Basalt Red Cap	314	321	
Basalt Fractured - streaks of Clay Blue	321	328	
Basalt Red Cap	328	334	↓
Basalt Blk	334	349	85

Work started 9-10 1977 Completed 9-15 1977
Date well drilling machine moved off of well 9-15 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ernest Johnson Date 9-18, 1977
(Drilling Machine Operator)
Drilling Machine Operator's License No. 604

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Northwest Drilling (Type or print)
Address Large City, Oregon
[Signed] Donald J. ... (Water Well Contractor)
Contractor's License No. 577 Date 9-19, 1977

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

APR 28 1994

WATER RESOURCES DEPT. (START CARD)

*BAKE
2022*

*9S/40E/9a
157830*

(1) OWNER: SALEM
 Name: Steve Bogard
 Address: 1205 17th St
 City: PALEO CITY State: OR Zip: 97914

(9) LOCATION OF WELL by legal description:
 County: PA/9E17 Latitude _____ Longitude _____
 Township: 9 N of S, Range: 40 (E or W, W)
 Section: 9 SE 1/4 NE 1/4
 Tax Lot: 100 Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address): 1205 17th St

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD
 Rotary Air Rotary Mud Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(5) BORE HOLE CONSTRUCTION:
 Special Construction approval Yes No Depth of Completed Well: 330 ft.
 Explosives used Yes No Type _____ Amount _____

HOLE			SEAL			Amount sacks or pounds
Diameter	From	To	Material	From	To	
10	0	19	BENTONITE	0	19	7.50
6	19	330				

How was seal placed: Method A B C D E
 Other: RAY BENTONITE
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6	0	259	259	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2	259	330	330	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s): 259

(7) PERFORATIONS/SCREENS:
 Perforations Method: SLITTED PIPE
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
290	330	8	69	1/4	4 1/2	<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailor Air Flowing Artesian
 Yield gal/min: 2.5 Drawdown: 280 Drill stem at: 330 Time: 1 hr.

Temperature of water: 54 Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: 73-100

(10) STATIC WATER LEVEL:
50 ft. below land surface. Date: 4-8-94
 Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
 Depth at which water was first found: 73

From	To	Estimated Flow Rate
73	110	2
117	119	3
195	210	3
325	330	25

(12) WELL LOG: Ground elevation _____

Material	From	To
TOP SOIL	0	3
CLAY yellow	3	23
" Red	23	41
" yellow	46	73
SAND GRAVEL - 2-1/2	73	100
CLAY BLUE	100	117
SAND FINE - 4-1/2 - B	117	119
CLAY BLUE	119	195
SAND - 4-1/2 - D	195	210
CLAY BLUE	210	325
SAND - 1/2 - B	325	330

Date started: 3-29-94 Completed: 4-9-94

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration, abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my knowledge and belief.

WWC Number _____
 Signed _____ Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above work performed during this time is in compliance with Oregon construction standards. This report is true to the best of my knowledge and belief.

WWC Number 59
 Signed W. L. ... Date 4-8-94

STATE ENGINEER TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED
JUL 3 1972
STATE ENGINEER
SALEM, OREGON

(Handwritten signature/initials)

BAKE
1140

9S/40-19

STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion.

STATE ENGINEER (Type or print)
(Do not write above this line)

State Well No. _____
State Permit No. _____

(1) OWNER:

Name Park Taylor
Address 1241 4th St.; Baker, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Aug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 11 ft. to 197.6 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mel's Perforator
Size of perforations 2.5 in. by 5/16 in.
88 perforations from 100 ft. to 122 ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 10 ft. below land surface Date 2/16/72
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Id: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Baller test 4.5 gal./min. with 120 ft. drawdown after 2 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 50° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Benzonite
Depth of seal _____ 20 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Baker Driller's well number _____
1/4 Section 19 T. 9 S. R. 40 E. W. 1
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 5.75"
Depth drilled 305 ft. Depth of completed well 305

Formation: Describe color, texture, grain size and structure of material and show thickness and nature of each stratum and aquifer penetrate with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rate

MATERIAL	From	To	SWL
Top soil	0	2	
Broken rock; clay	2	10	
Broken rock; clay	10	15	
Hard yellow clay	15	22	
Broken rock; clay	22	26	
Broken rock; clay; sand	26	30	
Broken rock; clay; sand	30	35	
Hard brown rock	35	37	
Clay	37	40	
Hard rock	40	43	
Hard clay; Broken rock	43	50	
Hard Clay; Broken rock	50	68	
Hard blue shale	68	80	
Hard blue shale	80	88	
Brown rock; clay	88	90	
Brown rock; clay	90	100	
Brown rock; clay	100	105	1.2
Brown rock; clay	105	120	
Brown rock; clay; gravel	120	121	10'
Brown rock; clay; gravel	121	126	
Brown rock; clay; gravel	126	131	34'

(continued on extra page)

Work started Jan. 20, 1972 Completed March 30, 1972
Date well drilling machine moved off of well May 15, 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Wilbur C. Skinner Date June 30, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 20

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Wilbur C. Skinner
(Person, firm or corporation) (Type or print)

Address 305 2nd St.; Baker, Ore.

[Signed] Wilbur C. Skinner
(Water Well Contractor)

Contractor's License No. 68 Date _____, 19____

Appendix B

Appendix B: Aquifer Test Analysis and Results

Appendix B

Aquifer Test Analysis and Results

Step Drawdown Test Analysis

The step drawdown test consisted of four 1-hour consecutive steps with discharge rates of 500 gpm, 1000 gpm, 1500 gpm and 2000 gpm, respectively. The drawdown data for each step are presented in Figure B-1.




Figure B-1

Step Drawdown Test Hydrograph Baker City ASR Reservoir Well Study

The Hantush-Bierschenk (1964) method was used to analyze the data in order to pick a pumping rate for the constant rate test and to assess head losses in the well due to laminar flow. The governing equation for evaluating the step drawdown test data is:

$$s = BQ + CQ^2$$

where:

- s is the drawdown
- Q is the pumping rate
- B is the laminar flow loss constant
- C is the turbulent flow loss constant

Solving for laminar flow losses as a percentage of total head loss the equation becomes:

$$L_p = \frac{BQ}{BQ + CQ^2}$$

The data analysis is summarized in Table B-1 and figure B-2.

Table B-1

Step Drawdown Test Analysis
Baker City ASR Reservoir Well Project

Step	S (60 min)	Q (gpm)	S/Q	
1	5.23	500	0.01034	Slope (C)= 4E-6 Y Intercept (B)= 0.0086 Q = 1500 Laminar Flow Losses = 58.9
2	7.5	1000	0.01267	
3	8.38	1500	0.01403	
4	11.17	2000	0.01611	




Figure B-2

Hantush Bierschenk Analysis
Baker City ASR Reservoir Well

Constant Rate Test Analysis

The constant rate aquifer test included pumping the Reservoir Well at a rate of 1500 gpm for approximately 120 hours. Water levels in the Reservoir Well were monitored during pumping and also for approximately 216 hours during recovery. Water levels in the Paul Hill Well and Golf Course Well also were measured during the pumping phase of the test. Figure B-3 shows a hydrograph of water level changes in the Reservoir well during the pumping and recovery phases of the test. Figure B-4 shows a hydrograph of water levels in the Paul Hill Well during the pumping phase of the test. No change in water level was observed in the Golf Course Well and so no hydrograph was prepared.

The test data for the Reservoir Well were plotted on semi-log graphs and assessed for potential boundary conditions. The aquifer transmissivity was calculated from the early time pumping phase water level data and from the recovery data using the Cooper-Jacob (1946) method. The Cooper-Jacob equation for calculating transmissivity using English units is:

$$T = \frac{264 \cdot Q}{\Delta s}$$

where:

T = transmissivity of the aquifer in gallons per day per foot of aquifer thickness

Q = pumping rate in gallons per minute (gpm)

Δs = the change in drawdown over one log cycle of t (time in minutes) on a plot of drawdown versus log time (minutes since the beginning of pumping)

Using projected late time pumping phase data shown on Figure B-5 to calculate the aquifer transmissivity gives:

$$T_1 = \frac{264 \cdot 1500 \text{ gpm}}{140 \text{ feet}}$$

$$T_1 = \sim 2800 \text{ gpd/ft}$$

The equation is the same for calculating transmissivity from recovery data except Δs is taken as the drawdown over one log cycle of time plotted as t/t' where t is the elapsed time in minutes since the beginning of pumping and t' is the time since pumping stopped. If the projected late time recovery data ($t/t' < 10$) are used to calculate transmissivity (Figure B-6), the results are as follows:

$$T_2 = \frac{264 \cdot 1500 \text{ gpm}}{54 \text{ feet}}$$

$$T_2 = \sim 7300 \text{ gpd/ft}$$






Figure B-3
Reservoir Well Hydrograph
Constant Rate Aquifer Test
Baker City ASR Reservoir Well Study




Figure B-4
Hydrograph of Paul Hill Well
Constant Rate Aquifer Test
Baker City ASR Reservoir Well Study




Figure B-5
Pumping Phase Data Analysis - Reservoir Well
Constant Rate Aquifer Test
Baker City ASR Reservoir Well Study




Figure B-6
Reservoir Well Recovery Data Analysis
Constant Rate Aquifer Test

Water Level Measurements

Project Baker City ASR Project
 Well Id Reservoir Wall

Page 1 of 10

Date 1/29/03

Pump Test Id Step Test
 Dist. From pumping well 0 ft
 Start of Pump Test 10:15 AM
 Stop of Pump Test _____
 Initial Water Level _____

Well Depth _____ ft
 Screen Interval _____

Reference Point Description Top of 1.5" PVC access tube. Steep 2.97' above floor
 Remarks _____

100 PSI transducer set at ~ 225' below static (vented)
INW 1522 logger
Agua 4 software

BRP = below reference point

Date	Time	Initials	Depth to Water ft BRP	Drawdown ft	Discharge Rate			Field Parameters
					Date	Time	Flow Meter Reading	
1/29/03	3:43 p	JB	248.30				0	
1/23	6:45 p	JB	248.12					
1/24	08:30	JB	247.94					
1/24	10:15						500	
	10:17		251.85				↓	
	10:20		251.56				↓	
	10:25		251.73				↓	
	10:37		252.38				↓	
	10:49		252.94				500	
	10:58		253.05				↓	
	11:14		253.17				↓	
	11:15						1000	
	11:16		258.74				↓	
	12:00		260.10				↓	
	12:11		260.63				1000	
	12:14		260.67				1000	
	12:15						1500	
	12:16		267.20				↓	
	12:49		268.48				↓	
	13:14		269.05				↓	
	13:15						2000	
	13:20							
								PH 2.97
								T = 15.5
								EC = 376

45
 ↑
 not calibrated

Water Level Measurements

Project BAKER CITY ASR

Page 3 of 10

Well Id RESERVOIR WELL

Date 1/25/03

Pump Test Id CONSTANT RATE

Dist. From pumping well 0 ft

Well Depth _____ ft

Start of Pump Test _____

Screen Interval _____

Stop of Pump Test _____

Initial Water Level _____

Final Water Level _____

Reference Point Description TOP OF 1.5" PVC ACCESS TUBE, 2.97' ABOVE FLOOR

Remarks 100 PSI TRANSDUCER SET AT ~ 225' BELOW STATIC (VENTED)

IN W 1522 LOGGER

AQUA4 SOFTWARE

File RESCONS.DAT, RESCONS1.DAT

BRP = below reference point

Date	Time	Initials	Depth to Water ft BRP	Drawdown ft	Discharge Rate			Field Parameters	
					Date	Time	Flow Meter Reading		Discharge Rate gpm
1/25/03	8:02	JLZ	250.36				092954	0	
	8:51		250.27						
	9:20		250.17				92954	0	
	9:21:00		266.13					1500	
	9:21:30		266.50						
	9:22:00		266.23						
	9:22:30		267.42						
	9:23:00		267.58						
	9:23:30		267.65						
	9:24:00		267.74						
	9:24:30		267.84						
	9:25:00		267.86						
	9:25:30		267.92						
	9:26:00		267.98						
	9:31		268.21			9:32	092972	1500	
	9:36		268.52						
	9:41		268.67						
	9:46		268.87						
	9:51		269.04						
	9:56		269.19						
	10:01		269.30						
	10:06		269.73						
	10:11		269.83						
	10:16		269.95						
	10:21	JLZ	270.10				093048	1500	

Water Level Measurements

Project BALCONY ASR
 Well Id RESERVOIR Well

Page 9 of 10

Pump Test Id CONSTANT RATE RECHARGE.

Date _____

Dist. From pumping well _____ ft

Well Depth _____ ft

Start of Pump Test _____

Screen Interval _____

Stop of Pump Test _____

Initial Water Level _____

Final Water Level _____

Reference Point Description _____

Remarks _____

BRP = below reference point

Date	Time	Initials	Depth to Water ft BRP	Drawdown ft	Discharge Rate			Field Parameters
					Date	Time	Flow Meter Reading	
1/30/03	11:14		341.15				103946	1500
	11:15:00		316.77					0
	15:30		318.19					
	16:00		318.19					
	16:30		321.80					
	17:00		321.89					
	17:30		321.89					
	18:00		321.92					
	18:30		321.94					
	19:00		321.91					
	19:30		321.86					
	11:20:00		321.83					
	11:25:00		321.55					
	11:30		321.39					
	11:35		321.22					
	11:40		321.12					
	11:45		320.97					
	11:50		320.83					
	11:55		320.73					
	12:00		320.64					
	12:05		320.52					
	12:10		320.41					
	12:15		320.29					
	12:35		319.89					
	12:55		319.59					

Water Level Measurements

Project _____

Page 10 of 10

Well Id Reservoir Well

Pump Test Id CONSTANT RATE RECHARGE Date _____

Dist. From pumping well _____ ft Well Depth _____ ft

Start of Pump Test _____ Screen Interval _____

Stop of Pump Test _____

Initial Water Level _____

Final Water Level _____

Reference Point Description _____

Remarks _____

BRP = below reference point

Date	Time	Initials	Depth to Water ft BRP	Drawdown ft	Discharge Rate				Field Parameters
					Date	Time	Flow Meter Reading	Discharge Rate gpm	
1/30/03	1:15		319.20						
	2:15		318.16						
	3:15		317.30						
	4:15		316.38						
	6:15		314.87						
	8:15		313.40						
1-31-03	6:15		307.18						
	8:15		306.10						
	10:10		305.15						
	12:15		304.10						
	14:15		303.16						
	16:13		302.27						
2-1-03	18:35		301.23						
	20:15		300.56						
	6:17		296.81						
	8:13		296.20						
	10:10		295.58						
	12:16		294.89						
2-2-03	14:15		294.25						
	16:16		293.72						
	18:15		293.15						
	20:12		292.59						
	6:22		290.02						
	8:19		289.58						
2-2-03	10:19		289.09						
	12:27		288.61						

Appendix C

Appendix C: Laboratory Data Sheets


MAGIC VALLEY LABS
 210 Addison Ave / PO Box 1867
 Twin Falls ID 83303-1867
 Phone: (208) 733-4250
 Fax: (208) 734-2539

BAKER CITY OF

P.O. BOX 650
 BAKER CITY OR 97814

Sample #	Test / Method Code	Results in mg/L	Date Analyzed	Analyst
309841	CHLORIDE	3	1/31/2002	RB
309842	IRON	ND	2/12/2003	RB
309843	DISSOLVED IRON	ND	2/12/2003	RB
309844	MANGANESE	ND	3/11/2003	RB
309845	DISSOLVED MANGANESE	ND	3/11/2003	RB
309846	TDS	42	1/31/2003	RB
309847	ZINC	ND	1/31/2003	RB
309848	ALKALINITY	246 25	1/29/2003	EB
309849	CARBONATE	<1	1/29/2003	EB
3098410	BICARBONATE	246 25	1/29/2003	EB

*correction from
 MVL = 5/6/03
 SK*



Signature

Report Date: Wednesday, March 26, 2003


MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

CHUCK EVERSON
BAKER CITY OF

P.O. BOX 650
BAKER CITY OR 97814

Collection Date 12/18/2002 Received Date 12/18/2002 Location
Collection Time 7:30 AM Received Time 6:00 PM RESERVOIR A.S.R

Sample #	Test / Method Code	Results in mg/L	Date Analyzed	Analyst
302471	BICARBONATE	38	12/19/2002	EB
302472	CARBONATE	<1	12/19/2002	EB
302473	ALKALINITY	38	12/19/2002	EB
302474	CALCIUM	18.6	1/24/2003	RB
302475	CHLORIDE	2	12/20/2002	RB
302476	HARDNESS	86	12/20/2002	RB
302477	MAGNESIUM	5.72	1/28/2003	RB
302478	NITRATE/N SM4500D	0.19	12/19/2002	JK
302479	NITRITE/N SM4500E	<0.002	12/19/2002	JK
3024710	NITRATE/N + NITRITE/N	0.19	12/19/2002	JK




Signature

Report Date: Friday, January 31, 2003

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

3024711	POTASSIUM	0.7	1/29/2003	RB
3024712	SILICA	16.8	12/24/2002	JH
3024713	SODIUM	5.03	1/22/2003	RB
3024714	SULFATE	11	12/20/2002	RB
3024715	TDS	79	12/20/2002	RB
3024716	TOC	0.71	12/26/2002	MDM
3024717	TSS EPA160.2	<1	12/19/2002	EB
3024718	ALUMINIUM	<0.10	12/30/2002	JH
3024719	ARSENIC	<0.005	1/8/2003	JMR
3024720	DISSOLVED IRON	<0.1	1/16/2003	RB
3024721	TOTAL IRON	<0.1	1/16/2003	RB
3024722	DISSOLVED MANGANESE	<0.05	1/14/2003	RB
3024723	TOTAL MANGANESE	<0.05	1/14/2003	RB
3024724	FILTER	*		..




Signature

Report Date: Friday, January 31, 2003

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

3098411	CALCIUM	8.95	2/12/2003	RB
3098412	HARDNESS	51	1/31/2003	RB
3098413	MAGNESIUM	2.18	2/12/2003	RB
3098414	pH EPA150.1	6.2	1/29/2003	EB
3098415	POTASSIUM	ND	2/8/2003	RB
3098416	SILICA	11.1	2/10/2003	JH
3098417	SULFATE	ND	2/5/2003	RB
3098418	TSS EPA160.2	2.	1/31/2003	EB
3098419	TOC	0.98	2/7/2003	MDM

Signature


Report Date: Wednesday, March 26, 2003

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

To be Filled in by Person Submitting Sample:		
Public Water System <input type="checkbox"/>	Realty Transaction <input type="checkbox"/>	
Pws ID #: 4100073	Source ID:	Source name:
Public Water System or Property Owner Name		
BAKER CITY OF		
Address P.O. BOX 650		
City, State, Zip BAKER CITY OR 97814		
Sampled at: GROUNDWATER	Sampled by:	
Date Collected: 1/29/2003	Time collected: 12:00:00 PM	
Sample Composition: Plant Tap	Single	

To be Completed by Laboratory					
Date received in lab: 1/30/2003		Nitrate MDL = 0.06mg/L Nitrite MDL = 0.003mg/L Date analyzed NO3: Date analyzed NO2: 1/31/2003 1/31/2003			
Lab sampled ID #: 309821		Sample composited in lab: N			
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
Nitrate	1040	10.	<0.05	SM4500D	RB
Nitrate-Nitrite	1038	10.			
Nitrite	1041	1.0	<.002	SM4500E	RB

Signature / date: Shelly Koles

Magic Valley Labs, Inc.
210 Addison Ave
Twin Falls ID 83301

Baker city of
PO Box 650
Baker City OR 97814

38

Date	Time	Name	Sample #	Total coliform mpr/100ml	E-coli mpr/100ml	Completed	Initials
------	------	------	----------	-----------------------------	---------------------	-----------	----------

1/29/2003	12:00pm	Groundwater		<1	<1	1/31/2003	EB

Signature & date: Colleen Pass 2-3-03

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

BAKER CITY OF

P.O. BOX 650
BAKER CITY OR 97814

Collection Date	1/29/2003	Received Date	1/30/2003	Location	
Collection Time	12:00 PM	Received Time	8:10 AM	GROUNDWATER	
Sample #	Test / Method Code	Results in mg/L	Date Analyzed	Analyst	
309811	CHLORIDE	6	1/31/2003	RB	
309812	COLOR	ND	2/7/2003	MDM	
309813	IRON	<0.1	2/12/2003	RB	
309814	DISSOLVED IRON	<0.1	2/12/2003	RB	
309815	MANGANESE	0.12	2/11/2003	RB	
309816	DISSOLVED MANGANESE	0.09	2/11/2003	RB	
309817	ODOR	ND	2/7/2003	MDM	
309818	SURFACTANTS	ND	2/15/2003	MDM	
309819	TDS	184	1/31/2003	RB	
3098110	ZINC	ND	2/8/2003	RB	

Signature




Report Date: Wednesday, March 26, 2003

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

3098111	ALUMINIUM	ND	2/12/2003	RB
3098112	ALKALINITY	92	1/29/2003	EB
3098113	CARBONATE	<1	1/29/2003	EB
3098114	BICARBONATE	92	1/29/2003	EB
3098115	CALCIUM	30.9	2/12/2003	RB
3098116	HARDNESS	154	1/31/2003	RB
3098117	MAGNESIUM	16.3	2/12/2003	RB
3098118	POTASSIUM	1.8	2/8/2003	RB
3098119	SILICA	38.1	2/10/2003	JH
3098120	SULFATE	39	2/5/2003	SK
3098121	TSS EPA160.2	<1	1/31/2003	EB
3098122	TOC	6.7	2/7/2003	MDM
3098123	LANGELIER INDEX	0.23	2/18/2003	RB

Signature



Report Date: Wednesday, March 26, 2003



LABORATORY ANALYTICAL REPORT

Client: Magic Valley Labs Inc
 Project: Baker City
 Lab ID: C03010962-001
 Client Sample ID: Ground Water

Report Date: 03/11/03
 Collection Date: 01/29/03
 Date Received: 01/30/03
 Matrix: Drinking Water

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
MAJOR IONS							
Fluoride	0.3	mg/L		0.1	2	A4500-F C	02/03/03 14:30 / slb
METALS - TOTAL							
Sodium	19	mg/L		1.0		E200.7	02/05/03 13:13 / cp
RADIONUCLIDES - TOTAL							
Gross Alpha	1.1	pCi/L		1.0	15	E900.0	02/03/03 12:00 / rs
Gross Alpha Precision (±)	1.0	pCi/L				E900.0	02/03/03 12:00 / rs
Gross Beta	12.2	pCi/L		2.0	50	E900.0	02/03/03 12:00 / rs
Gross Beta Precision (±)	1.9	pCi/L				E900.0	02/03/03 12:00 / rs
Radon 222	465	pCi/L		100	300	D5072-92	01/31/03 17:05 / db
Radon 222 precision (±)	80.7	pCi/L				D5072-92	01/31/03 17:05 / db
INORGANIC COMPOUNDS							
Aluminum	0.0071	mg/L		0.0001	0.2	E200.8	02/05/03 22:15 / smd
Antimony	ND	mg/L		0.001	0.006	E200.8	02/05/03 22:15 / smd
Arsenic	0.006	mg/L		0.005	0.01	E200.8	02/05/03 22:15 / smd
Barium	ND	mg/L		0.1	2	E200.8	02/05/03 22:15 / smd
Beryllium	ND	mg/L		0.0005	0.004	E200.8	02/05/03 22:15 / smd
Cadmium	ND	mg/L		0.0005	0.005	E200.8	02/05/03 22:15 / smd
Chromium	ND	mg/L		0.05	0.1	E200.8	02/05/03 22:15 / smd
Copper	ND	mg/L		0.01	1.3	E200.8	02/05/03 22:15 / smd
Lead	0.005	mg/L		0.001	0.015	E200.8	02/05/03 22:15 / smd
Mercury	ND	mg/L		0.0005	0.002	E200.8	02/05/03 22:15 / smd
Nickel	ND	mg/L		0.02	0.1	E200.8	02/05/03 22:15 / smd
Selenium	ND	mg/L		0.005	0.05	E200.8	02/05/03 22:15 / smd
Silver	ND	mg/L		0.0009	0.05	E200.8	02/05/03 22:15 / smd
Thallium	ND	mg/L		0.0004	0.002	E200.8	02/05/03 22:15 / smd
VOLATILE ORGANIC COMPOUNDS							
1,1,1,2-Tetrachloroethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,1,1-Trichloroethane	ND	ug/L		0.50	200	E524.2	01/31/03 23:02 / rh
1,1,2,2-Tetrachloroethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,1,2-Trichloroethane	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
1,1-Dichloroethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,1-Dichloroethene	ND	ug/L		0.50	7	E524.2	01/31/03 23:02 / rh
1,1-Dichloropropene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,2,3-Trichloropropane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh

Report Definitions: RL - Analyte reporting limit.
 QCL - Quality control limit.
 * - The result exceeds the MCL.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Magic Valley Labs Inc
 Project: Baker City
 Lab ID: C03010962-001
 Client Sample ID: Ground Water

Report Date: 03/11/03
 Collection Date: 01/29/03
 Date Received: 01/30/03
 Matrix: Drinking Water

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
VOLATILE ORGANIC COMPOUNDS							
1,2,4-Trichlorobenzene	ND	ug/L		0.50	70	E524.2	01/31/03 23:02 / rh
1,2,4-Trimethylbenzene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,2-Dichlorobenzene	ND	ug/L		0.50	600	E524.2	01/31/03 23:02 / rh
1,2-Dichloroethane	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
1,2-Dichloropropane	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
1,3-Dichlorobenzene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,3-Dichloropropane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
1,4-Dichlorobenzene	ND	ug/L		0.50	75	E524.2	01/31/03 23:02 / rh
2,2-Dichloropropane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
2-Chlorotoluene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
4-Chlorotoluene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Benzene	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
Bromobenzene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Bromodichloromethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Bromoform	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Bromomethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Carbon tetrachloride	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
Chlorobenzene	ND	ug/L		0.50	100	E524.2	01/31/03 23:02 / rh
Chlorodibromomethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Chloroethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Chloroform	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Chloromethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
cis-1,2-Dichloroethene	ND	ug/L		0.50	70	E524.2	01/31/03 23:02 / rh
cis-1,3-Dichloropropene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Dibromomethane	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Ethylbenzene	ND	ug/L		0.50	700	E524.2	01/31/03 23:02 / rh
Methylene chloride	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
Styrene	ND	ug/L		0.50	100	E524.2	01/31/03 23:02 / rh
Tetrachloroethene	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
Toluene	ND	ug/L		0.50	1000	E524.2	01/31/03 23:02 / rh
trans-1,2-Dichloroethene	ND	ug/L		0.50	100	E524.2	01/31/03 23:02 / rh
trans-1,3-Dichloropropene	ND	ug/L		0.50		E524.2	01/31/03 23:02 / rh
Trichloroethene	ND	ug/L		0.50	5	E524.2	01/31/03 23:02 / rh
Vinyl chloride	ND	ug/L		0.50	2	E524.2	01/31/03 23:02 / rh
VOC pH	7	s.u.		0.10		E524.2	01/31/03 23:02 / rh
Xylenes, Total	ND	ug/L		1.0	10000	E524.2	01/31/03 23:02 / rh
Trihalomethanes, Total	ND	ug/L		2.0	80	E524.2	01/31/03 23:02 / rh
Surr: Dibromofluoromethane	101	%REC			70-130	E524.2	01/31/03 23:02 / rh

Report Definitions: RL - Analyte reporting limit.
 QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Magic Valley Labs Inc
 Project: Baker City
 Lab ID: C03010962-001
 Client Sample ID: Ground Water

Report Date: 03/11/03
 Collection Date: 01/29/03
 Date Received: 01/30/03
 Matrix: Drinking Water

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
VOLATILE ORGANIC COMPOUNDS							
Surr: p-Bromofluorobenzene	97.6	%REC		80-120		E524.2	01/31/03 23:02 / rh
Surr: Toluene-d8	104	%REC		80-120		E524.2	01/31/03 23:02 / rh
SYNTHETIC ORGANIC COMPOUNDS							
1,2-Dibromo-3-chloropropane	ND	ug/L		0.02	0.2	E504.1	02/05/03 15:47 / rlo
1,2-Dibromoethane	ND	ug/L		0.01	0.05	E504.1	02/05/03 15:47 / rlo
Surr: 1,1,1,2-Tetrachloroethane	96.0	%REC			70-130	E504.1	02/05/03 15:47 / rlo
Alachlor	ND	ug/L		0.20	2	E505	02/06/03 01:36 / rlo
Aldrin	ND	ug/L		0.010		E505	02/06/03 01:36 / rlo
Chlordane	ND	ug/L		0.20	2	E505	02/06/03 01:36 / rlo
Dieldrin	ND	ug/L		0.10		E505	02/06/03 01:36 / rlo
Endrin	ND	ug/L		0.010	2	E505	02/06/03 01:36 / rlo
gamma-BHC (Lindane)	ND	ug/L		0.020	0.2	E505	02/06/03 01:36 / rlo
Heptachlor	ND	ug/L		0.040	0.4	E505	02/06/03 01:36 / rlo
Heptachlor epoxide	ND	ug/L		0.020	0.2	E505	02/06/03 01:36 / rlo
Hexachlorobenzene	ND	ug/L		0.10	1	E505	02/06/03 01:36 / rlo
Hexachlorocyclopentadiene	ND	ug/L		0.10	50	E505	02/06/03 01:36 / rlo
Methoxychlor	ND	ug/L		0.10	40	E505	02/06/03 01:36 / rlo
Toxaphene	ND	ug/L		1.0	3	E505	02/06/03 01:36 / rlo
PCBs, Total	ND	ug/L		0.50	0.5	E505	02/06/03 01:36 / rlo
Surr: Decachlorobiphenyl	92.8	%REC			60-130	E505	02/06/03 01:36 / rlo
Surr: Tetrachloro-m-xylene	94.6	%REC			70-130	E505	02/06/03 01:36 / rlo
Buffer pH	5.0	s.u.		0.10		E531.1	02/10/03 19:27 / wen
Aldicarb	ND	ug/L		0.50	3	E531.1	02/10/03 19:27 / wen
Aldicarb sulfone	ND	ug/L		0.50	2	E531.1	02/10/03 19:27 / wen
Aldicarb sulfoxide	ND	ug/L		0.50	4	E531.1	02/10/03 19:27 / wen
Carbaryl	ND	ug/L		0.50		E531.1	02/10/03 19:27 / wen
Carbofuran	ND	ug/L		0.50	40	E531.1	02/10/03 19:27 / wen
3-Hydroxycarbofuran	ND	ug/L		0.50		E531.1	02/10/03 19:27 / wen
Methomyl	ND	ug/L		0.50		E531.1	02/10/03 19:27 / wen
Oxamyl	ND	ug/L		0.50	200	E531.1	02/10/03 19:27 / wen
Surr: BDMC	92.1	%REC			70-130	E531.1	02/10/03 19:27 / wen
Glyphosate	ND	ug/L		5.0	700	E547	02/07/03 15:27 / wen
Diquat	ND	ug/L		0.40	20	E549.2	02/18/03 18:37 / wen

Report Definitions: RL - Analyte reporting limit.
 QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Magic Valley Labs Inc
 Project: Baker City
 Lab ID: C03010962-002
 Client Sample ID: Surface Water

Report Date: 03/11/03
 Collection Date: 01/29/03
 Date Received: 01/30/03
 Matrix: Aqueous

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
METALS - TOTAL							
Sodium	2.1	mg/L		1.0		E200.7	02/05/03 13:16 / cp
INORGANIC COMPOUNDS							
Aluminum	0.0489	mg/L		0.0001	0.2	E200.8	02/05/03 22:20 / smd
Antimony	ND	mg/L		0.001	0.006	E200.8	02/05/03 22:20 / smd
Arsenic	ND	mg/L		0.005	0.01	E200.8	02/05/03 22:20 / smd
Barium	ND	mg/L		0.1	2	E200.8	02/05/03 22:20 / smd
Beryllium	ND	mg/L		0.0005	0.004	E200.8	02/05/03 22:20 / smd
Cadmium	ND	mg/L		0.0005	0.005	E200.8	02/05/03 22:20 / smd
Chromium	ND	mg/L		0.05	0.1	E200.8	02/05/03 22:20 / smd
Copper	0.02	mg/L		0.01	1.3	E200.8	02/05/03 22:20 / smd
Lead	ND	mg/L		0.001	0.015	E200.8	02/05/03 22:20 / smd
Mercury	ND	mg/L		0.0005	0.002	E200.8	02/05/03 22:20 / smd
Nickel	ND	mg/L		0.02	0.1	E200.8	02/05/03 22:20 / smd
Selenium	ND	mg/L		0.005	0.05	E200.8	02/05/03 22:20 / smd
Silver	ND	mg/L		0.0009	0.05	E200.8	02/05/03 22:20 / smd
Thallium	ND	mg/L		0.0004	0.002	E200.8	02/05/03 22:20 / smd

Report Definitions: RL - Analyte reporting limit.
 QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.

TRACKING NO. PAGE NO.
 010962R0004



LABORATORY ANALYTICAL REPORT

Client: Magic Valley Labs Inc
 Project: Baker City
 Lab ID: C03010962-003
 Client Sample ID: Trip Blank

Report Date: 03/11/03
 Collection Date: 01/09/03 12:00
 Date Received: 01/30/03
 Matrix: Aqueous

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
VOLATILE ORGANIC COMPOUNDS							
1,1,1,2-Tetrachloroethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,1,1-Trichloroethane	ND	ug/L		0.50	200	E524.2	01/31/03 17:10 / rh
1,1,2,2-Tetrachloroethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,1,2-Trichloroethane	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
1,1-Dichloroethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,1-Dichloroethene	ND	ug/L		0.50	7	E524.2	01/31/03 17:10 / rh
1,1-Dichloropropene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,2,3-Trichloropropane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,2,4-Trichlorobenzene	ND	ug/L		0.50	70	E524.2	01/31/03 17:10 / rh
1,2,4-Trimethylbenzene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,2-Dichlorobenzene	ND	ug/L		0.50	600	E524.2	01/31/03 17:10 / rh
1,2-Dichloroethane	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
1,2-Dichloropropane	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
1,3-Dichlorobenzene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,3-Dichloropropane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
1,4-Dichlorobenzene	ND	ug/L		0.50	75	E524.2	01/31/03 17:10 / rh
2,2-Dichloropropane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
2-Chlorotoluene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
4-Chlorotoluene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Benzene	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
Bromobenzene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Bromodichloromethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Bromoform	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Bromomethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Carbon tetrachloride	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
Chlorobenzene	ND	ug/L		0.50	100	E524.2	01/31/03 17:10 / rh
Chlorodibromomethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Chloroethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Chloroform	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Chloromethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
cis-1,2-Dichloroethene	ND	ug/L		0.50	70	E524.2	01/31/03 17:10 / rh
cis-1,3-Dichloropropene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Dibromomethane	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Ethylbenzene	ND	ug/L		0.50	700	E524.2	01/31/03 17:10 / rh
Methylene chloride	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
Styrene	ND	ug/L		0.50	100	E524.2	01/31/03 17:10 / rh
Tetrachloroethene	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
Toluene	ND	ug/L		0.50	1000	E524.2	01/31/03 17:10 / rh

Report Definitions: RL - Analyte reporting limit.
 QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Magic Valley Labs Inc
Project: Baker City
Lab ID: C03010962-003
Client Sample ID: Trip Blank

Report Date: 03/11/03
Collection Date: 01/09/03 12:00
Date Received: 01/30/03
Matrix: Aqueous

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
VOLATILE ORGANIC COMPOUNDS							
trans-1,2-Dichloroethene	ND	ug/L		0.50	100	E524.2	01/31/03 17:10 / rh
trans-1,3-Dichloropropene	ND	ug/L		0.50		E524.2	01/31/03 17:10 / rh
Trichloroethene	ND	ug/L		0.50	5	E524.2	01/31/03 17:10 / rh
Vinyl chloride	ND	ug/L		0.50	2	E524.2	01/31/03 17:10 / rh
Xylenes, Total	ND	ug/L		1.0	10000	E524.2	01/31/03 17:10 / rh
Trihalomethanes, Total	ND	ug/L		2.0	80	E524.2	01/31/03 17:10 / rh
Surr: Dibromofluoromethane	103	%REC			70-130	E524.2	01/31/03 17:10 / rh
Surr: p-Bromofluorobenzene	98.9	%REC			80-120	E524.2	01/31/03 17:10 / rh
Surr: Toluene-d8	104	%REC			80-120	E524.2	01/31/03 17:10 / rh

Report Definitions: RL - Analyte reporting limit.
QCL - Quality control limit.

MCL - Maximum contaminant level.
ND - Not detected at the reporting limit.



QA/QC Summary Report

Client: Magic Valley Labs Inc
 Project: Baker City

Report Date: 03/11/03
 Work Order: C03010962

Analyte	Result	Units	RL	%REC	Low Limit	High Limit	RPD	RPDLimit	Qual
Method: A4500-F C							Batch: O-020303-2		
Sample ID: DI-BLANK	Method Blank								02/03/03 13:47
Fluoride	ND	mg/L	0.100						
Sample ID: C03010931-006A	Matrix Spike								02/03/03 13:56
Fluoride	1.60	mg/L	0.100	106	90	110			
Sample ID: C03010931-006A	Matrix Spike Duplicate								02/03/03 14:00
Fluoride	1.58	mg/L	0.100	104	90	110	1.3	10	
Method: D5072-92							Batch: R18599		
Sample ID: C03010962-001JDUP	Sample Duplicate								01/31/03 17:05
Radon 222	483	pCi/L	100				3.8	30	
Sample ID: MB-R18599	Method Blank								01/31/03 17:05
Radon 222	ND	pCi/L	100						
Method: E200.7							Batch: R18662		
Sample ID: C03010813-001DMS1	Matrix Spike								02/05/03 10:32
Sodium	81	mg/L	1.0	87.4	80	120			
Sample ID: C03010813-001DMSD1	Matrix Spike Duplicate								02/05/03 10:41
Sodium	90	mg/L	1.0	106	80	120	11	20	
Sample ID: C03010955-001CMS1	Matrix Spike								02/05/03 12:29
Sodium	538	mg/L	1.00	106	80	120			
Sample ID: C03010955-001CMSD1	Matrix Spike Duplicate								02/05/03 12:38
Sodium	524	mg/L	1.00	104	80	120	2.6	20	

Qualifiers: ND - Not Detected at the Reporting Limit
 R - RPD outside of recommended recovery limits

S - Spike Recovery outside of recommended recovery limits

TRACKING NO. PAGE NO.

010962R0007



QA/QC Summary Report

Client: Magic Valley Labs Inc
 Project: Baker City

Report Date: 03/11/03
 Work Order: C03010962

Analyte	Result	Units	RL	%REC	Low Limit	High Limit	RPD	RPDLimit	Qual	
Method: E200.8							Batch: ICPMS1-C020503a			
Sample ID: LRB		Method Blank			02/05/03 17:05					
Aluminum	ND	mg/L	0.00100							
Antimony	ND	mg/L	0.00100							
Arsenic	ND	mg/L	0.00100							
Barium	ND	mg/L	0.00100							
Beryllium	ND	mg/L	0.00100							
Cadmium	ND	mg/L	0.00100							
Chromium	ND	mg/L	0.00100							
Copper	ND	mg/L	0.00100							
Lead	ND	mg/L	0.00100							
Mercury	ND	mg/L	0.00100							
Nickel	ND	mg/L	0.00100							
Selenium	0.00119	mg/L	0.00100							
Silver	ND	mg/L	0.00100							
Thallium	ND	mg/L	0.00100							
Sample ID: C03010881-001AMS		Matrix Spike			02/05/03 19:00					
Aluminum	0.0661	mg/L	0.00100	107	70	130				
Antimony	0.0541	mg/L	0.00100	108	70	130				
Arsenic	0.0582	mg/L	0.00100	109	70	130				
Barium	0.274	mg/L	0.00100	113	70	130				
Beryllium	0.0586	mg/L	0.00100	117	70	130				
Cadmium	0.0539	mg/L	0.00100	108	70	130				
Chromium	0.0503	mg/L	0.00100	98.8	70	130				
Copper	0.0543	mg/L	0.00100	107	70	130				
Lead	0.0528	mg/L	0.00100	105	70	130				
Mercury	0.00507	mg/L	0.00100	101	70	130				
Nickel	0.0584	mg/L	0.00100	111	70	130				
Selenium	0.0803	mg/L	0.00100	111	70	130				
Silver	0.0191	mg/L	0.00100	95.3	70	130				
Thallium	0.0520	mg/L	0.00100	104	70	130				
Sample ID: C03010881-001AMS		Matrix Spike Duplicate			02/05/03 19:06					
Aluminum	0.0657	mg/L	0.00100	106	70	130	0.6	20		
Antimony	0.0537	mg/L	0.00100	107	70	130	0.6	20		
Arsenic	0.0574	mg/L	0.00100	107	70	130	1.5	20		
Barium	0.278	mg/L	0.00100	120	70	130	1.3	20		
Beryllium	0.0573	mg/L	0.00100	115	70	130	2.3	20		
Cadmium	0.0522	mg/L	0.00100	104	70	130	3.2	20		
Chromium	0.0495	mg/L	0.00100	97.3	70	130	1.5	20		
Copper	0.0537	mg/L	0.00100	106	70	130	1.1	20		
Lead	0.0516	mg/L	0.00100	102	70	130	2.4	20		
Mercury	0.00510	mg/L	0.00100	102	70	130	0.7	20		
Nickel	0.0585	mg/L	0.00100	112	70	130	0.2	20		

Qualifiers: ND - Not Detected at the Reporting Limit
 R - RPD outside of recommended recovery limits

S - Spike Recovery outside of recommended recovery limits

TRACKING NO. PAGE NO.

010962R0008



QA/QC Summary Report

Client: Magic Valley Labs Inc
 Project: Baker City

Report Date: 03/11/03
 Work Order: C03010962

Analyte	Result	Units	RL	%REC	Low Limit	High Limit	RPD	RPDLimit	Qual
Method: E200.8							Batch: ICPMS1-C020503a		
Sample ID: C03010881-001AMSD	Matrix Spike Duplicate %								02/05/03 19:06
Selenium	0.0587	mg/L	0.00100	107	70	130	2.6	20	
Silver	0.0175	mg/L	0.00100	87.6	70	130	8.4	20	
Thallium	0.0526	mg/L	0.00100	105	70	130	1.0	20	
Method: E504.1							Batch: 2889		
Sample ID: MB-2889	Method Blank								02/05/03 09:55
1,2-Dibromo-3-chloropropane	ND	ug/L	0.0200						
1,2-Dibromoethane	ND	ug/L	0.0100						
Surr: 1,1,1,2-Tetrachloroethane			0.0200	98	70	130			
Sample ID: C03010962-001G	Matrix Spike								02/05/03 16:55
1,2-Dibromo-3-chloropropane	0.221	ug/L	0.0200	88.4	65	135			
1,2-Dibromoethane	0.237	ug/L	0.0100	94.8	65	135			
Surr: 1,1,1,2-Tetrachloroethane			0.0200	99	70	130			
Sample ID: C03010997-001H	Matrix Spike								02/05/03 17:31
1,2-Dibromo-3-chloropropane	0.227	ug/L	0.0200	90.8	65	135			
1,2-Dibromoethane	0.232	ug/L	0.0100	92.8	65	135			
Surr: 1,1,1,2-Tetrachloroethane			0.0200	99	70	130			

Qualifiers: ND - Not Detected at the Reporting Limit
 R - RPD outside of recommended recovery limits

S - Spike Recovery outside of recommended recovery limits

TRACKING NO. PAGE NO.

010962R00000



QA/QC Summary Report

Client: Magic Valley Labs Inc
 Project: Baker City

Report Date: 03/11/03
 Work Order: C03010962

Analyte	Result	Units	RL	%REC	Low Limit	High Limit	RPD	RPDLimit	Qual
Method: E505 Batch: 2890									
Sample ID: MB-2890	Method Blank								02/05/03 18:36
Alachlor	ND	ug/L	0.200						
Aldrin	ND	ug/L	0.0100						
Chlordane	ND	ug/L	0.200						
Dieldrin	ND	ug/L	0.100						
Endrin	ND	ug/L	0.0100						
gamma-BHC (Lindane)	ND	ug/L	0.0200						
Heptachlor	ND	ug/L	0.0400						
Heptachlor epoxide	ND	ug/L	0.0200						
Hexachlorobenzene	ND	ug/L	0.100						
Hexachlorocyclopentadiene	ND	ug/L	0.100						
Methoxychlor	ND	ug/L	0.100						
Toxaphene	ND	ug/L	1.00						
PCBs, Total	ND	ug/L	0.500						
Surr: Decachlorobiphenyl			0.100	96.6	60	130			
Surr: Tetrachloro-m-xylene			0.100	94.4	70	130			
Sample ID: C03010962-001G 02/06/03 03:00									
Matrix Spike									
Alachlor	3.10	ug/L	0.200	124	65	135			
Aldrin	0.255	ug/L	0.0100	102	80	140			
Dieldrin	0.285	ug/L	0.100	114	65	135			
Endrin	0.288	ug/L	0.0100	115	65	135			
gamma-BHC (Lindane)	0.276	ug/L	0.0200	110	75	135			
Heptachlor	0.281	ug/L	0.0400	112	75	135			
Heptachlor epoxide	0.248	ug/L	0.0200	99.2	65	135			
Hexachlorobenzene	0.308	ug/L	0.100	123	65	135			
Hexachlorocyclopentadiene	0.359	ug/L	0.100	144	65	135			S
Methoxychlor	1.33	ug/L	0.100	106	65	125			
Surr: Decachlorobiphenyl			0.100	108	60	130			
Surr: Tetrachloro-m-xylene			0.100	115	70	130			
- HCCPD and Simazine were slightly over range. Since the samples affected had no reportable responses for the analytes and the batch has an acceptable alternate MS result, this batch was approved.									
Sample ID: C03010997-001I 02/06/03 03:42									
Matrix Spike									
Alachlor	2.59	ug/L	0.200	104	65	135			
Aldrin	0.180	ug/L	0.0100	72	70	130			
Dieldrin	0.232	ug/L	0.100	92.8	65	135			
Endrin	0.239	ug/L	0.0100	95.6	65	135			
gamma-BHC (Lindane)	0.244	ug/L	0.0200	97.6	75	135			
Heptachlor	0.207	ug/L	0.0400	82.8	75	135			
Heptachlor epoxide	0.220	ug/L	0.0200	88	65	135			
Hexachlorobenzene	0.235	ug/L	0.100	94	65	135			
Hexachlorocyclopentadiene	0.329	ug/L	0.100	132	65	135			
Methoxychlor	1.03	ug/L	0.100	82.7	65	125			
Surr: Decachlorobiphenyl			0.100	90.8	60	130			

Qualifiers: ND - Not Detected at the Reporting Limit
 R - RPD outside of recommended recovery limits

S - Spike Recovery outside of recommended recovery limits

TRACKING NO. PAGE NO.

01005280010



ENERGY LABORATORIES, INC. • 2393 Salt Creek Highway (82601) • P.O. Box 3258 • Casper, WY 82602
Toll Free 888.235.0515 • 307.235.0515 • Fax 307.234.1639 • casper@energylab.com • www.energylab.com

QA/QC Summary Report

Client: Magic Valley Labs Inc
Project: Baker City

Report Date: 03/11/03
Work Order: C03010962

Analyte	Result	Units	RL	%REC	Low Limit	High Limit	RPD	RPDLimit	Qual
Method: E505									Batch: 2890
Sample ID: C03010997-0011	Matrix Spike								02/06/03 03:42
Surr: Tetrachloro-m-xylene			0.100	86.6	70	130			

Qualifiers: ND - Not Detected at the Reporting Limit
R - RPD outside of recommended recovery limits

S - Spike Recovery outside of recommended recovery limits



Environmental Health Laboratories
The Nation's Drinking Water Laboratory

110 S. Hill Street
South Bend, IN 46617
574.233.4777
800.332.4345
Fax: 574.233.8207
www.ehl.cc

LABORATORY REPORT

Client: Energy Laboratories
Attn: Jim Yocum
P.O. Box 3258
Casper, WY 82602

Report: 845351-54
Priority: Standard Written
Status: Final

Sampling Point: C03010962-001A, 001B, 001E & 001F

Samples Submitted: Four drinking water samples

Copies to: None

Collected: 01/29/03

By: Client

Received: 01/31/03

REPORT SUMMARY

None of the analytes included in the detailed parameter list were detected in the sample submitted for analysis.

Note: Sample containers were provided by the client.

Note: See attached page for additional comments.

Detailed quantitative results are presented on the following page.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call us at 574-233-4777.

Note: This report may not be reproduced, except in full, without written approval from Environmental Health Laboratories (EHL). EHL is accredited by the National Environmental Laboratory Accreditation Program (NELAP).


Reviewed By: Steve Dwyer

Date: 2/17/03

Finalized By: Walt Hayer

TRACKING NO. 010962R0016 Date: 2-18-03 PAGE NO. 1

010962R0016



Sampling Point: C03010962-001A, 001B, 001E & 001F

PARAMETER	SDWA Method	MRL * (ug/L)	Result (ug/L)	MCL (ug/L)	Analysis Date	Lab Number
2,4-D	515.3	0.1	< 0.1	70	02/05/03	845351
Dalapon	515.3	1.0	< 1.0	200	02/05/03	845351
2,4-DB	515.3	2.0	< 2.0	---	02/12/03	845351
Dicamba	515.3	0.1	< 0.1	---	02/05/03	845351
Dichlorprop	515.3	2.0	< 2.0	---	02/05/03	845351
Dinoseb	515.3	0.1	< 0.1	7	02/05/03	845351
Pentachlorophenol	515.3	0.04	< 0.04	1	02/05/03	845351
Picloram	515.3	0.1	< 0.1	500	02/05/03	845351
2,4,5-TP (Silvex)	515.3	0.1	< 0.1	50	02/05/03	845351

Atrazine	525.2	0.1	< 0.1	3	02/06/03	845352
Benzo[a]pyrene	525.2	0.02	< 0.02	0.2	02/06/03	845352
Butachlor	525.2	0.1	< 0.1	---	02/06/03	845352
Butylbenzylphthalate	525.2	1.0	< 1.0	---	02/06/03	845352
Di-n-butylphthalate	525.2	2.0	< 2.1	---	02/06/03	845352
Di(2-ethylhexyl)adipate	525.2	0.6	< 0.6	400	02/06/03	845352
Di(2-ethylhexyl)phthalate	525.2	0.6	< 0.6	6	02/06/03	845352
Diethylphthalate	525.2	1.0	< 1.0	---	02/06/03	845352
Dimethylphthalate	525.2	1.0	< 1.0	---	02/06/03	845352
Metolachlor	525.2	0.1	< 0.1	---	02/06/03	845352
Metribuzin	525.2	0.1	< 0.1	---	02/06/03	845352
Propachlor	525.2	0.1	< 0.1	---	02/06/03	845352
Simazine	525.2	0.07	< 0.07	4	02/06/03	845352

Endothall	548.1	9.0	< 9.0	100	02/06/03	845354
-----------	-------	-----	-------	-----	----------	--------

Bromochloroacetic Acid	552.2	1.0	< 1.0	NA	02/06/03	845353
Dibromoacetic Acid	552.2	1.0	< 1.0	¥	02/06/03	845353
Dichloroacetic Acid	552.2	1.0	< 1.0	¥	02/06/03	845353
Monobromoacetic Acid	552.2	1.0	< 1.0	¥	02/06/03	845353
Monochloroacetic Acid	552.2	2.0	< 2.0	¥	02/06/03	845353
Trichloroacetic Acid	552.2	1.0	< 1.0	¥	02/06/03	845353

NA = Not applicable

¥ MCL for total haloacetic acids(5) is 60 ug/L in Stage I of the D/DBP Rule

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

CHUCK EVERSON
BAKER CITY OF

P.O. BOX 650
BAKER CITY OR 97814

Collection Date 12/11/2002 Received Date 12/11/2002 Location
Collection Time Received Time 6:00 PM RESERVOIR

Sample #	Test / Method Code	Results in mg/L	Date Analyzed	Analyst
301431	BICARBONATE	51	12/11/2002	BE
301432	CARBONATE	<1	12/11/2002	BE
301433	ALKALINITY	51	12/11/2002	BE
301434	CALCIUM	13.4	12/17/2002	RB
301435	CHLORIDE	15	12/12/2002	JK
301436	HARDNESS	34	12/13/2002	RB
301437	MAGNESIUM	2.39	12/17/2002	RB
301438	NITRATE/N SM4500D	0.14	12/12/2002	BE
301439	NITRITE/N SM4500E	<0.002	12/12/2002	JK
3014310	NITRATE/N + NITRITE/N	0.14	12/12/2002	BE

Signature

Report Date: Monday, December 30, 2002

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

3014311	POTASSIUM	<0.5	12/17/2002	RB
3014312	SILICA	.		..
3014313	SODIUM	1.93	12/17/2002	RB
3014314	SULFATE	0.4	12/12/2002	JK
3014315	TDS	50	12/12/2002	JK
3014316	TOC	0.37	12/18/2002	MDM
3014317	TSS EPA160.2	<1	12/12/2002	EB
3014318	ALUMINIUM	<0.10	12/17/2002	JH
3014319	ARSENIC	<0.005	12/13/2002	RB
3014320	DISSOLVED IRON	<0.1	12/14/2002	RB
3014321	IRON	<0.1	12/14/2002	RB
3014322	DISSOLVED MANGANESE	<0.05	12/14/2002	RB
3014323	MANGANESE	<0.05	12/14/2002	RB
3014324	FILTER	*		..
3014325	DIGESTION	*		..

Signature

Report Date: Monday, December 30, 2002

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

CHUCK EVERSON
BAKER CITY OF

P.O. BOX 650
BAKER CITY OR 97814

Sample #	Test / Method Code	Results in mg/L	Date Analyzed	Analyst
301441	BICARBONATE	133	12/11/2002	BE
301442	CARBONATE	<1	12/11/2002	BE
301443	ALKALINITY	133	12/11/2002	BE
301444	CALCIUM	30.8	12/17/2002	RB
301445	CHLORIDE	19	12/12/2002	JK
301446	HARDNESS	205	12/13/2002	RB
301447	MAGNESIUM	18.4	12/17/2002	RB
301448	NITRATE/N SM4500D	0.17	12/12/2002	BE
301449	NITRITE/N SM4500E	<0.002	12/12/2002	JK
3014410	NITRATE/N + NITRITE/N	0.17	12/12/2002	BE

Signature

Report Date: Monday, December 30, 2002

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

3014411	POTASSIUM	1.9	12/17/2002	RB
3014412	SILICA	.		..
3014413	SODIUM	16.3	12/17/2002	RB
3014414	SULFATE	38	12/12/2002	JK
3014415	TDS	179	12/12/2002	JK
3014416	TOC	0.93	12/18/2002	MDM
3014417	TSS EPA160.2	<1	12/12/2002	EB
3014418	ALUMINIUM	<0.10	12/17/2002	JH
3014419	ARSENIC	<0.005	12/13/2002	RB
3014420	DISSOLVED IRON	<0.1	12/14/2002	RB
3014421	IRON	<0.1	12/14/2002	RB
3014422	DISSOLVED MANGANESE	0.11	12/14/2002	RB
3014423	MANGANESE	0.11	12/14/2002	RB
3014424	FILTER	*		..
3014425	DIGESTION	*		..

Signature

Report Date: Monday, December 30, 2002

Magic Valley Labs, Inc. 210 Addison Ave. PO Box 1867 Twin Falls Id 83301

System ID #: 4100073	Entry Point or Source ID:	Source name(s):
Water System BAKER CITY OF		
Address P.O. BOX 650		
City, State, Zip BAKER CITY OR 97814		
Sample Identification		
Sampled at: RESEVOIR WELL	Sampled by: KEN ELLIS	
Date Collected: 10/14/2002	Time collected: 8:10:00 AM	
Date recieved: 10/14/2002	Date analyzed:	
Sample:	Single (Circle appropriate descriptors above)	
Lab sample ID #: 28941	Composite Sample:	

Inorganic Chemicals

Contaminant	Code	MCL mg/l	Analysis mg/l	Method	MDL	Analyst
Antimony Total	1074	0.006	ND	200.9	0.003	Umpqua
Arsenic	1005	0.05	0.006	200.9	0.005	Umpqua
Asbestos	1094	7 MF/l ³				
Barium	1010	2	ND	SM3113B	0.1	Umpqua
Beryllium Total	1075	0.004	ND	200.9	0.0002	Umpqua
Cadmium	1015	0.005	ND	200.9	0.001	Umpqua
Chromium	1020	0.1	ND	200.9	0.02	Umpqua
Cyanide	1024	0.2	ND	SM4500CN	0.02	Umpqua
Fluoride	1025	4.0	0.47	300.1		Umpqua
Lead	1030	0.015	ND	200.9	0.002	Umpqua
Mercury	1035	0.002	ND	245.1	0.001	Umpqua
Nickel	1036		ND	200.9	0.02	Umpqua
Nitrate	1040	10.				
Nitrate-Nitrite	1038	10.				
Nitrite	1041	1.0				
Selenium	1045	0.05	ND	200.9	0.003	Umpqua
Sodium ²	1052		21.0	SM3111B		Umpqua
Sulfate	1055		38.8	300.0		Umpqua
Thallium Total	1085	0.002	ND	200.9	0.001	Umpqua

pH = 7.7
 Conductivity = 334 umho/cm

² Community systems only
³ Million Fibers/liter >10um

Signature / Date: *Ken Ellis* 12-10-02

Magic Valley Labs, Inc. 210 Addison Ave. PO Box 1867 Twin Falls Id 83301

System ID #: 4100073	Entry Point or Source ID:	Source name(s):
Water System BAKER CITY OF		
Address P.O. BOX 650		
City, State, Zip BAKER CITY OR 97814		
Sample Identification		
Sampled at: OLD MOUNTAIN LINE		Sampled by: KEN ELLIS
Date Collected: 10/14/2002		Time collected: 8:30:00 AM
Date recieved: 10/14/2002		Date analyzed:
Sample: Single (Circle appropriate descriptors above)		
Lab sample ID #: 28945		Composite Sample:

Inorganic Chemicals

Contaminant	Code	MCL mg/l	Analysis mg/l	Method	MDL	Analyst
Antimony Total	1074	0.006	ND	200.9	0.003	Umpqua
Arsenic	1005	0.05	ND	200.9	0.005	Umpqua
Asbestos	1094	7 MF/l ¹				
Barium	1010	2	ND	SM3113B	0.1	Umpqua
Beryllium Total	1075	0.004	ND	200.9	0.0002	Umpqua
Cadmium	1015	0.005	ND	200.9	0.001	Umpqua
Chromium	1020	0.1	ND	200.9	0.02	Umpqua
Cyanide	1024	0.2	ND	SM4500CN	0.02	Umpqua
Fluoride	1025	4.0	4.9	300.1		Umpqua
Lead	1030	0.015	ND	200.9	0.002	Umpqua
Mercury	1035	0.002	ND	245.1	0.001	Umpqua
Nickel	1036		ND	200.9	0.02	Umpqua
Nitrate	1040	10.				
Nitrate-Nitrite	1038	10.				
Nitrite	1041	1.0				
Selenium	1045	0.05	ND	200.9	0.003	Umpqua
Sodium ²	1052		2.21	SM3111B		Umpqua
Sulfate	1055		3.85	300.0		Umpqua
Thallium Total	1085	0.002	ND	200.9	0.001	Umpqua

pH = 7.3
Conductivity = 104 umho/cm

² Community systems only
¹ Million Fibers/liter >10um

Signature / Date: *Brenda Ellis* 10-10-02

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

Water System ID #: 4100073	Source ID:	Source name(s):			
Water System BAKER CITY OF					
Address PO BOX 650					
City, State, Zip BAKER CITY OR 97814					
Sample Identification					
Sampled at: RESERVOIR WELL		Sampled by: KEN ELLIS			
Date Collected: 10/14/02		Time collected: 8:10:00AM			
Date received: 10/14/02		Date analyzed: 11/05/02			
Sample Composition:		Single			
Lab sample ID #: 28954		Sample Compositied : No			
UCMR					
Regulated VOCs					
Contaminant	Code	MDL mg/l	Analysis mg/l	Method	Analyst
Perchlorate		4.0	ND	314.0	*Umpqua
DCEPA-mono + di acid		1.0	ND	515.2	
Methyl-tert butyl ether (MTBE)		5.0	ND	524.2	
Nitrobenzene		10.0	ND	524.2	
2,4-Dinitrotoluene		2.0	ND	525.2	
2,6-Dinitrotoluene		2.0	ND	525.2	
Acetochlor		2.0	ND	525.2	
4,4'-DDE		0.8	ND	525.2	
EPTC		1.0	ND	525.2	
Molinate		0.9	ND	525.2	
Terbacil		2.0	ND	525.2	

Ken Ellis 12-10-02

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

Water System ID #: 4100073	Source ID:	Source name(s):			
Water System BAKER CITY OF					
Address P.O. BOX 650					
City, State, Zip BAKER CITY OR 97814					
Sample Identification					
Sampled at: RESERVOIR WELL		Sampled by: KEN ELLIS			
Date Collected: 10/14/2002		Time collected: 8:10:00 AM			
Date received: 10/14/2002		Date analyzed: 11/16/2002			
Sample Composition:		Single			
Lab sample ID #: 28954		Sample Compositied : No			
Volatile Organic Chemicals		MDL for all test = 0.0005			
Regulated VOCs					
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
1,1-Dichloroethylene	2977	0.007	ND	524.2	*Umpqua
1,1,1-Trichloroethane	2981	0.2	ND		
1,1,2-Trichloroethane	2985	0.005	ND		
1,2 Dichloroethane	2980	0.005	ND		
1,2 Dichloropropane	2983	0.005	ND		
1,2,4-Trichlorobenzene	2378	0.07	ND		
Benzene	2990	0.005	ND		
Carbon Tetrachloride	2982	0.005	ND		
Cis-1,2-Dichloroethylene	2380	0.07	ND		
Methylene Chloride	2964	0.005	ND		
Ethylbenzene	2992	0.7	ND		
Chlorobenzene	2989	0.1	ND		
1-2-Dichlorobenzene	2968	0.6	ND		
1-4-Dichlorobenzene	2969	0.075	ND		
Styrene	2996	0.1	ND		
Tetrachloroethylene	2987	0.005	ND		
Toluene	2991	1.0	ND		
Total Xylenes	2955	10.0	ND		
Trans-1,2-Dichloroethylene	2979	0.1	ND		
Trichloroethylene	2984	0.005	ND		

Vinyl Chloride 2976 0.002 ND

Unregulated

Contaminant	Code	Analysis mg/l	Method	Analyst * Unique
1,1-Dichloroethane	2978	ND	524.2	
1,1-Dichloropropene	2410	ND		
1,1,1,2-Tetrachloroethane	2986	ND		
1,1,2,2,-Tetrachloroethane	2988	ND		
1,2,3,-Trichloropropane	2414	ND		
1,3-Dichloropropane	2412	ND		
trans-1,3-Dichloropropene	2224			
Cis-1,3-Dichloropropene	2413			
2,2-Dichloropropane	2416	ND		
Bromobenzene	2993	ND		
Bromodichloromethane	2943	ND		
Bromoform	2942	ND		
Bromomethane	2214	ND		
Chloroethane	2216	ND		
Chloroform	2941	ND		
Chloromethane	2210	ND		
Dibromochloromethane	2944	ND		
Dibromomethane	2408			
1-3-Dichlorobenzene	2967			
2-Chlorotoluene	2965	ND		
4-Chlorotoluene	2966	ND		

BAKER CITY OF 28954

Comments:

Signature / Date:

Brenda Ellis 12-10-02

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

Water System ID #: 4100073	Source ID:	Source name(s):			
Water System BAKER CITY OF					
Address PO BOX 650					
City, State, Zip BAKER CITY OR 97814					
Sample Identification					
Sampled at: OLD MOUNTAIN LINE		Sampled by: KEN ELLIS			
Date Collected: 10/14/02		Time collected: 8:00:00AM			
Date received: 10/14/02		Date analyzed: 11/05/02			
Sample Composition:		Single			
Lab sample ID #: 28953		Sample Compositied : No			
UCMR					
Regulated VOCs					
Contaminant	Code	MDL mg/l	Analysis mg/l	Method	Analyst
Perchlorate		4.0	ND	314.0	*Umpqua
DCPA-mono + di acid		1.0	ND	515.2	
Methyl-tert butyl ether (MTBE)		5.0	ND	524.2	
Nitrobenzene		10.0	ND	524.2	
2,4-Dinitrotoluene		2.0	ND	525.2	
2,6-Dinitrotoluene		2.0	ND	525.2	
Acetochlor		2.0	ND	525.2	
4,4'-DDE		0.8	ND	525.2	
EPTC		1.0	ND	525.2	
Molinate		0.9	ND	525.2	
Terbacil		2.0	ND	525.2	

Brenda Ellis 12-10-02

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

Water System ID #: 4100073	Source ID:	Source name(s):			
Water System BAKER CITY OF					
Address P.O. BOX 650					
City, State, Zip BAKER CITY OR 97814					
Sample Identification					
Sampled at: OLD MOUNTAIN LINE	Sampled by: KEN ELLIS				
Date Collected: 10/14/2002	Time collected: 8:00:00 AM				
Date received: 10/14/2002	Date analyzed: 11/16/2002				
Sample Composition:	Single				
Lab sample ID #: 28953	Sample Compositied : No				
Volatile Organic Chemicals		MDL for all test = 0.0005			
Regulated VOCs					
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
1,1-Dichloroethylene	2977	0.007	ND	524.2	*Umpqua
1,1,1-Trichloroethane	2981	0.2	ND		
1,1,2-Trichloroethane	2985	0.005	ND		
1,2 Dichloroethane	2980	0.005	ND		
1,2 Dichloropropane	2983	0.005	ND		
1,2,4-Trichlorobenzene	2378	0.07	ND		
Benzene	2990	0.005	ND		
Carbon Tetrachloride	2982	0.005	ND		
Cis-1,2-Dichloroethylene	2380	0.07	ND		
Methylene Chloride	2964	0.005	ND		
Ethylbenzene	2992	0.7	ND		
Chlorobenzene	2989	0.1	ND		
1-2-Dichlorobenzene	2968	0.6	ND		
1-4-Dichlorobenzene	2969	0.075	ND		
Styrene	2996	0.1	ND		
Tetrachloroethylene	2987	0.005	ND		
Toluene	2991	1.0	ND		
Total Xylenes	2955	10.0	ND		
Trans-1,2-Dichloroethylene	2979	0.1	ND		
Trichloroethylene	2984	0.005	ND		

Vinyl Chloride	2976	0.002	ND		
Unregulated					
Contaminant	Code	Analysis mg/l	Method	Analyst	
1,1-Dichloroethane	2978	ND	524.2	* Umpqua	
1,1-Dichloropropene	2410	ND			
1,1,1,2-Tetrachloroethane	2986	ND			
1,1,2,2,-Tetrachloroethane	2988	ND			
1,2,3,-Trichloropropane	2414	ND			
1,3-Dichloropropane	2412	ND			
Trans-1,3-Dichloropropene	2224				
Cis-1,3-Dichloropropene	2413				
2,2-Dichloropropane	2416	ND			
Bromobenzene	2993	ND			
Bromodichloromethane	2943	ND			
Bromoform	2942	ND			
Bromomethane	2214	ND			
Chloroethane	2216	ND			
Chloroform	2941	ND			
Chloromethane	2210	ND			
Dibromochloromethane	2944	ND			
Dibromomethane	2408				
1-3-Dichlorobenzene	2967				
2-Chlorotoluene	2965	ND			
4-Chlorotoluene	2966	ND			

BAKER CITY OF 28953

Comments:

Signature / Date: *Brenda Ellis 12-10-02*

H:\chemdata\mcp\mcpresults.vpp 3/16/01

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

Water System ID #: 4100073	Source ID:	Source name(s):			
Water System BAKER CITY OF					
Address P.O. BOX 650					
City, State, Zip BAKER CITY OR 97814					
Sample Identification					
Sampled at: OLD MOUNTAIN LINE		Sampled by: KEN ELLIS			
Date Collected: 10/14/2002		Time collected: 8:30:00 AM			
Date received: 10/14/2002		Date analyzed: 10/23/2002			
Sample Composition:		Single			
Lab sample ID #: 28947		Sample Compositied : No			
Volatile Organic Chemicals		MDL for all test = 0.0005			
Regulated VOCs					
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
1,1-Dichloroethylene	2977	0.007	ND	524.2	*Umpqua
1,1,1-Trichloroethane	2981	0.2	ND		
1,1,2-Trichloroethane	2985	0.005	ND		
1,2 Dichloroethane	2980	0.005	ND		
1,2 Dichloropropane	2983	0.005	ND		
1,2,4-Trichlorobenzene	2378	0.07	ND		
Benzene	2990	0.005	ND		
Carbon Tetrachloride	2982	0.005	ND		
Cis-1,2-Dichloroethylene	2380	0.07	ND		
Methylene Chloride	2964	0.005	ND		
Ethylbenzene	2992	0.7	ND		
Chlorobenzene	2989	0.1	ND		
1,2-Dichlorobenzene	2968	0.6	ND		
1,4-Dichlorobenzene	2969	0.075	ND		
Styrene	2996	0.1	ND		
Tetrachloroethylene	2987	0.005	ND		
Toluene	2991	1.0	ND		
Total Xylenes	2955	10.0	ND		
Trans-1,2-Dichloroethylene	2979	0.1	ND		
Trichloroethylene	2984	0.005	ND		

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

Water System ID #: 4100073	Source ID:	Source name(s):			
Water System BAKER CITY OF					
Address P.O. BOX 650					
City, State, Zip BAKER CITY OR 97814					
Sample Identification					
Sampled at: RESEVOIR WELL		Sampled by: KEN ELLIS			
Date Collected: 10/14/2002		Time collected: 8:10:00 AM			
Date received: 10/14/2002		Date analyzed: 10/23/2002			
Sample Composition:		Single			
Lab sample ID #: 28943		Sample Compositied : No			
Volatile Organic Chemicals		MDL for all test = 0.0005			
Regulated VOCs					
Contaminant	Code	MCL mg/l	Analysis mg/l	Method	Analyst
1,1-Dichloroethylene	2977	0.007	ND	524.2	*Umpqua
1,1,1-Trichloroethane	2981	0.2	ND		
1,1,2-Trichloroethane	2985	0.005	ND		
1,2 Dichloroethane	2980	0.005	ND		
1,2 Dichloropropane	2983	0.005	ND		
1,2,4-Trichlorobenzene	2378	0.07	ND		
Benzene	2990	0.005	ND		
Carbon Tetrachloride	2982	0.005	ND		
Cis-1,2-Dichloroethylene	2380	0.07	ND		
Methylene Chloride	2964	0.005	ND		
Ethylbenzene	2992	0.7	ND		
Chlorobenzene	2989	0.1	ND		
1-2-Dichlorobenzene	2968	0.6	ND		
1-4-Dichlorobenzene	2969	0.075	ND		
Styrene	2996	0.1	ND		
Tetrachloroethylene	2987	0.005	ND		
Toluene	2991	1.0	ND		
Total Xylenes	2955	10.0	ND		
Trans-1,2-Dichloroethylene	2979	0.1	ND		
Trichloroethylene	2984	0.005	ND		

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

System ID #: 4100073	Entry Point or Source ID:	Source name(s):
Water System BAKER CITY OF		
Address P.O. BOX 650		
City, State, Zip BAKER CITY OR 97814		
Sample Identification		
Sampled at: RESEVOIR WELL		Sampled by: KEN ELLIS
Date Collected: 10/14/2002		Time collected: 8:10:00 AM
Date recieved: 10/14/2002		Date analyzed:
Sample Composition:		Single
Lab sample ID #: 28942		Sample Compositied: No

Synthetic Organic Chemicals

Regulated

Contaminant	Code	MCL mg/l	Analysis mg/l	MDL	Method	Analyst
2,4-D	2105	0.07	ND	0.0002	515.1	Umpqua
2,4,5-TP Silvex	2110	0.05	ND	0.0004	515.1	Umpqua
Adipates	2035	0.4	ND	0.001	506	Umpqua
Alachlor (Lasso)	2051	0.002	ND	0.0004	505	Umpqua
Atrazine	2050	0.003	ND	0.0002	507	Umpqua
Benzo(A)Pyrene	2306	0.0002	ND	0.00004	550.1	Umpqua
BHC-gamma (Lindane)	2010	0.0002	ND	0.00002	505	Umpqua
Carbofuran	2046	0.04	ND	0.001	531.1	Umpqua
Chlordane	2959	0.002	ND	0.0004	508	Umpqua
Dalapon	2031	0.2	ND	0.002	515.1	Umpqua
Dibromochloropropane	2931	0.0002	ND	0.00002	504.1	Umpqua
Dinoseb	2041	0.007	ND	0.0004	515.1	Umpqua
Dioxin	2063	3x10 ⁻⁴				
Diquat	2032	0.02	ND	0.004	549.2	Umpqua
Endothall	2033	0.1	ND	0.01	548.1	Umpqua
Endrin	2005	0.002	ND	0.00002	505	Umpqua
Ethylene Dibromide (EDB)	2946	0.00005	ND	0.00001	504.1	Umpqua
Glyphosate	2034	0.7	ND	0.01	547	Umpqua
Heptachlor Epoxide	2067	0.0002	ND	0.00002	505	Umpqua

CORRECTED

Heptachlor	2065	0.0004	ND	0.00004	505	Umpqua
Hexachlorobenzene (HCB)	2274	0.001	ND	0.0001	505	Umpqua
Hexachlorocyclopentadiene	2042	0.05	ND	0.0002	505	Umpqua
Methoxychlor	2015	0.04	ND	0.0002	505	Umpqua
Pentachlorophenol	2326	0.001	ND	0.00008	515.1	Umpqua
Phthalates	2039	0.006	ND	0.002	506	Umpqua
Picloram	2040	0.5	ND	0.0002	515.1	Umpqua
Polychlorinated Biphenyls	2383	0.0005	ND	0.0002	508	Umpqua
Simazine	2037	0.004	ND	0.0001	507	Umpqua
Toxaphene	2020	0.003	ND	0.001	508	Umpqua
Vydate	2036	0.2	ND	0.002	531.1	Umpqua

Unregulated

Contaminant	Code	Analysis mg/l	Method	MDL	Analyst
3-Hydroxycarbofuran	2066	ND	531.1	0.004	Umpqua
Aldicarb	2047	ND	531.1	0.002	Umpqua
Aldicarb Sulfoxide	2043	ND	531.1	0.003	Umpqua
Aldicarb Sulfone	2044	ND	531.1	0.001	Umpqua
Aldrin	2356	ND	505	0.0001	Umpqua
Butachlor	2076	ND	507	0.001	Umpqua
Carbaryl	2021	ND	531.1	0.004	Umpqua
Dicamba	2440	ND	515.1	0.005	Umpqua
Dieldrin	2070	ND	505	0.0001	Umpqua
Methomyl	2022	ND	531.1	0.004	Umpqua
Metolachlor	2045	ND	507	0.002	Umpqua
Metribuzin	2595	ND	507	0.001	Umpqua
Propachlor	2077	ND	507	0.001	Umpqua

BAKER CITY OF 289421

Signature / Date:
Brent Ellis 1-4-03

CORRECTED

Magic Valley Labs, 210 Addison Box 1867, Twin Falls, ID 83301

System ID #: 4100073	Entry Point or Source ID:	Source name(s):
Water System BAKER CITY OF		
Address P.O. BOX 650		
City, State, Zip BAKER CITY OR 97814		
Sample Identification		
Sampled at: OLD MOUNTAIN LINE	Sampled by: KEN ELLIS	
Date Collected: 10/14/2002	Time collected: 8:30:00 AM	
Date received: 10/14/2002	Date analyzed:	
Sample Composition:	Single	
Lab sample ID #: 28946	Sample Compositied: No	

Synthetic Organic Chemicals						
Regulated						
Contaminant	Code	MCL mg/l	Analysis mg/l	MDL	Method	Analyst
2,4-D	2105	0.07	ND	0.0002	515.1	Umpqua
2,4,5-TP Silvex	2110	0.05	ND	0.0004	515.1	Umpqua
Adipates	2035	0.4	ND	0.001	506	Umpqua
Alachlor (Lasso)	2051	0.002	ND	0.0004	505	Umpqua
Atrazine	2050	0.003	ND	0.0002	507	Umpqua
Benzo(A)Pyrene	2306	0.0002	ND	0.00004	550.1	Umpqua
BHC-gamma (Lindane)	2010	0.0002	ND	0.00002	505	Umpqua
Carbofuran	2046	0.04	ND	0.001	531.1	Umpqua
Chlordane	2959	0.002	ND	0.0004	508	Umpqua
Dalapon	2031	0.2	ND	0.002	515.1	Umpqua
Dibromochloropropane	2931	0.0002	ND	0.00002	504.1	Umpqua
Dinoseb	2041	0.007	ND	0.0004	515.1	Umpqua
Dioxin	2063	3x10 ⁻⁸				
Diquat	2032	0.02	ND	0.004	549.2	Umpqua
Endothall	2033	0.1	ND	0.01	548.1	Umpqua
Endrin	2005	0.002	ND	0.00002	505	Umpqua
Ethylene Dibromide (EDB)	2946	0.00005	ND	0.00001	504.1	Umpqua
Glyphosate	2034	0.7	ND	0.01	547	Umpqua
Heptachlor Epoxide	2067	0.0002	ND	0.00002	505	Umpqua

CORRECTED

Heptachlor	2065	0.0004	ND	0.00004	505	Umpqua
Hexachlorobenzene (HCB)	2274	0.001	ND	0.0001	505	Umpqua
Hexachlorocyclopentadiene	2042	0.05	ND	0.0002	505	Umpqua
Methoxychlor	2015	0.04	ND	0.0002	505	Umpqua
Pentachlorophenol	2326	0.001	ND	0.00008	515.1	Umpqua
Phthalates	2039	0.006	ND	0.002	506	Umpqua
Picloram	2040	0.5	ND	0.0002	515.1	Umpqua
Polychlorinated Biphenyls	2383	0.0005	ND	0.0002	508	Umpqua
Simazine	2037	0.004	ND	0.0001	507	Umpqua
Toxaphene	2020	0.003	ND	0.001	508	Umpqua
Vydate	2036	0.2	ND	0.002	531.1	Umpqua

Unregulated

Contaminant	Code	Analysis mg/l	Method	MDL	Analyst
3-Hydroxycarbofuran	2066	ND	531.1	0.004	Umpqua
Aldicarb	2047	ND	531.1	0.002	Umpqua
Aldicarb Sulfoxide	2043	ND	531.1	0.003	Umpqua
Aldicarb Sulfone	2044	ND	531.1	0.001	Umpqua
Aldrin	2356	ND	505	0.0001	Umpqua
Butachlor	2076	ND	507	0.001	Umpqua
Carbaryl	2021	ND	531.1	0.004	Umpqua
Dicamba	2440	ND	515.1	0.005	Umpqua
Dieldrin	2070	ND	505	0.0001	Umpqua
Methomyl	2022	ND	531.1	0.004	Umpqua
Metolachlor	2045	ND	507	0.002	Umpqua
Metribuzin	2595	ND	507	0.001	Umpqua
Propachlor	2077	ND	507	0.001	Umpqua

BAKER CITY OF 289461

Signature / Date:
Brenda Ellis 1-4-03

CORRECTED

Appendix D

Appendix D: ASR Head Buildup/Drawdown Calculations

Appendix D: ASR Head Buildup/Drawdown Calculations

Assumptions

Baker City ASR Head Buildup/Drawdown Calculations

Operational Assumption

General –

- Wintertime (long term) injection event**
- Summer time injection event to offset spilling**
- Target injection volume is 100 MG +**

Wintertime

- **Wintertime injection period: December 1st to April 30th**
- **Assume injection shutdown due to turbidity events. Assume two events at 20 days per event, which is equal to 40 days of no injection**
- **Assume back flushing every 3 weeks (loss of 10 days of injection)**
- **Total days of injection = 100 days**
- **Assume 800 gpm (gallons per minute) for wintertime injection rate.**

Summer Time

- **Summer-time injection period: June 15th to July 30th**
- **Assume shutdown due to turbidity events. Assume two events at 2 days per event, which is equal to 4 days of no injection.**
- **Assume back flushing which will result in 3 days loss of injection**
- **Assume a loss of 10 days during injection due to cycling on and off the clear well.**
- **Total days of injection = 28 days**
- **Assume 1250 gpm for summer-time injection rate**

Pumping

- **Head buildup calculations from year-to-year assume that 100% of the stored water is removed from storage; otherwise the head buildup in the injection well will exceed the ground surface during Year 2 injection.**
- **Pumping rate is 1800 gpm**
 - **Winter-time storage volume is 115 MG, which is equal to a 44 day supply assuming 1800 gpm.**
 - **Summer-time storage volume is 50 MG, which is equal to a 19 day supply assuming 1800 gpm.**

Key Assumption


- *Aquifer characteristics further away from the well are uncertain. We have assumed no negative boundary(s) (e.g., faults that limited the size of the storage), which is based on results of 5-day constant rate test data. As such, we used specific capacity at 100 days based on projection of constant rate test drawdown curve. If the aquifer permeability is lower than estimated, the assumed injection rate of 800 gpm may not be sustainable over the entire injection period (100 days). Options for reducing the injection rate and keeping the pump column full without air include: 1) down-hole control valve, 2) periodically stopping injection to allow head buildup to dissipate, and 3) injecting under pressure in order to maintain a full pipe-column at a lower injection rate.*

Other Conservative Assumptions


- 1) Threshold water level rise in ASR well during injection to be maintained 25 feet below ground surface (bgs).
- 2) Assume back flushing will help control the head buildup due to clogging in the ASR well.
- 3) Assume a 15% reduction in specific capacity between injection and pumping (based on early cycle testing data for the Beaverton Project). Year 2002 data for Beaverton showed little or no reduction between the injection and pumping specific capacity.
- 4) Assume a 15% reduction in injection specific capacity from year-to-year (based on early cycle testing data for Beaverton).
- 5) Assume no reduction in pumping specific capacity from year-to-year.
- 6) Assume a well efficiency of 50%, which is typical for basalt wells (e.g., Hanson Well).
- 7) Water level rise in aquifer will be used to predict seeps. If the water level in the aquifer is less than 177 feet bgs (which was the depth to water when the well was drilled) then assume no likelihood of seeps.
- 8) Specific capacity at 100 days based on constant rate test which was run at 1500 gpm – starting point.
- 9) Change in specific capacity at either higher or lower pumping rates calculated using step test data.
- 10) Wintertime head rise will begin to decay prior to start of summer-time injection. Decay rate calculated based on recovery curve of constant rate test. Trend line and equation fitted to test data to calculate decay rate for greater time span.
- 11) Since there was 6 feet of residual drawdown after the constant rate test, assume that all of the water pumped was taken out of storage.
- 12) Assume summer-time injection specific capacity is 30% lower than wintertime injection specific capacity since the aquifer has already been loaded with approximately 100 MG.
- 13) Incorporate turbidity events into the injection cycle.
- 14) Incorporate cycling of the clear well for summer-time injection cycle.

- 15) Head build up for summer injection period starts from where the wintertime head build in injection well ended up minus decay amount (which is 36 feet).
- 16) Assume the head rise in the aquifer is the same from year to year starting from the pre-ASR static water level, which is based on the assumption that 100 percent of stored water is removed. No reduction in aquifer transmissivity beyond the borehole skin.
- 17) Drawdown is based on where the head is after injection and not based on pre-injection static water level.


Baker City Constant Rate Aquifer Test
 Reservoir Well
 1/24/03 - 1/27/03



Baker City Constant Rate Test Recovery
Reservoir Well
1/30/02 - 2/9/03



Baker City Step Test



Estimating Changes in Specific Capacity at different injection/pumping rates

Use Step Test Equation

$$4 \times 10^{-6} Q + 00.86$$

Where $y = s/Q$ ft/gpm

Thus $1/y = Q/s$ gpm/ft (same as Specific Capacity (SC))

Drawdown at different pumping rates from step tests

$$\text{SWL} = 248 \text{ ft bgs}$$

$$500 \text{ gpm} = 253 \text{ ft dd}$$

$$1000 \text{ gpm} = 261 \text{ ft dd}$$

$$1500 \text{ gpm} = 269 \text{ ft dd}$$

$$\text{SC @ 1500 gpm} = 1500/(269-248) = 71.41 \text{ gpm/ft}$$

SC from 1500 gpm to 800 gpm

$$Y = 4 \times 10^{-6} (800 \text{ gpm}) + 0.0086$$

$$Y = 0.0118$$

$$1/y = 84.75 \text{ gpm/ft}$$

SC @ 1500 gpm = 71.42 gpm/ft to SC @ 800 gpm = 84.75 gpm/ft or 19% increase

Assume 20% increase in SC when going from 1500 gpm to 800 gpm

SC from 1500 gpm to 1250 gpm

$$Y = 4 \times 10^{-6} (1250 \text{ gpm}) + 0.0086$$

$$Y = 0.0136$$

$$1/y = 73.52 \text{ gpm/ft}$$

Assume a 3% increase in SC when going from 1500 gpm to 1250 gpm

SC from 1500 gpm to 1800 gpm

$$Y = 4 \times 10^{-6} (1800 \text{ gpm}) + 0.0086$$


$$Y = 0.0158$$

$$1/y = 63.3 \text{ gpm/ft}$$

Assume a 10% reduction in SC when going from 1500 gpm to 1800 gpm

Baker City ASR
Constant Rate Test Recovery
Reservoir 01/30/03

$$y = -3.8987 \ln(x) + 337.45$$



Baker City Head Buildup Calculations -- Winter Time

Assumptions

SWL									SWL bgs
Start Injection			1-Dec	Each year					
Stop Injection			30-Apr	Each year					
Total Days				160	days				
Back flush 20 weeks every 3 weeks 7 days				-10	days				
NTU events greater than 0.5									
2 events at 20 days per				-40	days				
			Total Days	100					days
Assume a 50% well efficiency -- typical for basalt wells									well eff
Volume estimates:									
At 800 gpm	115,200,000	MG							gpm injection rate
At 1300 gpm	187,200,000	MG							gpm injection rate
At 1800 gpm pumping assuming winter and summer time storage of 147 MG						57	days		gpm pumping rate
Maintain head buildup in well at 25 bgs -- threshold									bgs threshold
Assume 800 gpm since target is only 100 MG									gpm injection rate
Constant rate SC @ 1500 gpm at 100 days									gpm/ft
Pumping SC @ 800 gpm at 100 days is 20% greater based on step test data						20%	1.2		gpm/ft
Pumping SC at 1500 at 56 days									gpm/ft
Pumping SC at 1800 at 56 days assuming 15 % reduction based on step test data						-15%			gpm/ft
Injection SC is 15% less than pumping SC						-15%	0.85		gpm/ft
Assume 15% reduction in SC between successive years									15% reduction

Head Buildup Estimates (800 gpm injection rate)

	Inside Well Casing		Outside Borehole In Aquifer		
Year 1	136.40	ft of head buildup			
SC yr 1	5.865	113.60 bgs		181.80 bgs	
Year 2	160.47	ft of head buildup			
SC yr 2	4.99	89.53 bgs		181.80 bgs	Same since water recovered from storage and SC in aquifer is not reduced with each injection cycle
Year 3	188.79	ft of head buildup			
SC yr 3	4.24	61.21 bgs		181.80	Ditto
Year 4	222.11	ft of head buildup			
SC yr 4	3.60	27.89 bgs		181.80	Ditto
Year 5	261.30	ft of head buildup			
SC yr 5	3.06	-11.30 bgs			Head Buildup in Well Above Ground Surface -- Redevelopment Needed

Drawdown Estimates

Pumping rate of 1800 gpm -- prior to summer time injection

	Inside Well Casing		Outside Borehole In Aquifer		
Year 1	327.27	ft drawdown		345.44	bgs
SC yr 1	6.50	440.87 bgs			
Year 2	327.27	ft drawdown		345.44	bgs
SC yr 2	5.50	416.80 bgs	Note: Since Head Building is higher each year the drawdown in the well in terms of bgs is less each year assuming no reduction in pumping SC	345.44	bgs
Year 3	327.27	ft drawdown		345.44	bgs
SC yr 3	5.50	388.48 bgs			
Year 4	327.27	ft drawdown		345.44	bgs
SC yr 4	5.50	355.16 bgs			
Year 5	327.27	ft drawdown		345.44	bgs
SC yr 5	6.50	315.97 bgs			

SC = specific capacity = injection or pumping rate divided by drawup or drawdown = gpm/ft

bgs = below ground surface

SWL = static water level bgs

Baker City Head Buildup Calculations -- Summer Time

Assumptions

Start Injection after one winter injection season					
Start Injection		15-Jun	Each year		
Stop Injection		30-Jul	Each year		
Total Days		45	days		
Back flush 3 times		-3	days		
NTU events greater than 0.5					
	2 events at 2 days per event	-4	days		
Cycling of Clear Well results in lost days		-10			
	Total Days	28		days	
Assume 50% well efficiency which is typical for basalt wells				% well eff	
Volume estimates:					
At 800 gpm	32,256,000	MG		gpm injection rate	
At 1250 gpm	50,400,000	MG		gpm injection rate	
Pumping Rate				gpm pumping	
Maintain head buildup in well at 25 bgs -- threshold				bgs threshold	
Assume 1250 Injection rate per Baker request				gpm injection rate	
Constant rate SC @ 1500 gpm for 30 days				gpm/ft	
Pumping SC @ 1250 gpm for 30 days is 3% greater based on step test data		3%	1.03	gpm/ft	
Pumping SC at 1800 at 56 days assuming 15% reduction based on step test data				gpm/ft	
Summer time injection specific capacity is 30% less due to winter-time loading of aquifer		-30%	0.7	gpm/ft	
Assume 15% reduction in SC between successive years				15% reduction	
Based on recovery curve trend the winter-time head rise will decay 36 ft after 45 days				ft decay of winter-time head rise	

Head Buildup Estimates (1250 gpm Injection rate)

	Inside Well Casing		Outside Borehole in Aquifer	
Year 1	78.80	ft of head buildup		
SC yr 1	15.862	70.79 bgs	142.40	bgs
Year 2	92.71	ft of head buildup		
SC yr 2	13.48	32.82 bgs	142.40	bgs
				Same since water recovered from storage and SC in aquifer is not reduced with each injection cycle
Year 3	109.07	ft of head buildup		
SC yr 3	11.46	-11.86 bgs		Head Buildup in Well Above Ground Surface -- Redevelopment Needed

Drawdown Estimates

	Inside Well Casing		Outside Borehole in Aquifer	
Year 1	327.27	ft of drawdown	306.03	bgs
SC yr 1	5.50	398.07 bgs		
				Note: Since Head Building is higher each year the drawdown in the well in terms of bgs is less each year assuming no reduction in pumping SC
Year 2	327.27	ft of drawdown	306.03	bgs
SC yr 2	5.50	360.09 bgs		Same since water recovered from storage and SC in aquifer is not reduced with each injection cycle
Year 3	327.27	ft of drawdown	306.03	bgs
SC yr 3	5.50	315.41 bgs		

SC = specific capacity = injection or pumping rate divided by drawup or drawdown = gpm/ft
 bgs = below ground surface

Baker City Storage Volume Estimate

Volume removed during constant rate test @ 1500 gpm for 5 days

Volume = 10,800,000

SWL 1977	177 bgs
SWL 2003	250 bgs
Difference	73

Residual Recovery 6 ft
(see recovery curve)

Assuming all water pumped during constant rate test was from storage

Gallons per foot of residual drawdown 1,800,000

Assume that there is 73 feet of available head room in the aquifer to allow the water level to rise to the 1977 level and assume that the 1977 SWL is in equilibrium with the system with no anomalies.

Thus: 73 X ^{1.8}3.6 MG 131,400,000

Available storage volume based on
1977 SWL levels 131.4 MG

Appendix E: Phase 2 ASR Pilot Project Scope of Work

Appendix E

Phase 2 Aquifer Storage and Recovery Pilot Project

If the City chooses to move forward with the ASR project based on the findings from the feasibility study, an ASR pilot project will be conducted as required by the OWRD ASR rules. The project will include permitting the well according to State ASR regulations and will include completing an ASR pilot test under an ASR limited license. The following specific scope of services will be provided.

Task 1 – Permitting. Meet with the Oregon Water Resources Department (OWRD) to discuss the City's plans for implementing ASR. Discuss with OWRD any concerns they may have with the program to make sure there are no fatal flaws prior to proceeding. Prepare an ASR limited license application on behalf of the City and submit it to OWRD. Follow-up with OWRD to ensure a limited license is issued for the project. We assume that the City will be intimately involved in this task and that GSI will provide support in agency meetings and that GSI will prepare the limited license application. Dick Fleming will be task lead.

Task 2 – ASR Design and Bidding. AP will prepare plans and specifications for retrofitting the well and will prepare a bid document that the City can use to solicit bids from qualified contractors for retrofitting the ASR well. We will work closely with the City during the design phase to be sure that the system equipment, controls and operation meet expectations. Because the well cannot be out-of-service for an extended period of time, the work must be well planned; this will be accomplished through frequent communications with the City, the selected contractor and the GSI-AP team. An evaluation of the best way to control injection will be performed. Methods that will be evaluated include injection through the pump bowls and the use of a down-hole control valve. In most cases, injection through the pump bowls is preferred due to the high cost and complexity of down-hole control valves. The recharge source water will come from the reservoir via a new booster pump. The booster pump will permit the City to recharge at a constant rate whenever there is additional capacity in the system. The injection system will be controlled via telemetry using the level in the reservoir, which will eliminate the need to spill excess water delivered from the watershed. The design will include a pump to waste system for wastewater generated during pump startup and periodic back flushing episodes. A SCADA system will be developed to allow the City to remotely monitor (including City Hall) and data log important operating characteristics of the ASR system. These operating characteristics will include reservoir level, flow rate, injection/recovery volume, turbidity, well water level, temperature, and alarm status. AP will provide the general conditions and technical specifications for the contract documents. The City will bid, advertise and manage the retrofit of the ASR well; AP will be involved in bid evaluation and will be available to answer technical questions related to the retrofit. Because this is a municipal water system, the Oregon Health Division must approve plans for the ASR system. If desired by the City, we would also be willing to discuss doing the ASR design and construction as a turnkey project utilizing Ed Butts and Stettler Supply as the ASR system construction contractor. Robin Harris and Jess Holt of AP will lead this task.

Task 3 – ASR Work Plan. GSI will prepare an ASR Work Plan and submit it to OWRD for approval following City review and acceptance. The work plan will present a groundwater monitoring plan, water quality sampling plan, ASR pilot testing plan, and ASR system design. GSI will address agency comments on the work plan. Jeff Barry of GSI will be task lead.

Task 4 – ASR Pilot Testing. Complete a pilot test program based on the approved ASR work plan. The pilot test program will consist of a short-term (1 week) injection and recovery test followed by an extended injection period (4 to 6 months depending upon available recharge water supply and

turbidity levels). Well efficiency will be monitored closely during injection (utilizing water level and injection rate data) to determine the rate of clogging and to identify when back flushing should occur in order to remove sediment introduced during injection. Beginning in June or July, the well will be pumped to recover the stored water. Prior to introduction of the water to the City's system, a water sample will be collected to confirm that it meets all drinking water standards and that it has acceptable taste and odor. Additional water samples will be collected periodically during recovery to assess water quality changes. The testing program will last approximately one year. As a cost saving measure, we have assumed that the City will collect the majority of the field data with support from GSI and local AP staff. Jeff Barry of GSI will be task lead with support from Larry Eaton. Specific work elements include the following:

- 1) GSI will install dataloggers and direct collection of base line groundwater elevation data by City staff prior to ASR testing.
- 2) AP will assist the City during initial injection and recovery startup and testing to make sure that the system is functioning properly.
- 3) GSI will direct monitoring of the injection well and up to three groundwater wells during ASR testing based on the approved ASR Work Plan. City staff will collect the water level and injection/pumping rate data. Periodically, local AP staff will download dataloggers and forward the data to GSI. The City will collect water quality samples according to the ASR work plan and ship them to the laboratory for testing. GSI will evaluate the data and enter it into a project database.
- 4) GSI will analyze the water level and water quality data and present bi-weekly updates to the City during the injection phase of the ASR pilot test program. GSI will recommend when the City should perform back flushing.

Task 5 – ASR Analysis and Report. We will complete a review of the ASR pilot study and determine if the project is feasible and whether or not the City should apply for an ASR Permit for full-scale operation. Treatment requirements will be evaluated. A realistic ASR expansion plan will be provided that includes preliminary engineering cost estimates and cost/benefits and associated risk of adding additional ASR wells to the system. This analysis will include a review of how an expanded ASR system can be beneficially incorporated into the City's existing water supply system. Pilot testing results will be presented in a final ASR report and submitted to the City and OWRD for review. Jeff Barry of GSI will be task lead.

Task 6 – ASR Operations Plan. We will develop an ASR operational plan that the City staff can use to run the ASR system. The plan will include target injection and pumping rates, injection and recovery schedule, recharge turbidity criteria, injection efficiency monitoring, recommended back flushing frequency, and injection startup, injection shutdown, and pumping startup procedures. We have assumed City involvement in this task to ensure that the operational plan meets the City's expectations and that ASR operational protocols fit well with the City's current water supply operational plan. Jeff Barry and Robin Harris will collaborate with the City on this task.

Appendix F: ASR Process Narrative (Stettler Supply Company)

City of Baker City Oregon

Well #1 ASR Program

Process Narrative

Introduction: The Aquifer Storage and Recovery (ASR) system contemplated for the Baker City Well #1 will consist of two individual and separate operations: 1) Recharging, and 2) Withdrawal. The control and safety functions for each operation will utilize equipment with parallel capability, when possible, to simplify the system and avoid duplication of cost and/or control function. The following narratives outline the preliminary concept of operational and safety functions for each operation:

Recharging

Recharge operation will consist of extraction of potable and treated water from the chlorine contact chamber through use of a new booster pump. This water will be diverted to Well #1 via a new 10" buried recharge line to be installed from the proposed booster pump location to Well #1. Water will be delivered into the well and aquifer by direct discharge through a series of control valves and ultimately down the column, through the bowl assembly and pump inlet, and into the well. Adequate pressure to prevent cascading or air entrainment will be accomplished through wellhead pressure developed through a combination of the booster pump, gravity head developed from the wellhead down to the standing water level in the well, and frictional losses developed from the column/lineshaft and the bowl assembly. Flow control will be the primary control threshold with safety overrides capable of disabling the system at any time. The system is intended to be controlled as a manual operation with automatic safety overrides.

Control: The following control functions, in the order listed, will operate the recharge process:

Beginning Status: All pumps off---valving and control logic in normal operational position for withdrawal---Safeties in normal configuration---No alarms

Control Valve "A"---open; Control Valve "B"----closed; Control Valve "C"----open

- 1) Operator rotates selector switch to "Recharge" position from "Off" position (Selector switch positions: "Off"----"Recharge"----"Well Pump")
- 2) Operator selects desired recharge rate: 800 GPM-----1500 GPM
- 3) Operator presses "Start" button
- 4) Well pump is immediately "locked out of service"
- 5) Blowoff control valve "C" remains open
- 6) Discharge line control valve "B" remains closed
- 7) Well Discharge valve "A" closes
- 8) Recharge booster pump starts

- 9) Initial recharge water discharged through blowoff for pre-determined interval or until turbidity is within acceptable range.
- 10) Well Discharge control valve "A" opens
- 11) Blowoff control valve "C" closes
- 12) Booster pump operates at full rate until column is filled
- 13) Pressure sensor on well discharge line reports adequate recharge pressure at wellhead
- 14) Booster pump, via variable frequency drive, lowers flow rate and controls flow rate at selected rate after receipt of appropriate signal from pressure sensor using analog comparator from flowmeter.

<Normal shutdown sequence>

- 1) Operator returns selector switch to "Off" position
- 2) Control valve "C" opens
- 3) Booster pump shuts down
- 4) Control valve "B" remains closed

<system now at normal "off" state>

Control: The following controls will regulate the recharge process:

- 1) Flowmeter-----Controls preselected recharge flow rate via analog feedback
- 2) Analog pressure sensor-----Insures maintenance of adequate wellhead pressure during recharge
- 3) Variable Frequency Drive-----Modulates motor speed to regulate and maintain pre-determined recharge flow rate.

Safety Overrides: The following safety controls will immediately shutdown the recharge process

- 1) Analog pressure sensor: Will shutdown and lockout the recharge process should wellhead pressure fall below 10 psi or above 100 psi - "Alarm output"
- 2) Flowmeter: Will shutdown and lockout the recharge process should recharge flow vary more than 20% above or below the selected flow rate.-----
"Alarm output"
- 3) Turbidity: Will send alarm (but not shutdown) should turbidity rise above selected value.---"Alarm output"
- 4) Power failure: System will not restart until manually restarted "Alarm output"
- 5) Well water level—Will send alarm (but not shutdown system) should water level in well exceed or fall below predetermined levels.
- 6) Valve failure: Any valve that fails to operate (open or close) to it's required location will result in system shutdown via microswitches-- "Alarm output"

Withdrawal

Normal operation of the well will not differ appreciably from the current operation, except for operation of the control valves and a predetermined blowoff period. Well operation will be based on normal withdrawal of water from the existing well using a new vertical turbine pump (which will also be used for recharge purposes). Operation of the well pump is also intended to be a manual operation with appropriate operational and safety controls.

Control: The following functions, in the order listed, will control normal well pump operation:

Beginning status: All pumps "off"----Valving and controls in normal withdrawal position----All safeties in normal configuration----No alarms

Control Valve "A"---open; Control Valve "B"-----closed; Control Valve "C"----open

- 1) Operator rotates selector switch to "Well Pump" from "Off" position
- 2) Operator presses "Start" button
- 3) Pre-lube injection valve opens and prelubricates lineshaft bearings for 10-15 minutes.
- 4) At end of prelube interval, well pump starts and delivers water to surface
- 5) Initial water from well discharges through Control Valve "C" for predetermined period.
- 6) Control valve "B" opens
- 7) Control valve "C" closes
- 8) Well pump delivers water to system

<Normal Shutdown Sequence>

- 1) Operator returns selector switch to "Off" position
- 2) Control valve "C" opens
- 3) Control valve "B" closes
- 4) Pump and motor shutdown occurs when control valve "C" is fully open


<System is now at normal "Off" state>

Safety Functions: The following safety controls will shutdown the well pump operation:

- 1) Analog pressure sensor: Will shutdown and lockout the well pump should operating pressure fall below or rise above predetermined levels—"Alarm output"
- 2) Flowmeter: Well pump will shutdown if analog signal is not received at adequate levels to PLC, indicates broken shaft—"Alarm output"
- 3) Power failure: System will not restart until manually restarted-"Alarm output"

- 4) Valve failure: Any valve that fails to operate to it's required location (open or closed) will prompt shutdown and lockout of system—"Alarm output"
- 5) Well water level: Water level below predetermined level (10'-20' above the bowl intake) will prompt shutdown and lockout of pump----"Alarm output"

BAKER CITY WELL #1 FOR GSI



SCHEMATIC
N.T.S.

 10" BUTTERFLY VALVE W/
ELECTRIC ACTUATOR &
AUX. LIMIT SWITCHES
(OPEN/CLOSED)

 FLOW DIRECTION

STETTLER COMPANY

1810 LANA AVENUE NE
SALEM, OREGON 97303
(503) 585-5550

DATE: 11-18-02