



WATERMASTER APPLICATION REVIEW

Application #:

Applicant's Name:

- 1) Would the proposed allocation have the potential for injury to existing rights?
 Yes No

- 2) If the proposed allocation will cause injury, can it be conditioned to avoid injury?
 Yes No If Yes, please list conditions:

- 3) Have you spoken with persons from other state agencies about this application?
 Yes No If yes, whom and why?

- 4) Please select the appropriate measurement, recording and reporting condition for this application. See #5 Below for explanation
 Small < 0.1 CFS, < 9.2 AF
 Medium > 0.1 CFS but < 0.25 CFS, > 9.2 AF but < 100 AF
 Large > 0.25 CFS, > 100 AF
 Require a staff gage if source is runoff or if the reservoir is located in-channel.
 Require an in-line flow restrictor.

- 5) Please provide any additional information or conditions that you believe are necessary for this application.
No measurement device is needed. The water level can be measured in the center of the dam at the trickle tube. It has stop logs in it and is easily accessible. For this reason no other measuring device would be needed or helpful.

Watermaster Name:

Watermaster Signature:

Date:

WRD Caseworker:

Ph: 503-986-0900/ Fax: 503-986-0901