



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

June 18, 2023

THOMAS R REARDON
REARDON NURSERY INC;
10050 SE 282ND AVE
BORING, OR 97009

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 13898	Permit: G 13476 *	MULT0058958	MULT0058958	01/21/2005	APPROVED	Unreas Burden	MATTHEW'S WELL/WELL 2 (L

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates the requirements were met under OAR 690-217, however; the limitations of the currently installed pump relative to the transmissivity of the aquifer provide little to no drawdown or recovery data useful for ground water resources characterization as was the intent of the rules. It is likely that a new test will yield similar results and therefore the Department has granted an exemption for testing this well on the above listed permit(s).

Please contact me if you have any questions.

Sincerely,

Gabi Ferreira
971-301-3088
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File

