



# Oregon

Tina Kotek, Governor

**Water Resources Department**  
725 Summer St NE, Suite A  
Salem, OR 97301  
(503)986-0900  
Fax (503) 986-0904

September 05, 2023

LINDA ESHRAGHI  
26985 SW FARMINGTON RD  
HILLSBORO, OR 97007

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 16021	Permit: G 15553 *	WASH0055919	WASH0055919	11/09/2022	APPROVED	Multiple Well	WELL 1 (L-38462)
G 16021	Permit: G 15553 *	WASH0064120	WASH0064120	11/10/2022	APPROVED	Unreas Burden	WELL 2 (L-84439)

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates that there are deficiencies (listed below) related to the requirements for pump tests outlined in OAR 690-217; however, it is likely that any re-testing would constitute an unreasonable burden on the permittee and would provide data of only marginal value in satisfying the intent of the rules.

- o Discharge rate varies for WASH 55919
- o No water level measurements submitted for WASH 64120

Although this test is being approved for these wells on the above listed permit(s), it is unlikely that the approval will carry forward onto any new permits or multiple-well exemption requests. If a new permit is issued for this particular well that requires a pump test or if you wish to request a multiple-well exemption on any other wells using this approved test, you may be denied and will need to perform a new test.

Please contact me if you have any questions.

Sincerely,

Gabi Ferreira  
971-375-7623  
Groundwater Section

cc: GW Pump Test File  
cc: Certificates Section/Application File

