



WATERMASTER APPLICATION REVIEW

Application #: G-19006

Applicant's Name: Holland Loop Holdings, LLC

1) Would the proposed allocation have the potential for injury to existing rights?

Yes No

2) Have you spoken with persons from other state agencies about this application?

Yes No If yes, whom and why?

3) Please select the appropriate measurement, recording and reporting condition for this application.

Small < 0.1 CFS, < 9.2 AF

Medium > 0.1 CFS but < 0.25 CFS, > 9.2 AF but < 100 AF

Large > 0.25 CFS, > 100 AF

Require a staff gage if source is runoff or if the reservoir is located in-channel.

4) Please provide any additional information or conditions that you believe are necessary for this application.

Potential to injure instream water right Cert 62325.

No water available at the 80% exceedance for watershed ID# 69810.

See GW Review for additional information.

Require a totalizing flow meter.

Watermaster Name: Scott Ceciliani

Watermaster Signature: **Scott Ceciliani** Digitally signed by Scott Ceciliani
Date: 2023.09.12 09:24:59 -0700

Date: 9/12/2023

WRD Caseworker: Adam Frederick

503-986-0900/ Fax 503-986-0901