



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

December 13, 2023

JAMES WOLFF
35590 SE TRACY RD
ESTACADA, OR 97023

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 15187	Permit: G 15381 *	CLAC0014538	CLAC0014538	09/21/2023	APPROVED	Unreas Burden	WELL 1

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates the requirements were met under OAR 690-217, however; the limitations of the currently installed pump relative to the transmissivity of the aquifer provide little to no drawdown or recovery data useful for ground water resources characterization as was the intent of the rules. It is likely that a new test will yield similar results and therefore the Department has granted an exemption for testing this well on the above listed permit(s).

Please contact me if you have any questions.

Sincerely,

Gabi Ferreira
971-375-7623
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File