



# Oregon

Tina Kotek, Governor

**Water Resources Department**  
725 Summer St NE, Suite A  
Salem, OR 97301  
(503)986-0900  
Fax (503) 986-0904

October 30, 2023

JAMES BOYLE  
14350 MATNEY RD  
KLAMATH FALLS, OR 97603

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 16020	Permit: G 15720 *	KLAM0052830	KLAM0052830	10/30/2019	APPROVED		A WELL (L-50145)

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates that there are one or more deficiencies (listed below) related to the requirements for pump tests outlined in OAR 690-217, however; it is likely that any re-testing would constitute an unreasonable burden on the permittee and would provide data of only marginal value in satisfying the intent of the rules.

- o Water levels were not measured to an accuracy of 0.1 feet.
- o Pre-test static water levels or shut in pressures were not measured at the specified intervals.
- o Water levels or shut in pressures were not measured at the specified time intervals during the test.
- o Water levels or shut in pressures were not measured during the recovery phase of the test.
- o Test data and the supporting documentation were not reported on the Department's forms.

Although this test is being approved for this well on the above listed permit(s), it is unlikely that the approval will carry forward onto any new permits or multiple-well exemption requests. If a new permit is issued for this particular well that requires a pump test or if you wish to request a multiple-well exemption on any other wells using this approved test, you may be denied and will need to perform a new test.

Please contact me if you have any questions.

Sincerely,

Grayson Fish  
971-283-1039  
Groundwater Section

cc: GW Pump Test File  
cc: Certificates Section/Application File