



# Oregon

Tina Kotek, Governor

**Water Resources Department**  
725 Summer St NE, Suite A  
Salem, OR 97301  
(503)986-0900  
Fax (503) 986-0904

October 30, 2023

Bryan Semingson  
1640 NW Cornelius-Scheffin Road  
Cornelius, OR 97113

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 14555	Permit: G 13382 *	WASH0052209	WASH0052209	10/04/2023	APPROVED	Unreas Burden	GROVELAND RD WELL (L

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates the requirements were met under OAR 690-217 based on the inconsistent pump rate; however, the limitations of the currently installed pump relative to the transmissivity of the aquifer indicate it is likely that a new test will yield similar results and therefore the Department has granted an exemption for testing this well on the above listed permit.

Please contact me if you have any questions.

Sincerely,

Gabi Ferreira  
971-375-7623  
Groundwater Section

cc: GW Pump Test File  
cc: Certificates Section/Application File