

Approved:



MEMO

To: Kristopher Byrd, Well Construction Manager
From: Tommy Laird, Well Construction Program Coordinator
Subject: Review of Water Right Application LL-1976
Date: May 21, 2024

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Grayson Fish reviewed the application. Please see Grayson's Groundwater Review and the Well Report.

Applicant's Well #1 (KLAM 11674): Based on a review of the Well Report, Applicant's Well #1 seems to protect the groundwater resource.

The construction of Well #1 may not satisfy hydraulic connection issues.

385/9E-196a RECEIVED

Klamath

NOV 4 1981

WATER RESOURCES DEPT
SALEM, OREGON

E.E. STOREY & SON WELL DRILLING, INC



3847 HOPE STREET - KLAMATH FALLS, OREGON 97601
503/884-3990 or 503/882-1152
CONTRACTOR'S LICENSES - ORE. 74 and 601

JELD-WEN, INC.
3303 LAKEPORT BLVD.
KLAMATH FALLS, OREGON 97601
NE 1/4 NW 1/4 S19 T38S R9E
COLD WATER WELL ON LAKEPORT BLVD, BEHIND PLANT

DAVE
STARTED 9/21/81
COMPLETED 10/7/81

LOG

0	-	5	brown clay topsoil
5	-	9	yellow shale
9	-	15	hard black sandstone
15	-	35	sticky blue clay
35	-	42	blue shale
42	-	76	green shale
76	-	97	hard green shale
97	-	156	hard gray shale
156	-	223	sticky brown clay
223	-	239	hard black basalt
239	-	252	black bubbly basalt
252	-	270	black lava
270	-	320	hard black basalt
320	-	365	broekn black lava
365	-	376	hard brown sandstone
376	-	440	green sticky clay
440	-	448	hard brown shale
448	-	486	green sticky clay
486	-	500	hard brown shale
500	-	565	green sticky clay
565	-	569	hard broekn black chalk rock
569	-	615	broken black basalt
615	-	639	hard black basalt
639	-	674	hard broken black basalt
674	-	785	hard black basalt
785	-	820	hard brown chalk rock
820	-	892	brown clay
892	-	962	gray clay
962	-	994	black shale with streaks of black clay
994	-	1021	hard black basalt
		1003'	taped finished hole depth after test pumping