

Approved:



MEMO

To: Kristopher Byrd, Well Construction and Compliance Section Manager
From: Travis Kelly, Well Construction Compliance Coordinator
Subject: Review of Water Right Application G-19191
Date: February 4, 2022

The attached application was forwarded to the Well Construction and Compliance Section by the Groundwater Section. Phil Marcy reviewed the application. Please see Phil's Groundwater Review.

Applicant's Well #1 (Proposed Well): Applicant's Well #1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of applicant's proposed Well #1 may not satisfy hydraulic connection issues.