



Oregon

Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

May 30, 2024

EUGENE BEYER
10750 EDMUNSON DR SE
SALEM, OR 97317

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 18542	Permit: G 18343 *	MARI0009193	MARI0009193	08/30/1996	REJECTED	Unreas Burden	A WELL

This well was last tested in 1996. ORS 537.772(1): "The owner or operator of a well, except wells used for purposes listed in ORS 537.545 (Exempt uses), shall conduct a pump test at least once every 10 years and report the results of that test to the Water Resources Commission. The owner or operator may conduct the test in conjunction with normal pump service and testing or at any time more convenient to the owner or operator of the well." Since it has been more than 27 years since the last pump test, another pump test is required per ORS 537.772(1).

Since the last pump test, the well was altered. The alteration log (MARI 68554) reported a lower yield (150-200 gpm) than the initial log ("300+" gpm). A new pump test may verify whether the well's hydraulic properties have been changed as a result of the alteration.

The following pump test related materials can be found on our web site at:

- Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>
- A booklet explaining pump tests: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf
- Pump test data forms: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf
- Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>
- Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Travis Brown
971-301-3088
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File