

Approved: 

MEMO

To: Kristopher Byrd, Well Construction and Compliance Section Manager
From: Tommy Laird, Well Construction Compliance Coordinator
Subject: Re-Review of Water Right Application G-19064
Date: May 30, 2024

The attached application was forwarded to the Well Construction and Compliance Section by the Groundwater Section. Travis Brown reviewed the application. Please see Travis' Groundwater Review.

Applicant's Well #1 (Proposed Well): Applicant's Well #1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of applicant's proposed Well #1 may not satisfy hydraulic connection issues.