

Approved: 

MEMO

To: Kristopher Byrd, Well Construction Manager
From: Tommy Laird, Well Construction Program Coordinator
Subject: Review of Water Right Application G-19204
Date: June 14, 2024

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Stacey Garrison and Travis Brown reviewed the application. Please see Stacey's and Travis' Groundwater Review.

Applicant's Well #1 through Well #5 (Proposed): Well #1 through Well #5 are proposed wells, therefore they cannot be reviewed for construction. Construction of these proposed wells shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of these wells, specific attention should be paid to ensure sealing requirements are met and that the wells do not commingle aquifers.

The construction of proposed Well #1 through Well #5 may not satisfy hydraulic connection issues.