



# Oregon

Tina Kotek, Governor

**Water Resources Department**  
725 Summer St NE, Suite A  
Salem, OR 97301  
(503)986-0900  
Fax (503) 986-0904

July 01, 2024

Roger Britt  
56574 Upper Rhea Cr Rd  
Heppner, OR 97836

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 15769	Permit: G 15327 *	MORR0051039	MORR0051039	04/01/2021	REJECTED	None	

The test was rejected for the following reason(s):

- o The pumping rate during the test (65 gpm) was not close enough to the anticipated pumping rate during normal use of the well (0.5 cfs/224 gpm).
- o After pumping stopped, water level measurements were not collected for at least 4 hours or until the well reached 90 percent recovery from the maximum drawdown.

The following pump test related materials can be found on our web site at:

- Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>
- A booklet explaining pump tests: [https://www.oregon.gov/owrd/WRDFormsPDF/pump\\_test.pdf](https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf)
- Pump test data forms: [https://www.oregon.gov/owrd/WRDFormsPDF/pump\\_test\\_coverF.pdf](https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf)
- Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>
- Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Andrew Wentworth  
Groundwater Section

cc: GW Pump Test File  
cc: Certificates Section/Application File