



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

August 06, 2024

ROYCE & KAREN BELCHER
T H BELCHER NURSERY INC
33755 SE BLUFF RD
BORING, OR 97009

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 15349	Permit: G 15155 *	CLAC0056617	CLAC0056617	04/03/2024	APPROVED	Unreas Burden	WELL 1 (L-44585)

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates the requirements were met under OAR 690-217, however; the limitations of the currently installed pump relative to the transmissivity of the aquifer provide little to no drawdown or recovery data useful for ground water resources characterization as was the intent of the rules. It is likely that a new test will yield similar results and therefore the Department has granted an exemption for testing this well on the above listed permit.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Gabi Ferreira
971-375-7623
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File