



Oregon

Tina Kotek, Governor

Water Resources Department

725 Summer St NE, Suite A

Salem, OR 97301

(503)986-0900

Fax (503) 986-0904

September 23, 2024

FERNANDO BENITEZ DIAZ
32123 MYRTLEWOOD LANE
HERMISTON, OR 97838

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 16094	Permit: G 15937 *	UMAT0054883	UMAT0054883	09/15/2020	APPROVED	Unreas Burden	A WELL (L-51321)

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates the requirements were met under OAR 690-217, however; the limitations of the currently installed pump relative to the transmissivity of the aquifer provide little to no drawdown or recovery data useful for ground water resources characterization as was the intent of the rules. It is likely that a new test will yield similar results and therefore the Department has granted an exemption for testing this well on the above listed permit(s).

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Andrew Wentworth
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File