

Approved:



# MEMO

**To:** Kristopher Byrd, Well Construction Manager  
**From:** Tommy Laird, Well Construction Program Coordinator  
**Subject:** Review of Water Right Application G-19278  
**Date:** October 23, 2024

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Mitra Khadka and Travis Brown reviewed the application. Please see Mitra's and Travis' Groundwater Review.

Applicant's Well #1 (Proposed): Well #1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of proposed Well #1 may not satisfy hydraulic connection issues.