



November 26, 2024

MANAGER PAUL MCLAUGHLIN
SPRINGFIELD COUNTRY CLUB
90333 SUNDERMAN ROAD
SPRINGFIELD, OR 97478

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 13489	Permit: G 12735 *	LANE0063460	LANE0063460	05/01/2020	REJECTED	None	WELL 1 (L-13887)
G 13489	Permit: G 12735 *	LANE0063461	LANE0063461	05/01/2020	REJECTED	None	WELL 2 (L-13905)

The test(s) was/were rejected for the following reason(s):

- ☐ The discharge rate was not held constant.
- ☐ The pump was turned off for a portion of the pumping phase.
- ☐ The discharge was not measured at the specified time intervals during the pumping phase of the test.
- ☐ Water levels were not measured to an accuracy of 0.1 feet.
- ☐ Pre-test static water levels or shut in pressures were not measured at the specified intervals.
- ☐ Water levels or shut in pressures were not measured at the specified time intervals during the test.
- ☒ Water levels or shut in pressures were not measured during the recovery phase of the test.
- ☐ Airline measurements are not allowed if the depth to water is less than or equal to 300 feet.
- ☐ Airline or sonic measurements were not verified by an electric tape measurement.
- ☐ Test data and the supporting documentation were not reported on the Department's forms.
- ☐ A graph indicates that the data is probably corrupt.
- ☐ Rising water levels during some or all of the pumping phase of the test indicate that the pumping rate was not held constant or that water-level measurements are inaccurate.

Recovery water levels for Well 1 (LANE 63460) were not measured at the required intervals.

Recovery water levels for Well 2 (LANE 63461) were not measured at all.

The following pump test related materials can be found on our web site at:

Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>
A booklet explaining pump tests: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf
Pump test data forms: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf
Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>
Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Travis Brown
971-301-3088
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File