



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

September 17, 2024

JERRY VESSELLO
DIRECTOR, FACILITIES & OPERATIONS
CHEMEKETA COMM. COLLEGE
PO BOX 14007
SALEM, OR 97309

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 12324	Permit: G 11304 *	MARI0006715	MARI0006715	08/27/2002	REJECTED		WELL 1

The test(s) was/were rejected for the following reason(s):

- ☒ The discharge rate was not held constant.
- ☐ The pump was turned off for a portion of the pumping phase.
- ☐ The discharge was not measured at the specified time intervals during the pumping phase of the test.
- ☐ Water levels were not measured to an accuracy of 0.1 feet.
- ☐ Pre-test static water levels or shut in pressures were not measured at the specified intervals.
- ☐ Water levels or shut in pressures were not measured at the specified time intervals during the test.
- ☐ Water levels or shut in pressures were not measured during the recovery phase of the test.
- ☐ Airline measurements are not allowed if the depth to water is less than or equal to 300 feet.
- ☐ Airline or sonic measurements were not verified by an electric tape measurement.
- ☐ Test data and the supporting documentation were not reported on the Department's forms.
- ☐ A graph indicates that the data is probably corrupt.
- ☐ Rising water levels during some or all of the pumping phase of the test indicate that the pumping rate was not held constant or that water-level measurements are inaccurate.

The test was rejected for the following reason(s):

- o Discharge rate was not held constant.
- o Per OAR 690-217-0025 (3), the pumping phase of the test shall be at least four hours; the pumping phase for this test was only 1 hour.

The following pump test related materials can be found on our web site at:

Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>
A booklet explaining pump tests: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf
Pump test data forms: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf
Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>
Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Stacey Garrison
503-551-0205
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File