

Approved:



MEMO

To: Kristopher Byrd, Well Construction Manager
From: Tommy Laird, Well Construction Program Coordinator
Subject: Review of Water Right Application G-19330
Date: February 26, 2025

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Phillip I. Marcy reviewed the application. Please see Phillip's Groundwater Review.

Applicant's Well #1 (Proposed): Well #1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of proposed Well #1 may not satisfy hydraulic connection issues.