

Approved:



MEMO

To: Kristopher Byrd, Well Construction Manager
From: Tommy Laird, Well Construction Program Coordinator
Subject: Review of Water Right Application G-19339
Date: February 26, 2025

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Gabriela Ferreira and Dennis Orlowski reviewed the application. Please see Gabriela's and Dennis' Groundwater Review.

Applicant's Well #Well 1 (Proposed): Well 1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of proposed Well 1 may not satisfy hydraulic connection issues.