

Approved:



MEMO

To: Kristopher Byrd, Well Construction Manager
From: Tommy Laird, Well Construction Program Coordinator
Subject: Review of Water Right Application G-19409
Date: March 7, 2025

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Gabriela Ferreira reviewed the application. Please see Gabriela's Groundwater Review.

Applicant's Well #1 and Well #2 (Proposed): Well #1 and Well #2 are proposed wells, therefore they cannot be reviewed for construction. Construction of these proposed wells shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of these wells, specific attention should be paid to ensure sealing requirements are met and that the wells do not commingle aquifers.

The construction of proposed Well #1 and Well #2 may not satisfy hydraulic connection issues.