



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

September 30, 2025

JENNIFER ELSON
STEWARDSHIP DIVISION
OREGON PARKS & RECREATION
725 SUMMER ST. NE, SUIT C
SALEM, OR 97301

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 16199	Permit: G 15772 *	WALL0000655	WALL0000655	06/05/2025	APPROVED	0		A WELL (L-95239)

o The pumping rate is close to the maximum authorized rate for the irrigation use on Permit G-15772 for 0.17 cubic feet per second (cfs).

o Commercial use on Permit G-15772 was not developed, therefore this pump test does not apply to the commercial use. A pumping rate with a flow rate approximately 5x greater than this conducted pump test would be required to satisfy any future development of the commercial use.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

James Hootsmans

James Hootsmans
503-871-2378
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File

