



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

October 06, 2025

LIN SHEN KOO
TEMPERANCE HILL VINEYARD
6020 BETHEL HEIGHTS RD NW
SALEM, OR 97304

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 13820	Permit: G 15777 *	POLK0050276	POLK0050276	07/24/2025	APPROVED	0	Unreas Burden	TEMPERANCE HILL

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates the requirements were met under OAR 690-217, however; the limitations of the currently installed pump relative to the transmissivity of the aquifer provide little to no drawdown or recovery data useful for ground water resources characterization as was the intent of the rules. The measured maximum instantaneous rate at the POA was 0.07 cfs according to the COBU; therefore, the water level during the pump test dropped less than 10 feet and recovered instantly. It is likely that a new test will yield similar results and therefore the Department has granted an exemption for testing this well on the above listed permit(s).

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

James Hootsmans

James Hootsmans
503-871-2378
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File