



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

October 22, 2025

John Fournier
Moon Pit LLC
95 SW SCALEHOUSE LOOP #100
Bend, OR 97702

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 13686	Permit: G 12860 *	DESC0009126	DESC0009126		APPROVED	0	Unreas Burden	

OWRD acknowledges the practical and financial burden of fulfilling the pump test requirements on this permit at this time. It should also be noted that this permit states that wells "...shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times." The owner is encouraged to install a dedicated airline or e-tape measuring tube when pump infrastructure is removed for maintenance or replacement so that the well is in compliance with permit conditions.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Joe Kemper
503-437-5305
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File