



November 10, 2025

Mark and Michael Johnson
65757 Courtney Lane
Summerville, OR 97876

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 13720	Permit: G 12653 *	UNIO0000186	UNIO0000186	04/21/2000	REJECTED	3	None	
G 13720	Permit: G 12653 *	UNIO0002451	UNIO0002451	04/21/2000	REJECTED	3	None	

The following problems were noted on at least one of the pump tests listed above:

- Pre-test static water levels or shut in pressures were not measured at the specified intervals.
- Water levels or shut in pressures were not measured during the recovery phase of the test.
- Test data and the supporting documentation were not reported on the Department's forms.

The following pump test related materials can be found on our web site at:

Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>
A booklet explaining pump tests: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf
Pump test data forms: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf
Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>
Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

James Hootsmans

James Hootsmans
503-871-2378
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File