



November 20, 2025

RENE MOORE
CITY ADMINISTRATOR
CITY OF MORO
PO BOX 231
MORO, OR 97039

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 15533	Permit: G 15249 *	SHER0050296	SHER0050296	02/07/2002	APPROVED	2	Unreas Burden	CEMETERY WELL

The following problems were noted on at least one of the pump tests listed above:

- Water levels were not measured and reported with sufficient accuracy and precision.

Although at least one test was approved despite problems, please note that those problems may be grounds for rejecting a test submitted in the future.

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates that there are one or more deficiencies (listed below) related to the requirements for pump tests outlined in OAR 690-217, however; it is likely that any re-testing would constitute an unreasonable burden on the permittee and would provide data of only marginal value in satisfying the intent of the rules.

- o Two hydrographs were provided for the pumping and recovery portions of the pump test. The method (instrument) used to measure the water level during the test is unknown, and no tabular data were provided. Therefore, it is not possible to confirm the accuracy or precision of the measurements for water levels and/or discharge during the test.

Although this test is being approved for this well on the above listed permit(s), it is unlikely that the approval will carry forward onto any new permits or multiple-well exemption requests. If a new permit is issued for this particular well that requires a pump test or if you wish to request a multiple-well exemption on any other wells using this approved test, you may be denied and will need to perform a new test.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Aaron Orr
971-707-1910
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File