



# Oregon

Tina Kotek, Governor

December 17, 2025

**Water Resources Department**  
725 Summer St NE, Suite A  
Salem, OR 97301  
(503)986-0900  
Fax (503) 986-0904

ROBERT LINDELL  
82452 RAIL HOLLOW RD  
DUFUR, OR 97021

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 15299	Permit: G 15094 *	WASC0050922	WASC0050922	09/30/2024	REJECTED	2	None	

The following problems were noted on at least one of the pump tests listed above:

- Water levels were not measured and reported with sufficient accuracy and precision.
- Pre-test static water levels or shut in pressures were not measured at the specified intervals.

The test was rejected for the following reason(s):

- o Pre-test static water levels were not measured at least three times in the hour before pumping began at no less than 20 minutes apart;
- o Water levels were not measured at the specified intervals during the pumping phase;
- o Water level accuracy was > 0.1 ft.

Please note that OWRD is interested in the hydrogeology of this area, so the department is willing to come out to conduct and staff the test themselves.

The following pump test related materials can be found on our web site at:

Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>  
A booklet explaining pump tests: [https://www.oregon.gov/owrd/WRDFormsPDF/pump\\_test.pdf](https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf)  
Pump test data forms: [https://www.oregon.gov/owrd/WRDFormsPDF/pump\\_test\\_coverF.pdf](https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf)  
Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>  
Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Aaron Orr  
971-707-1910

## Groundwater Section

cc: GW Pump Test File  
cc: Certificates Section/Application File