

CLAIM OF BENEFICIAL USE for Surface Water Permits claiming 0.1 cfs or less



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem, Oregon 97301-1266
(503) 986-0900
www.oregon.gov/OWRD

**A fee of \$345 must accompany this form for permits
with priority dates of July 9, 1987, or later.**

Enter the date the priority date of the permit:

MAY 11, 2005

A separate form shall be completed for each permit.

In cases where a permit has been amended through the permit amendment process, a separate claim for the permit amendment is not required. Incorporate the permit amendment into the claim for the permit.

This form is subject to revision. **Begin each new claim** by checking for a new version of this form at:

<https://www.oregon.gov/OWRD/Forms/Pages/default.aspx>

The completion of this form is required by OAR 690-014-0100(1) and 690-014-0110(4).

Please type or print in dark ink. If this form is found to contain errors or omissions, it may be returned to you. **Every item must have a response.** If any requested information does not apply to the claim, insert "NA." **Do not delete or alter any section of this form unless directed by the form.** The Department may require the submittal of additional information from any water user or authorized agent.

"Section 8" of this form is intended to aid in the completion of this form and should not be submitted.

If you have questions regarding the completion of this form, please call 503-986-0900.

The Department has a Reimbursement Authority program that allows it to enter into a voluntary agreement with an applicant for expedited services. Applicants interested in an estimate of the cost and timeline for expedited processing must submit a Reimbursement Authority Estimate Application and required fee. The form and additional information on this program see:

<https://www.oregon.gov/OWRD/programs/WaterRights/RA/Pages/default.aspx>

Received
JUN 08 2026
OWRD

SECTION 1 GENERAL INFORMATION

1. File Information:

APPLICATION # S-86302	PERMIT # (IF APPLICABLE) S-54321	PERMIT AMENDMENT # (IF APPLICABLE) NA
---------------------------------	--	---

2. Property Owner (current owner information):

APPLICANT/BUSINESS NAME BITNER FAMILY REVOCABLE TRUST		PHONE NO.	ADDITIONAL CONTACT No.
ADDRESS 5415 SUNSHINE ROAD			
CITY ROSEBURG	STATE OR	ZIP 97470	E-MAIL

If the current property owner is not the permit holder of record, it is recommended that an assignment be filed with the Department. ***Each permit holder of record must sign this form.***

3. Permit holder of record (this may, or may not, be the current property owner):

PERMIT HOLDER OF RECORD JERRY BITNER			
ADDRESS 2703 WOLKIN COVE			
CITY ROUND ROCK	STATE TX	ZIP 78681	

ADDITIONAL PERMIT HOLDER OF RECORD NA			
ADDRESS			
CITY	STATE	ZIP	

4. Date of Site Inspection:

5-20-2026

5. Person(s) interviewed and description of their association with the project:

NAME	DATE	ASSOCIATION WITH THE PROJECT
GEORGE SANDBERG	5-20-2026	BROTHER OF LANDOWNER

6. County:

DOUGLAS

7. If any property described in the place of use of the permit final order is excluded from this report, identify the owner of record for that property (ORS 537.230(5)):


OWNER OF RECORD NA				Received JUN 08 2026
ADDRESS				
CITY	STATE	ZIP		OWRD

Add additional tables for owners of record as needed

**SECTION 2
SIGNATURES**

CWRE Statement, Seal and Signature

The facts contained in this Claim of Beneficial Use are true and correct to the best of my knowledge.



CWRE NAME NATHAN REED		PHONE NO. 541-784-7191	ADDITIONAL CONTACT NO. NA
ADDRESS 157 WEST BODIE STREET			
CITY ROSEBURG	STATE OR	ZIP 97471	E-MAIL nreed68@hotmail.com

Permit Holder(s) of Record Signature or Acknowledgement

Each permit holder of record must sign this form in the space provided below.

The facts contained in this Claim of Beneficial Use are true and correct to the best of my knowledge. I request that the Department issue a water right certificate.

SIGNATURE	PRINT OR TYPE NAME	TITLE	DATE
<i>Jerry Bitner</i> <i>Bitner Family Revocable Trust</i>	Jerry Bitner	Land Owner	6-2-2026
			Received
			JUN 08 2026
			OWRD

**SECTION 3
CLAIM DESCRIPTION**

OWRD

1. POD source and, if from surface water, the tributary:

POD NAME OR NUMBER	SOURCE	TRIBUTARY
POD	NORTH UMPQUA RIVER	UMPQUA RIVER

2. Developed use(s), period of use, and rate for each use:

POD NAME OR NUMBER	USES	IF IRRIGATION, LIST CROP TYPE	SEASON OR MONTHS WHEN WATER WAS USED	ACTUAL RATE OR VOLUME USED (CFS, GPM, OR AF)
POD	DOMESTIC ONE	NA	YEAR ROUND	0.005 CFS
POD	IRRIGATION		MAR 1 – OCT 31	0.012 CFS
Total Quantity of Water Used				0.017 CFS

3. Provide a general narrative description of the distribution works. This description must trace the water system from each point of diversion to the place of use:

A 1-1/2 Hp centrifugal pump draws water from fish screen intake 1-1/4" ABS pipe and out to 1-1/4" buried PVC along the west property line. Hose bib risers are spaced 40 feet along the main line. Garden Hose and Rainbird lawn sprinkler used for irrigation. Domestic is a fish cleaning sink station attached to the garage.

Reminder: The map associated with this claim must identify the location of the point(s) of diversion, Donation Land Claims (DLC), Government Lots (GLot), and Quarter-Quarters (QQ).

4. Variations:

Was the use developed differently from what was authorized by the permit, permit amendment final order, or extension final order? If yes, describe below. **YES**

(e.g. "The permit allowed three points of diversion. The water user only developed one of the points." or "The permit allowed 40.0 acres of irrigation. The water user only developed 10.0 acres.")

The permit allowed 1.0 acres of irrigation. The water user can only develop 0.8 acres due to driveway, garage and shop building.

5. Claim Summary:

POD / POA NAME OR #	MAXIMUM RATE AUTHORIZED	CALCULATED THEORETICAL RATE BASED ON SYSTEM	AMOUNT OF WATER MEASURED	USE	# OF ACRES ALLOWED	# OF ACRES DEVELOPED
POD	0.017 CFS	0.015 CFS	Not Meas.	DOM/IRR	1.0	0.8

**SECTION 4
SYSTEM DESCRIPTION**

Are there multiple PODs?

NO

If "YES" you will need to copy and complete a separate Section 4 for each POD.

POD Name or Number this section describes (only needed if there is more than one):

A. Place of Use

Attach Claim of Beneficial Use map.

Reminder: The map associated with this claim must identify Donation Land Claims (DLC), Government Lots (Gov Lot), Quarter-Quarters (QQ), and if for irrigation, the number of acres irrigated within each projected DLC, Gov Lot, and QQ.

B. Diversion and Delivery System Information

Provide the following information concerning the diversion and delivery system. Information provided must describe the equipment used to transport and apply the water from the point of diversion to the place of use.

1. Is a pump used?

YES

If "NO" items 2 through item 5 may be deleted.

2. Pump Information:

MANUFACTURER	MODEL	SERIAL NUMBER	TYPE (CENTRIFUGAL, TURBINE OR SUBMERSIBLE)
A.O. Smith	ST1152	SE05	CENTRIFUGAL

3. Theoretical Pump Capacity:

HORSEPOWER	OPERATING PSI	LIFT FROM SOURCE TO PUMP	LIFT FROM PUMP TO PLACE OF USE	TOTAL PUMP OUTPUT (IN CFS)
1.5	50	15	35	0.05

4. Provide pump calculations:

50 psi = 139.7 feet; $Q = (Hp \times eff) / (\text{Sum Total Head}) = (1.5 \times 6.61) / (139.7 + 15 + 35) = 0.05 \text{ cfs}$

5. Measured Pump Capacity (using meter if meter was present and system was operating):

INITIAL METER READING	ENDING METER READING	DURATION OF TIME OBSERVED	TOTAL PUMP OUTPUT (IN CFS)
NA			

Reminder: For pump calculations use the reference information at the end of this document.

Received

JUN 08 2026

6. Sprinkler Information:

SIZE	OPERATING PSI	SPRINKLER OUTPUT (GPM)	TOTAL NUMBER OF SPRINKLERS	MAXIMUM NUMBER USED	TOTAL SPRINKLER OUTPUT (CFS)
RB PSRLSP	50	3.3	2	2	0.015

Reminder: For sprinkler output determination use the reference information at the end of this document.

7. Drip Emitter Information:

SIZE	OPERATING PSI	EMITTER OUTPUT (GPM)	TOTAL NUMBER OF EMITTERS	MAXIMUM NUMBER USED	TOTAL EMITTER OUTPUT (CFS)
NA					

8. Drip Tape Information:

DRIPPER SPACING IN INCHES	GPM PER 100 FEET	TOTAL LENGTH OF TAPE	MAXIMUM LENGTH OF TAPE USED	TOTAL TAPE OUTPUT (CFS)	ADDITIONAL INFORMATION
NA					

C. Storage

1. Does the distribution system include in-system storage (e.g. storage tank, bulge in system / reservoir)?

NO

D. Gravity Flow Pipe

(THE DEPARTMENT TYPICALLY USES THE HAZEN-WILLIAM'S FORMULA FOR A GRAVITY FLOW PIPE SYSTEM)

1. Does the system involve a gravity flow pipe?

NO

E. Gravity Flow Canal or Ditch

(THE DEPARTMENT TYPICALLY USES MANNING'S FORMULA FOR CANALS AND DITCHES)

1. Is a gravity flow canal or ditch used to convey the water as part of the distribution system?

NO

F. Additional notes or comments related to the system:

Received
JUN 08 2026

OWRD

SECTION 5 CONDITIONS

All conditions contained in the permit, permit amendment, or any extension final order shall be addressed. Reports that do not address all performance related conditions will be returned.

1. Time Limits:

Permits and any extension final orders contain any or all of the following dates: the date when the actual construction work was to begin, the date when the construction was to be completed, and the date when the complete application of water to the proposed use was to be completed. These dates may be referred to as ABC dates. Describe how the water user has complied with each of the development timelines established in the permit or extension final order:

	DATE FROM PERMIT	DATE ACCOMPLISHED*	DESCRIPTION OF ACTIONS TAKEN BY WATER USER TO COMPLY WITH THE TIME LIMITS
ISSUANCE DATE	7-21-2006		
BEGIN CONSTRUCTION (A)		7/2006	TRENCHED AND PIPED MAINLINE
COMPLETE CONSTRUCTION (B)		6/2020	FISH SCREEN & SINK PUT IN PLACE
COMPLETE APPLICATION OF WATER (C)	10-1-2021	6/2020	BENEFICALLY USING WATER FOR DOMESTIC & IRRIGATION.

* MUST BE WITHIN PERIOD BETWEEN PERMIT OR ANY EXTENSION FINAL ORDER ISSUANCE AND THE DATE TO COMPLETELY APPLY WATER

2. Is there an extension final order(s)? YES

If "NO", items a and b relating to this section may be deleted.

a. Did the Extension Final Order require the submittal of Progress Reports? NO

3. Measurement Conditions:

a. Does the permit, permit amendment, or any extension final order require the installation of a meter or approved measuring device? NO

4. Recording and reporting conditions:

a. Is the water user required to report the water use to the Department? NO

5. Fish Screening:

a. Are any points of diversion required to be screened to prevent fish from entering the point of diversion? YES

If "NO", items b through e relating to this section may be deleted.

Reminder: If fish screening devices were required, the COBU map must indicate their location in relation to the point of diversion.

b. Has the fish screening been installed? YES

Received
JUN 08 2026

OWRD

c. When was the fish screening installed?

DATE	BY WHOM
6/2020	GEORGE SANDBERG

Reminder: If the permit or transfer final order was issued on or after February 1, 2011, the fish screen is required to be approved by the Oregon Department of Fish and Wildlife regardless of the rate of diversion.

d. If the diversion **involves a pump** *and* the **total** diversion rate of all rights at the point of diversion is less than 225 gpm (0.5 cfs):

- Has the self-certification form previously been submitted to the Department? **NO**

If not, go to <https://www.oregon.gov/OWRD/Forms/Pages/default.aspx> complete and attach a copy of the 'ODFW Small Pump Screen Self Certification' form to this claim, and send a copy of it to the Oregon Department of Fish and Wildlife (ODFW).

Reminder: Failure to submit evidence of a timely installed fish screen may result in an unfavorable determination. The ODFW self certification form needs to have been previously submitted or be attached to this form.

e. If the diversion does **not involve a pump** *or* the **total** diversion rate of all rights at the point of diversion is 225 gpm (0.5 cfs) or greater:

- Has the ODFW approval been previously submitted? **NA**
- If not, contact and work with ODFW to ensure compliance. To demonstrate compliance, provide signed documentation from ODFW. A form is available at <https://www.oregon.gov/OWRD/Forms/Pages/default.aspx>

Reminder: Failure to submit evidence of a timely installed fish screen may result in an unfavorable determination. In order to receive a favorable approval, the ODFW/WRD "Fish Screen Inspection" form needs to have been previously submitted or be attached to this form.

6. By-pass Devices:

a. Are any points of diversion required to have a by-pass device to prevent fish from entering the point of diversion? **NO**

Received
JUN 08 2026
OWRD

7. Other conditions required by permit, permit amendment final order, or extension final order:

- a. Was the water user required to restore the riparian area if it was disturbed? **YES**
- b. Other conditions? **NO**

If "YES" to any of the above, identify the condition and describe the water user's actions to comply with the condition(s):

7.a. Riparian disturbance limited to maintenance/access path.

**SECTION 6
ATTACHMENTS**

Provide a list of any additional documents you are attaching to this report:

ATTACHMENT NAME	DESCRIPTION
ODFW LETTER	FISH SCREEN SIGN OFF
CBU MAP	FINAL PROOF SURVEY

Received
JUN 08 2026
OWRD



Oregon

John A. Kitzhaber, MD, Governor

Department of Fish and Wildlife

Rogue Watershed District Office

1495 East Gregory Road

Central Point OR 97502

(541) 826-8774

(541) 826-8776

dfw.state.or.us

September 12, 2016



Jerry Bitner
2703 Wolkin Cove
Round Rock, TX 78681

Dear Jerry,

Regarding OWRD water right permit S-54321 (application S-86302), ODFW is satisfied that the condition for fish screening at the point-of-diversion has been met, and has determined that a fish bypass device is not required.

Sincerely,

Rich Kilbane
SW Field Coordinator
Fish Screening and Passage Program

(541) 826-8774 ext. 243

Received

JUN 08 2026

OWRD

