



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

June 18, 2026

MICHAEL E GERIG
GERIG, ANN M
1048 69TH AVE NE
SALEM, OR 97317

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 16793	Permit: G 16283 *	MARI0061424	MARI0061424	09/25/2008	APPROVED	0		

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates that there are one or more deficiencies (listed below) related to the requirements for pump tests outlined in OAR 690-217, however; it is likely that any re-testing would constitute an unreasonable burden on the permittee and would provide data of only marginal value in satisfying the intent of the rules.

- o Water levels were not measured at the specified intervals as outlined by rule.

Additional well(s) listed on this/these permit(s) may be eligible for a multiple well exemption if they are under the same ownership, within five miles, and drawing water from the same aquifer as the tested well OAR 690-217-0020(3). A request for a multiple well exemption must be made in writing and the form can be found on the Department's website.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

James Hootsmans

James Hootsmans
503-871-2378
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File