

Approved:

Tony Janicek

Digitally signed by Tony Janicek
DN: OU=Dam Safety Program, O=Oregon Water
Resources Department, CN=Tony Janicek, E=
Tony.M.Janicek@water.oregon.gov
Reason: I am approving this document
Location:
Date: 2026.07.08 12:04:13-07'00'
Foxit PDF Editor Version: 12.1.9

MEMO

To: Tony Janicek, Interim Well Construction Manager
From: Tommy Laird, Well Construction Compliance Coordinator
Subject: Review of Water Right Application G-19491
Date: July 8, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Steve Ahlquist reviewed the application. Please see Steve's Groundwater Review.

Applicant's Well #N1 through Well #N8, Well #E1, and Well #S1 through Well #S3 (Proposed): Wells N1 through N8, E1, and S1 through S3 are proposed wells, therefore they cannot be reviewed for construction. Construction of these proposed wells shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of these wells, specific attention should be paid to ensure sealing requirements are met and that the wells do not commingle aquifers.

The construction of proposed wells N1 through N8, E1, and S1 through S3 may not satisfy hydraulic connection issues to surface water.